



HENDLEY ES LEAD WATER TEST RESULTS



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002802	6/19/2017	6/19/2018	Ground Floor	Cooler	In cafeteria	WF-62017-002802	10/23/2017	FT-FY18-102017-002802-A	< 1	FT-FY18-102017-002802-B	< 1
WS- 002804	10/11/2017	10/11/2018	Ground Floor	Combo Faucet	In classroom G11	WF-102017-002804	10/23/2017	FT-FY18-102017-002804-A	1	FT-FY18-102017-002804-B	< 1
WS- 002806	10/11/2017	10/11/2018	Ground Floor	Combo Faucet	In classroom G13	WF-102017-002806	10/23/2017	FT-FY18-102017-002806-A	< 1	FT-FY18-102017-002806-B	< 1
WS- 002809	6/19/2017	6/19/2018	1	Combo Fountain	In classroom 110	WF-62017-002809	10/23/2017	FT-FY18-102017-002809-A	< 1	FT-FY18-102017-002809-B	< 1
WS- 002813	6/19/2017	6/19/2018	1	Combo Fountain	In classroom 107	WF-62017-002813	10/23/2017	FT-FY18-102017-002813-A	< 1	FT-FY18-102017-002813-B	< 1
WS- 002814	6/19/2017	6/19/2018	1	Break Room	In break room 105	WF-62017-002814	10/23/2017	FT-FY18-102017-002814-A	< 1	FT-FY18-102017-002814-B	< 1
WS- 002820	6/19/2017	6/19/2018	1	Cooler	In hallway adjacent to resource room 109	WF-62017-002820	10/23/2017	FT-FY18-102017-002820-A	< 1	FT-FY18-102017-002820-B	< 1
WS- 002824	6/19/2017	6/19/2018	2	Cooler	In hallway adjacent to room 201	WF-62017-002824	10/23/2017	FT-FY18-102017-002824-A	< 1	FT-FY18-102017-002824-B	< 1
WS- 002825	6/19/2017	6/19/2018	3	Cooler	In hallway adjacent to girls' restroom	WF-62017-002825	10/23/2017	FT-FY18-102017-002825-A	< 1	FT-FY18-102017-002825-B	< 1
WS- 002827	6/19/2017	6/19/2018	3	Cooler	In hallway adjacent to boys' restroom	WF-62017-002827	10/23/2017	FT-FY18-102017-002827-A	< 1	FT-FY18-102017-002827-B	< 1
WS- 002833	10/11/2017	10/11/2018	Ground Floor	Combo Faucet	Annex, in classroom G16	WF-102017-002833	10/23/2017	FT-FY18-102017-002833-A	< 1	FT-FY18-102017-002833-B	< 1
WS- 002837	6/19/2017	6/19/2018	Ground Floor	Combo Fountain	Annex, in music room G15	WF-62017-002837	10/23/2017	FT-FY18-102017-002837-A	< 1	FT-FY18-102017-002837-B	< 1
WS- 002839	10/11/2017	10/11/2018	1	Combo Faucet	Annex, in classroom 118 first clockwise from entry door	WF-102017-002839	10/23/2017	FT-FY18-102017-002839-A	1.9	FT-FY18-102017-002839-B	< 1

Food Prep Sink

Greater than 5 ppb - Devices Requiring Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002800	Ground Floor	Food Prep Sink	In kitchen on north wall	10/23/2017	FT-FY18-102017-002800-A	6.1	FT-FY18-102017-002800-B	< 1