



# Ludlow Taylor ES Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003272	10/10/2017	10/10/2018	1	Classroom Faucet	In classroom 105	WF-102017-003272	10/25/2017	FT-FY18-102017-003272-A	< 1	FT-FY18-102017-003272-B	< 1
WS-003274	10/10/2017	10/10/2018	1	Combo Faucet	In classroom 105	WF-102017-003274	10/25/2017	FT-FY18-102017-003274-A	< 1	FT-FY18-102017-003274-B	< 1
WS-003275	6/27/2017	6/27/2018	1	Cooler	In hallway adjacent to stairwell B	WF-62017-003275	10/25/2017	FT-FY18-102017-003275-A	< 1	FT-FY18-102017-003275-B	< 1
WS-003277	10/10/2017	10/10/2018	1	Classroom Faucet	In classroom 101	WF-102017-003277	10/25/2017	FT-FY18-102017-003277-A	< 1	FT-FY18-102017-003277-B	< 1
WS-003279	6/27/2017	6/27/2018	1	Combo Fountain	In classroom 101	WF-62017-003279	10/25/2017	FT-FY18-102017-003279-A	< 1	FT-FY18-102017-003279-B	< 1
WS-003281	6/27/2017	6/27/2018	1	Combo Fountain	In classroom 100	WF-62017-003281	10/25/2017	FT-FY18-102017-003281-A	< 1	FT-FY18-102017-003281-B	< 1
WS-003286	10/10/2017	10/10/2018	1	Classroom Faucet	In classroom 104	WF-102017-003286	10/25/2017	FT-FY18-102017-003286-A	< 1	FT-FY18-102017-003286-B	< 1
WS-003287	10/10/2017	10/10/2018	1	Combo Faucet	In classroom 104	WF-102017-003287	10/25/2017	FT-FY18-102017-003287-A	< 1	FT-FY18-102017-003287-B	< 1
WS-003288	6/27/2017	6/27/2018	1	Combo Fountain	In classroom 104	WF-62017-003288	10/25/2017	FT-FY18-102017-003288-A	< 1	FT-FY18-102017-003288-B	< 1
WS-003289	10/10/2017	10/10/2018	1	Classroom Faucet	In classroom 106	WF-102017-003289	10/25/2017	FT-FY18-102017-003289-A	< 1	FT-FY18-102017-003289-B	< 1
WS-003293	6/27/2017	6/27/2018	1	Combo Fountain	In bathroom in room 108	WF-62017-003293	10/25/2017	FT-FY18-102017-003293-A	< 1	FT-FY18-102017-003293-B	< 1
WS-003295	6/27/2017	6/27/2018	1	Cooler	In hallway adjacent to stairwell A	WF-62017-003295	10/25/2017	FT-FY18-102017-003295-A	< 1	FT-FY18-102017-003295-B	< 1
WS-003304	6/27/2017	6/27/2018	1	Cooler	In hallway adjacent to janitor closet	WF-62017-003304	10/25/2017	FT-FY18-102017-003304-A	< 1	FT-FY18-102017-003304-B	< 1
WS-003312	6/27/2017	6/27/2018	2	Combo Fountain	In classroom 200	WF-62017-003312	10/25/2017	FT-FY18-102017-003312-A	< 1	FT-FY18-102017-003312-B	< 1
WS-003315	6/27/2017	6/27/2018	2	Combo Fountain	In classroom 200	WF-62017-003315	10/25/2017	FT-FY18-102017-003315-A	< 1	FT-FY18-102017-003315-B	< 1
WS-003320	10/10/2017	10/10/2018	2	Combo Faucet	In classroom 206	WF-102017-003320	10/25/2017	FT-FY18-102017-003320-A	< 1	FT-FY18-102017-003320-B	< 1
WS-003332	6/27/2017	6/27/2018	2	Cooler	In hallway adjacent to room 219	WF-62017-003332	10/25/2017	FT-FY18-102017-003332-A	< 1	FT-FY18-102017-003332-B	< 1
WS-003336	10/10/2017	10/10/2018	2	Combo Faucet	In classroom 217	WF-102017-003336	10/25/2017	FT-FY18-102017-003336-A	< 1	FT-FY18-102017-003336-B	< 1
WS-003342	10/10/2017	10/10/2018	3	Combo Faucet	In classroom 301	WF-102017-003342	10/25/2017	FT-FY18-102017-003342-A	< 1	FT-FY18-102017-003342-B	< 1
WS-003343	6/27/2017	6/27/2018	3	Combo Fountain	In classroom 301	WF-62017-003343	10/25/2017	FT-FY18-102017-003343-A	< 1	FT-FY18-102017-003343-B	< 1
WS-003345	6/27/2017	6/27/2018	3	Cooler	In hallway adjacent to stairwell B	WF-62017-003345	10/25/2017	FT-FY18-102017-003345-A	< 1	FT-FY18-102017-003345-B	< 1
WS-003346	10/10/2017	10/10/2018	3	Combo Faucet	In classroom 304	WF-102017-003346	10/25/2017	FT-FY18-102017-003346-A	1.1	FT-FY18-102017-003346-B	< 1
WS-003350	10/10/2017	10/10/2018	3	Combo Faucet	In classroom 325	WF-102017-003350	10/25/2017	FT-FY18-102017-003350-A	< 1	FT-FY18-102017-003350-B	< 1
WS-003353	6/27/2017	6/27/2018	3	Combo Fountain	In classroom 323	WF-62017-003353	10/25/2017	FT-FY18-102017-003353-A	< 1	FT-FY18-102017-003353-B	< 1
WS-003354	6/27/2017	6/27/2018	3	Cooler	In hallway adjacent to stairwell A	WF-62017-003354	10/25/2017	FT-FY18-102017-003354-A	< 1	FT-FY18-102017-003354-B	< 1
WS-003355	6/27/2017	6/27/2018	3	Cooler	In hallway adjacent to stairwell A	WF-62017-003355	10/25/2017	FT-FY18-102017-003355-A	< 1	FT-FY18-102017-003355-B	< 1
WS-003357	6/27/2017	6/27/2018	3	Combo Fountain	In classroom 321	WF-62017-003357	10/25/2017	FT-FY18-102017-003357-A	< 1	FT-FY18-102017-003357-B	< 1
WS-003360	10/10/2017	10/10/2018	3	Combo Faucet	In classroom 307	WF-102017-003360	10/25/2017	FT-FY18-102017-003360-A	< 1	FT-FY18-102017-003360-B	< 1
WS-003361	6/27/2017	6/27/2018	3	Combo Fountain	In classroom 307	WF-62017-003361	10/25/2017	FT-FY18-102017-003361-A	< 1	FT-FY18-102017-003361-B	< 1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003307	1	Food Prep Sink	In kitchen on east wall	10/25/2017	FT-FY18-102017-003307-A	< 1	FT-FY18-102017-003307-B	< 1