



KING ES LEAD WATER TEST RESULTS



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008504	5/25/2017	5/25/2018	1	Cooler	In gym/cafeteria	WF-52017-008504	10/23/2017	FT-FY18-102017-008504-A	< 1	FT-FY18-102017-008504-B	< 1
WS- 008510	5/25/2017	5/25/2018	1	Cooler	In hallway adjacent to girls' restroom	WF-52017-008510	10/23/2017	FT-FY18-102017-008510-A	< 1	FT-FY18-102017-008510-B	< 1
WS- 008513	10/9/2017	10/9/2018	1	Classroom Faucet	In classroom 113	WF-102017-008513	10/23/2017	FT-FY18-102017-008513-A	< 1	FT-FY18-102017-008513-B	< 1
WS- 008515	10/9/2017	10/9/2018	1	Classroom Faucet	In classroom 116	WF-102017-008515	10/23/2017	FT-FY18-102017-008515-A	< 1	FT-FY18-102017-008515-B	< 1
WS- 008521	5/25/2017	5/25/2018	2	Cooler	In hallway adjacent to room 208	WF-52017-008521	10/23/2017	FT-FY18-102017-008521-A	< 1	FT-FY18-102017-008521-B	< 1
WS- 008525	5/25/2017	5/25/2018	2	Cooler	In hallway adjacent to boys' restroom 206	WF-52017-008525	10/23/2017	FT-FY18-102017-008525-A	< 1	FT-FY18-102017-008525-B	< 1
WS- 008535	5/25/2017	5/25/2018	3	Cooler	In hallway adjacent to room 307	WF-52017-008535	10/23/2017	FT-FY18-102017-008535-A	< 1	FT-FY18-102017-008535-B	< 1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008502	1	Food Prep Sink	In kitchen second clockwise from entry door	10/23/2017	FT-FY18-102017-008502-A	< 1	FT-FY18-102017-008502-B	< 1	
WS- 008503	1	Food Prep Sink	In kitchen third clockwise from entry door	10/23/2017	FT-FY18-102017-008503-A	< 1	FT-FY18-102017-008503-B	< 1	