



PAYNE ES LEAD WATER TEST RESULTS



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000115	5/3/2017	5/3/2018	1	Cooler	In hallway adjacent to restaurant	Right Low	WF-52017-000115	10/23/2017	FT-FY18-102017-000115-A	< 1	FT-FY18-102017-000115-B	< 1
WS-000116	5/3/2017	5/3/2018	1	Bottle Filler	In hallway adjacent to restaurant (bottle filler)	Left High	WF-52017-000116	10/23/2017	FT-FY18-102017-000116-A	< 1	FT-FY18-102017-000116-B	< 1
WS-000117	5/3/2017	5/3/2018	1	Cooler	In hallway adjacent to restaurant	Left Low	WF-52017-000117	10/23/2017	FT-FY18-102017-000117-A	< 1	FT-FY18-102017-000117-B	< 1
WS-000125	5/4/2017	5/4/2018	1	Combo Fountain	In classroom 131	Right	WF-52017-000125	10/23/2017	FT-FY18-102017-000125-A	< 1	FT-FY18-102017-000125-B	< 1
WS-000131	5/4/2017	5/4/2018	1	Health Suite	In health suite 129A	Left	WF-52017-000131	10/23/2017	FT-FY18-102017-000131-A	< 1	FT-FY18-102017-000131-B	< 1
WS-000133	5/4/2017	5/4/2018	1	Combo Fountain	In health suite 129A	Right	WF-52017-000133	10/23/2017	FT-FY18-102017-000133-A	< 1	FT-FY18-102017-000133-B	< 1
WS-000134	10/10/2017	10/10/2018	1	Combo Faucet	In classroom 161	Left Low	WF-102017-000134	10/23/2017	FT-FY18-102017-000134-A	< 1	FT-FY18-102017-000134-B	< 1
WS-000137	5/4/2017	5/4/2018	1	Combo Fountain	In classroom 161	Left Low	WF-52017-000137	10/23/2017	FT-FY18-102017-000137-A	< 1	FT-FY18-102017-000137-B	< 1
WS-000142	10/10/2017	10/10/2018	1	Classroom Faucet	In classroom 190	Left High	WF-102017-000142	10/23/2017	FT-FY18-102017-000142-A	< 1	FT-FY18-102017-000142-B	< 1
WS-000144	10/10/2017	10/10/2018	1	Combo Faucet	In classroom 168	Left Low	WF-102017-000144	10/23/2017	FT-FY18-102017-000144-A	1.6	FT-FY18-102017-000144-B	< 1
WS-000146	5/4/2017	5/4/2018	1	Combo Fountain	In classroom 168	Left Low	WF-52017-000146	10/23/2017	FT-FY18-102017-000146-A	< 1	FT-FY18-102017-000146-B	< 1
WS-000150	10/10/2017	10/10/2018	1	Combo Faucet	In classroom 187	Right Low	WF-102017-000150	10/23/2017	FT-FY18-102017-000150-A	< 1	FT-FY18-102017-000150-B	< 1
WS-000156	10/10/2017	10/10/2018	1	Combo Faucet	In classroom 184	Right Low	WF-102017-000156	10/23/2017	FT-FY18-102017-000156-A	4	FT-FY18-102017-000156-B	< 1
WS-000158	5/4/2017	5/4/2018	1	Combo Fountain	In classroom 184	Right Low	WF-52017-000158	10/23/2017	FT-FY18-102017-000158-A	< 1	FT-FY18-102017-000158-B	< 1
WS-000169	5/3/2017	5/3/2018	1	Cooler	In hallway between rooms 180 and 181	Right Low	WF-52017-000169	10/23/2017	FT-FY18-102017-000169-A	< 1	FT-FY18-102017-000169-B	< 1
WS-000178	10/10/2017	10/10/2018	2	Combo Faucet	In classroom 205	Left	WF-102017-000178	10/23/2017	FT-FY18-102017-000178-A	< 1	FT-FY18-102017-000178-B	< 1
WS-000180	5/4/2017	5/4/2018	2	Combo Fountain	In classroom 205	Right	WF-52017-000180	10/23/2017	FT-FY18-102017-000180-A	< 1	FT-FY18-102017-000180-B	< 1
WS-000181	5/3/2017	5/3/2018	2	Cooler	In classroom 204	Right Low	WF-52017-000181	10/23/2017	FT-FY18-102017-000181-A	< 1	FT-FY18-102017-000181-B	< 1
WS-000191	5/4/2017	5/4/2018	2	Combo Fountain	In classroom 207	Right	WF-52017-000191	10/23/2017	FT-FY18-102017-000191-A	< 1	FT-FY18-102017-000191-B	< 1
WS-000194	5/4/2017	5/4/2018	3	Cooler	In hallway adjacent to girls' restroom	Right Low	WF-52017-000194	10/23/2017	FT-FY18-102017-000194-A	< 1	FT-FY18-102017-000194-B	< 1
WS-000209	5/3/2017	5/3/2018	2	Cooler	In hallway adjacent to room 243	Left Low	WF-52017-000209	10/23/2017	FT-FY18-102017-000209-A	< 1	FT-FY18-102017-000209-B	< 1
WS-000222	5/3/2017	5/3/2018	2	Cooler	In hallway adjacent to room 233	Left Low	WF-52017-000222	10/23/2017	FT-FY18-102017-000222-A	< 1	FT-FY18-102017-000222-B	< 1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location		Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)		
WS-000111	1	Food Prep Sink	In kitchen sixth clockwise from entry door	Right	10/23/2017	FT-FY18-102017-000111-A	< 1	FT-FY18-102017-000111-B	< 1		