



Peabody ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009537	10/9/2017	10/9/2018	1	Combo Faucet	In classroom 103	WF-102017-009537	10/25/2017	FT-FY18-102017-009537-A	< 1	FT-FY18-102017-009537-B	< 1
WS- 009539	10/9/2017	10/9/2018	1	Combo Faucet	In classroom 104	WF-102017-009539	10/25/2017	FT-FY18-102017-009539-A	< 1	FT-FY18-102017-009539-B	< 1
WS- 009543	6/27/2017	6/27/2018	1	Combo Fountain	In classroom 106	WF-62017-009543	10/25/2017	FT-FY18-102017-009543-A	< 1	FT-FY18-102017-009543-B	< 1
WS- 009546	6/27/2017	6/27/2018	2	Health Suite	In health suite 202B	WF-62017-009546	10/25/2017	FT-FY18-102017-009546-A	< 1	FT-FY18-102017-009546-B	< 1
WS- 009549	6/27/2017	6/27/2018	2	Combo Fountain	In classroom 206	WF-62017-009549	10/25/2017	FT-FY18-102017-009549-A	< 1	FT-FY18-102017-009549-B	< 1
WS- 009554	10/9/2017	10/9/2018	3	Combo Faucet	In classroom 307	WF-102017-009554	10/25/2017	FT-FY18-102017-009554-A	< 1	FT-FY18-102017-009554-B	< 1
WS- 009556	6/27/2017	6/27/2018	3	Combo Fountain	In classroom 303	WF-62017-009556	10/25/2017	FT-FY18-102017-009556-A	< 1	FT-FY18-102017-009556-B	< 1
WS- 009557	10/9/2017	10/9/2018	3	Combo Faucet	In classroom 303	WF-102017-009557	10/25/2017	FT-FY18-102017-009557-A	< 1	FT-FY18-102017-009557-B	< 1
WS- 009562	10/9/2017	10/9/2018	4	Classroom Faucet	In library	WF-102017-009562	10/25/2017	FT-FY18-102017-009562-A	< 1	FT-FY18-102017-009562-B	< 1
WS- 009563	10/9/2017	10/9/2018	2	Combo Faucet	In classroom 204 Left	WF-102017-009563	10/25/2017	FT-FY18-102017-009563-A	< 1	FT-FY18-102017-009563-B	< 1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009533	Basement	Food Prep Sink	In kitchen Left	10/25/2017	FT-FY18-102017-009533-A	< 1	FT-FY18-102017-009533-B	< 1