



Randle Highlands ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation													
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004143	6/9/2017	6/9/2018	2	Cooler	In hallway adjacent to 2214	Right	Low	WF-62017-004143	10/27/2017	FT-FY18-102017-004143-A	<1	FT-FY18-102017-004143-B	<1
WS-004150	6/9/2017	6/9/2018	1	Cooler	In classroom 2109 connecting hallway	Left	High	WF-62017-004150	10/27/2017	FT-FY18-102017-004150-A	<1	FT-FY18-102017-004150-B	<1
WS-004151	6/9/2017	6/9/2018	1	Cooler	In classroom 2109 connecting hallway	Right	Low	WF-62017-004151	10/27/2017	FT-FY18-102017-004151-A	<1	FT-FY18-102017-004151-B	<1
WS-004154	6/9/2017	6/9/2018	1	Cooler	In hallway adjacent to room 2114	Right	Low	WF-62017-004154	10/27/2017	FT-FY18-102017-004154-A	<1	FT-FY18-102017-004154-B	<1
WS-004157	6/9/2017	6/9/2018	1	Cooler	In classroom 2104 connecting hallway	Left	High	WF-62017-004157	10/27/2017	FT-FY18-102017-004157-A	<1	FT-FY18-102017-004157-B	<1
WS-004158	6/9/2017	6/9/2018	1	Cooler	In classroom 2104 connecting hallway	Right	Low	WF-62017-004158	10/27/2017	FT-FY18-102017-004158-A	<1	FT-FY18-102017-004158-B	<1
WS-004184	6/9/2017	6/9/2018	Ground Floor	Cooler	In classroom 2009 connecting hallway	Left	High	WF-62017-004184	10/27/2017	FT-FY18-102017-004184-A	<1	FT-FY18-102017-004184-B	<1
WS-004185	6/9/2017	6/9/2018	Ground Floor	Cooler	In classroom 2009 connecting hallway	Right	Low	WF-62017-004185	10/27/2017	FT-FY18-102017-004185-A	<1	FT-FY18-102017-004185-B	<1
WS-004186	10/17/2017	10/17/2018	Ground Floor	Classroom Faucet	In classroom 2009			WF-102017-004186	10/27/2017	FT-FY18-102017-004186-A	1.5	FT-FY18-102017-004186-B	<1
WS-004187	6/9/2017	6/9/2018	Ground Floor	Health Suite	In health suite 2007			WF-62017-004187	10/27/2017	FT-FY18-102017-004187-A	<1	FT-FY18-102017-004187-B	<1
WS-004189	6/9/2017	6/9/2018	Ground Floor	Cooler	In classroom 2004 connecting hallway	Left	High	WF-62017-004189	10/27/2017	FT-FY18-102017-004189-A	<1	FT-FY18-102017-004189-B	<1
WS-004190	6/9/2017	6/9/2018	Ground Floor	Cooler	In classroom 2004 connecting hallway	Right	Low	WF-62017-004190	10/27/2017	FT-FY18-102017-004190-A	<1	FT-FY18-102017-004190-B	<1
WS-004196	6/9/2017	6/9/2018	Ground Floor	Cooler	In hallway adjacent to room 2014	Left	High	WF-62017-004196	10/27/2017	FT-FY18-102017-004196-A	<1	FT-FY18-102017-004196-B	<1
WS-004199	6/9/2017	6/9/2018	Basement	Cooler	In hallway adjacent to room 2B14	Right	Low	WF-62017-004199	10/27/2017	FT-FY18-102017-004199-A	<1	FT-FY18-102017-004199-B	<1
WS-004204	10/17/2017	10/17/2018	Basement	Classroom Faucet	In classroom 2B09			WF-102017-004204	10/27/2017	FT-FY18-102017-004204-A	<1	FT-FY18-102017-004204-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004213	Ground Floor	Food Prep Sink	In kitchen room 2038	Left			10/27/2017	FT-FY18-102017-004213-A	<1	FT-FY18-102017-004213-B	<1
WS-004214	Ground Floor	Food Prep Sink	In kitchen 2038	Right			10/27/2017	FT-FY18-102017-004214-A	<1	FT-FY18-102017-004214-B	<1