



# Savoy ES Lead Water Test Results



## FY18 Filter Test

| Less than 5 ppb - Devices Requiring No Remediation |                       |                        |       |                |                                 |       |      |                    |               |                         |                                  |                         |                                  |
|--|-----------------------|------------------------|-------|----------------|---------------------------------|-------|------|--------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| RECORD ID  | Filter Installed Date | Filter Expiration Date | Floor | Device Type    | Device Location                 |       |      | WATER FILTERS Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
| WS- 008926   | 6/9/2017              | 6/9/2018               | 1     | Cooler         | In hallway adjacent to room 125 | Left  | High | WF-62017-008926    | 10/27/2017    | FT-FY18-102017-008926-A | <1                               | FT-FY18-102017-008926-B | <1                               |
| WS- 008930   | 10/17/2017            | 10/17/2018             | 1     | Combo Faucet   | In classroom 109                | Left  |      | WF-102017-008930   | 10/27/2017    | FT-FY18-102017-008930-A | <1                               | FT-FY18-102017-008930-B | <1                               |
| WS- 008931   | 6/9/2017              | 6/9/2018               | 1     | Combo Fountain | In classroom 109                | Right |      | WF-62017-008931    | 10/27/2017    | FT-FY18-102017-008931-A | <1                               | FT-FY18-102017-008931-B | <1                               |
| WS- 008932   | 10/17/2017            | 10/17/2018             | 1     | Combo Faucet   | In classroom 111                | Left  |      | WF-102017-008932   | 10/27/2017    | FT-FY18-102017-008932-A | <1                               | FT-FY18-102017-008932-B | <1                               |
| WS- 008933   | 6/9/2017              | 6/9/2018               | 1     | Combo Fountain | In classroom 111                | Right |      | WF-62017-008933    | 10/27/2017    | FT-FY18-102017-008933-A | <1                               | FT-FY18-102017-008933-B | <1                               |
| WS- 008936   | 10/17/2017            | 10/17/2018             | 1     | Combo Faucet   | In classroom 115                | Left  |      | WF-102017-008936   | 10/27/2017    | FT-FY18-102017-008936-A | <1                               | FT-FY18-102017-008936-B | <1                               |
| WS- 008937   | 6/9/2017              | 6/9/2018               | 1     | Combo Fountain | In classroom 115                | Right |      | WF-62017-008937    | 10/27/2017    | FT-FY18-102017-008937-A | <1                               | FT-FY18-102017-008937-B | <1                               |
| WS- 008958   | 6/9/2017              | 6/9/2018               | 2     | Cooler         | In hallway adjacent to room 208 | Right | Low  | WF-62017-008958    | 10/27/2017    | FT-FY18-102017-008958-A | <1                               | FT-FY18-102017-008958-B | <1                               |
| WS- 008964   | 6/9/2017              | 6/9/2018               | 2     | Cooler         | In media center room 215        | Right | Low  | WF-62017-008964    | 10/27/2017    | FT-FY18-102017-008964-A | <1                               | FT-FY18-102017-008964-B | <1                               |
| WS- 008966   | 6/9/2017              | 6/9/2018               | 3     | Cooler         | In hallway across from room 300 | Right | Low  | WF-62017-008966    | 10/27/2017    | FT-FY18-102017-008966-A | <1                               | FT-FY18-102017-008966-B | <1                               |
| WS- 008971   | 6/9/2017              | 6/9/2018               | 3     | Cooler         | In hallway adjacent to room 306 | Left  | High | WF-62017-008971    | 10/27/2017    | FT-FY18-102017-008971-A | <1                               | FT-FY18-102017-008971-B | <1                               |

## Food Prep Sink

| Less than 5 ppb - Devices Requiring No Remediation |       |                |   |      |  |  |               |                         |                                  |                         |                                  |
|--|-------|----------------|---|------|--|--|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| RECORD ID  | Floor | Device Type    | Device Location                             |      |  |  | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
| WS- 008920   | 1     | Food Prep Sink | In kitchen first clockwise from entry door  | Left |  |  | 10/27/2017    | FT-FY18-102017-008920-A | <1                               | FT-FY18-102017-008920-B | <1                               |
| WS- 008921   | 1     | Food Prep Sink | In kitchen second clockwise from entry door | Mid  |  |  | 10/27/2017    | FT-FY18-102017-008921-A | <1                               | FT-FY18-102017-008921-B | <1                               |