



TURNER ES LEAD WATER TEST RESULTS



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003848	10/11/2017	10/11/2018	1	Combo Faucet	In classroom 107	Mid	WF-102017-003848	10/24/2017	FT-FY18-102017-003848-A	< 1	FT-FY18-102017-003848-B	< 1
WS- 003849	5/24/2017	5/24/2018	1	Combo Fountain	In classroom 107	Right	WF-52017-003849	10/24/2017	FT-FY18-102017-003849-A	< 1	FT-FY18-102017-003849-B	< 1
WS- 003851	10/11/2017	10/11/2018	1	Combo Faucet	In classroom 108	Mid	WF-102017-003851	10/24/2017	FT-FY18-102017-003851-A	< 1	FT-FY18-102017-003851-B	< 1
WS- 003857	10/11/2017	10/11/2018	1	Combo Faucet	In classroom 109A	Left	WF-102017-003857	10/24/2017	FT-FY18-102017-003857-A	< 1	FT-FY18-102017-003857-B	< 1
WS- 003860	5/24/2017	5/24/2018	1	Combo Fountain	In classroom 113	Left	WF-52017-003860	10/24/2017	FT-FY18-102017-003860-A	< 1	FT-FY18-102017-003860-B	< 1
WS- 003863	10/11/2017	10/11/2018	1	Classroom Faucet	In classroom 112	Mid	WF-102017-003863	10/24/2017	FT-FY18-102017-003863-A	1.7	FT-FY18-102017-003863-B	< 1
WS- 003865	5/24/2017	5/24/2018	1	Combo Fountain	In classroom 112	Right	WF-52017-003865	10/24/2017	FT-FY18-102017-003865-A	< 1	FT-FY18-102017-003865-B	< 1
WS- 003867	5/24/2017	5/24/2018	1	Cooler	In hallway adjacent to elevator	Right Low	WF-52017-003867	10/24/2017	FT-FY18-102017-003867-A	< 1	FT-FY18-102017-003867-B	< 1
WS- 003871	10/11/2017	10/11/2018	1	Classroom Faucet	In classroom 117	Left	WF-102017-003871	10/24/2017	FT-FY18-102017-003871-A	1.6	FT-FY18-102017-003871-B	< 1
WS- 003872	10/11/2017	10/11/2018	1	Combo Faucet	In classroom 117	Mid	WF-102017-003872	10/24/2017	FT-FY18-102017-003872-A	< 1	FT-FY18-102017-003872-B	< 1
WS- 003876	5/24/2017	5/24/2018	1	Cooler	In hallway adjacent to stairwell A	Left High	WF-52017-003876	10/24/2017	FT-FY18-102017-003876-A	< 1	FT-FY18-102017-003876-B	< 1
WS- 003884	5/24/2017	5/24/2018	1	Cooler	In hallway adjacent to room 131	Right Low	WF-52017-003884	10/24/2017	FT-FY18-102017-003884-A	< 1	FT-FY18-102017-003884-B	< 1
WS- 003896	5/24/2017	5/24/2018	2	Break Room	In staff lounge 213		WF-52017-003896	10/24/2017	FT-FY18-102017-003896-A	< 1	FT-FY18-102017-003896-B	< 1
WS- 003898	5/24/2017	5/24/2018	2	Cooler	In hallway adjacent to media center	Right Low	WF-52017-003898	10/24/2017	FT-FY18-102017-003898-A	< 1	FT-FY18-102017-003898-B	< 1
WS- 003899	10/11/2017	10/11/2018	2	Classroom Faucet	In classroom 206		WF-102017-003899	10/24/2017	FT-FY18-102017-003899-A	< 1	FT-FY18-102017-003899-B	< 1
WS- 003900	5/24/2017	5/24/2018	2	Cooler	In hallway adjacent to room 202	Left High	WF-52017-003900	10/24/2017	FT-FY18-102017-003900-A	< 1	FT-FY18-102017-003900-B	< 1
WS- 003908	5/24/2017	5/24/2018	3	Cooler	In hallway adjacent to room 313	Left High	WF-52017-003908	10/24/2017	FT-FY18-102017-003908-A	< 1	FT-FY18-102017-003908-B	< 1
WS- 003909	10/11/2017	10/11/2018	1	Classroom Faucet	In classroom 107, in bathroom		WF-102017-003909	10/24/2017	FT-FY18-102017-003909-A	< 1	FT-FY18-102017-003909-B	< 1
WS- 003914	5/24/2017	5/24/2018	3	Cooler	In hallway adjacent to room 316	Left High	WF-52017-003914	10/24/2017	FT-FY18-102017-003914-A	< 1	FT-FY18-102017-003914-B	< 1
WS- 003927	5/24/2017	5/24/2018	Basement	Combo Faucet	In art room B06 first clockwise from entry door		WF-72017-003927	10/24/2017	FT-FY18-102017-003927-A	< 1	FT-FY18-102017-003927-B	< 1
WS- 004533	10/11/2017	10/11/2018	1	Classroom Faucet	In classroom 108, in bathroom		WF-102017-004533	10/24/2017	FT-FY18-102017-004533-A	< 1	FT-FY18-102017-004533-B	< 1
WS- 004534	10/11/2017	10/11/2018	1	Classroom Faucet	In classroom 109, in bathroom		WF-102017-004534	10/24/2017	FT-FY18-102017-004534-A	1.6	FT-FY18-102017-004534-B	< 1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation										
RECORD ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003878	1	Food Prep Sink	In servery room in kitchen on south wall			10/24/2017	FT-FY18-102017-003878-A	< 1	FT-FY18-102017-003878-B	< 1