



Coolidge HS / Wells MS Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015151	8/14/2019	8/14/2020	1	Break Room	In room D102 adjacent to D102E (daycare)	WF-08142019-015151	9/17/2019	FT-FY20-092019-015151-A	<1	FT-FY20-092019-015151-B	<1
WS-015155	8/14/2019	8/14/2020	1	Cooler	In hallway adjacent to 139K restroom High Left	WF-08142019-015155	9/17/2019	FT-FY20-092019-015155-A	<1	FT-FY20-092019-015155-B	<1
WS-015156	8/14/2019	8/14/2020	1	Cooler	In hallway adjacent to 139K restroom Low Right	WF-08142019-015156	9/17/2019	FT-FY20-092019-015156-A	<1	FT-FY20-092019-015156-B	<1
WS-015157	8/14/2019	8/14/2020	1	Cooler	In hallway adjacent to 138 dining (south side) High Left	WF-08142019-015157	9/17/2019	FT-FY20-092019-015157-A	<1	FT-FY20-092019-015157-B	<1
WS-015158	8/14/2019	8/14/2020	1	Cooler	In hallway adjacent to 138 dining (south side) Low Right	WF-08142019-015158	9/17/2019	FT-FY20-092019-015158-A	<1	FT-FY20-092019-015158-B	<1
WS-015160	8/14/2019	8/14/2020	1	Health Suite	In room 147A	WF-08142019-015160	9/17/2019	FT-FY20-092019-015160-A	<1	FT-FY20-092019-015160-B	<1
WS-015161	8/14/2019	8/14/2020	1	Health Suite	In room 149K	WF-08142019-015161	9/17/2019	FT-FY20-092019-015161-A	<1	FT-FY20-092019-015161-B	<1
WS-015162	8/14/2019	8/14/2020	1	Health Suite	In room 149L	WF-08142019-015162	9/17/2019	FT-FY20-092019-015162-A	<1	FT-FY20-092019-015162-B	<1
WS-015163	8/14/2019	8/14/2020	1	Health Suite	In room 149J	WF-08142019-015163	9/17/2019	FT-FY20-092019-015163-A	<1	FT-FY20-092019-015163-B	<1
WS-015164	8/14/2019	8/14/2020	1	Health Suite	In room 149G	WF-08142019-015164	9/17/2019	FT-FY20-092019-015164-A	<1	FT-FY20-092019-015164-B	<1
WS-015165	8/14/2019	8/14/2020	1	Health Suite	In room 149F	WF-08142019-015165	9/17/2019	FT-FY20-092019-015165-A	<1	FT-FY20-092019-015165-B	<1
WS-015166	8/14/2019	8/14/2020	1	Health Suite	In room 149A adjacent to dentist chair Left	WF-08142019-015166	9/17/2019	FT-FY20-092019-015166-A	1	FT-FY20-092019-015166-B	<1
WS-015167	8/14/2019	8/14/2020	1	Health Suite	In room 149A in lab Right	WF-08142019-015167	9/17/2019	FT-FY20-092019-015167-A	<1	FT-FY20-092019-015167-B	<1
WS-015168	8/14/2019	8/14/2020	1	Cooler	In hallway adjacent to 138 dining (west side) High Left	WF-08142019-015168	9/17/2019	FT-FY20-092019-015168-A	<1	FT-FY20-092019-015168-B	<1
WS-015169	8/14/2019	8/14/2020	1	Cooler	In hallway adjacent to 138 dining (west side) Low Right	WF-08142019-015169	9/17/2019	FT-FY20-092019-015169-A	<1	FT-FY20-092019-015169-B	<1
WS-015170	8/14/2019	8/14/2020	1	Bottle Filler	In room 138 dining	WF-08142019-015170	9/17/2019	FT-FY20-092019-015170-A	<1	FT-FY20-092019-015170-B	<1
WS-015171	8/14/2019	8/14/2020	1	Cooler	In room 138 dining High Left	WF-08142019-015171	9/17/2019	FT-FY20-092019-015171-A	<1	FT-FY20-092019-015171-B	<1
WS-015172	8/14/2019	8/14/2020	1	Cooler	In room 138 dining Low Right	WF-08142019-015172	9/17/2019	FT-FY20-092019-015172-A	<1	FT-FY20-092019-015172-B	<1
WS-015188	8/14/2019	8/14/2020	1	Break Room	In room 106	WF-08142019-015188	9/17/2019	FT-FY20-092019-015188-A	<1	FT-FY20-092019-015188-B	<1
WS-015189	8/14/2019	8/14/2020	1	Cooler	In hallway adjacent to 115 mechanical High Left	WF-08142019-015189	9/17/2019	FT-FY20-092019-015189-A	<1	FT-FY20-092019-015189-B	<1
WS-015190	8/14/2019	8/14/2020	1	Cooler	In hallway adjacent to 115 mechanical Low Right	WF-08142019-015190	9/17/2019	FT-FY20-092019-015190-A	<1	FT-FY20-092019-015190-B	<1
WS-015196	8/14/2019	8/14/2020	1	Classroom Faucet	In room 118 first clock wise from entry	WF-08142019-015196	9/17/2019	FT-FY20-092019-015196-A	<1	FT-FY20-092019-015196-B	<1
WS-015200	8/14/2019	8/14/2020	1	Cooler	In room 122	WF-08142019-015200	9/17/2019	FT-FY20-092019-015200-A	<1	FT-FY20-092019-015200-B	<1
WS-015217	8/14/2019	8/14/2020	2	Break Room	In room 221	WF-08142019-015217	9/17/2019	FT-FY20-092019-015217-A	<1	FT-FY20-092019-015217-B	<1
WS-015219	8/14/2019	8/14/2020	2	Break Room	In room 225	WF-08142019-015219	9/17/2019	FT-FY20-092019-015219-A	<1	FT-FY20-092019-015219-B	<1
WS-015226	8/14/2019	8/14/2020	2	Cooler	In hallway adjacent 241 High Left	WF-08142019-015226	9/17/2019	FT-FY20-092019-015226-A	<1	FT-FY20-092019-015226-B	<1
WS-015227	8/14/2019	8/14/2020	2	Cooler	In hallway adjacent 241 Low Right	WF-08142019-015227	9/17/2019	FT-FY20-092019-015227-A	<1	FT-FY20-092019-015227-B	<1
WS-015236	8/14/2019	8/14/2020	2	Break Room	In room 257	WF-08142019-015236	9/17/2019	FT-FY20-092019-015236-A	<1	FT-FY20-092019-015236-B	<1
WS-015238	8/14/2019	8/14/2020	2	Cooler	In hallway adjacent to 209 High Left	WF-08142019-015238	9/17/2019	FT-FY20-092019-015238-A	<1	FT-FY20-092019-015238-B	<1
WS-015239	8/14/2019	8/14/2020	2	Cooler	In hallway adjacent to 209 Low Right	WF-08142019-015239	9/17/2019	FT-FY20-092019-015239-A	<1	FT-FY20-092019-015239-B	<1
WS-015242	8/14/2019	8/14/2020	2	Break Room	In room 216	WF-08142019-015242	9/17/2019	FT-FY20-092019-015242-A	<1	FT-FY20-092019-015242-B	<1
WS-015265	8/14/2019	8/14/2020	3	Cooler	In room 341	WF-08142019-015265	9/17/2019	FT-FY20-092019-015265-A	<1	FT-FY20-092019-015265-B	<1
WS-015266	8/14/2019	8/14/2020	3	Cooler	In room 343	WF-08142019-015266	9/17/2019	FT-FY20-092019-015266-A	<1	FT-FY20-092019-015266-B	<1
WS-015267	8/14/2019	8/14/2020	3	Cooler	In hallway adjacent to 345 High Left	WF-08142019-015267	9/17/2019	FT-FY20-092019-015267-A	<1	FT-FY20-092019-015267-B	<1

WS-015268	8/14/2019	8/14/2020	3	Cooler	In hallway adjacent to 345	Low Right	WF-08142019-015268	9/17/2019	FT-FY20-092019-015268-A	<1	FT-FY20-092019-015268-B	<1
WS-015277	8/14/2019	8/14/2020	3	Break Room	In room 363		WF-08142019-015277	9/17/2019	FT-FY20-092019-015277-A	<1	FT-FY20-092019-015277-B	<1
WS-015282	8/14/2019	8/14/2020	3	Break Room	In room 312		WF-08142019-015282	9/17/2019	FT-FY20-092019-015282-A	<1	FT-FY20-092019-015282-B	<1
WS-015283	8/14/2019	8/14/2020	3	Cooler	In hallway across from 322	High Left	WF-08142019-015283	9/17/2019	FT-FY20-092019-015283-A	<1	FT-FY20-092019-015283-B	<1
WS-015284	8/14/2019	8/14/2020	3	Cooler	In hallway across from 322	Low Right	WF-08142019-015284	9/17/2019	FT-FY20-092019-015284-A	<1	FT-FY20-092019-015284-B	<1
WS-015288	8/14/2019	8/14/2020	4	Cooler	In hallway adjacent to 443	High Left	WF-08142019-015288	9/17/2019	FT-FY20-092019-015288-A	<1	FT-FY20-092019-015288-B	<1
WS-015289	8/14/2019	8/14/2020	4	Cooler	In hallway adjacent to 443	Low Right	WF-08142019-015289	9/17/2019	FT-FY20-092019-015289-A	<1	FT-FY20-092019-015289-B	<1
WS-015290	8/14/2019	8/14/2020	4	Break Room	In room 461		WF-08142019-015290	9/17/2019	FT-FY20-092019-015290-A	<1	FT-FY20-092019-015290-B	<1
WS-015293	8/14/2019	8/14/2020	4	Break Room	In room 406		WF-08142019-015293	9/17/2019	FT-FY20-092019-015293-A	<1	FT-FY20-092019-015293-B	<1
WS-015294	8/14/2019	8/14/2020	4	Cooler	In hallway across from 414	High Left	WF-08142019-015294	9/17/2019	FT-FY20-092019-015294-A	<1	FT-FY20-092019-015294-B	<1
WS-015295	8/14/2019	8/14/2020	4	Cooler	In hallway across from 414	Low Right	WF-08142019-015295	9/17/2019	FT-FY20-092019-015295-A	<1	FT-FY20-092019-015295-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015182	8/14/2019	8/14/2020	1	Food Prep Sink	In kitchen tenth clockwise from entry	WF-08142019-015182	9/17/2019	FT-FY20-092019-015182-A	<1	FT-FY20-092019-015182-B	<1	
WS-015223	8/14/2019	8/14/2020	2	Food Prep Sink	In room 237	WF-08142019-015223	9/17/2019	FT-FY20-092019-015223-A	<1	FT-FY20-092019-015223-B	<1	
WS-015278	8/14/2019	8/14/2020	3	Food Prep Sink	In room 301	WF-08142019-015278	9/17/2019	FT-FY20-092019-015278-A	1	FT-FY20-092019-015278-B	<1	