



# Houston ES Lead Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014300	8/5/2019	8/5/2020	1	Combo Faucet	In room 100 pre-school classroom	WF-08052019-014300	8/14/2019	FT-FY20-082019-014300-A	<1	FT-FY20-082019-014300-B	<1	
WS-014301	8/5/2019	8/5/2020	1	Combo Fountain	In room 100 pre-school classroom	WF-08052019-014301	8/14/2019	FT-FY20-082019-014301-A	<1	FT-FY20-082019-014301-B	<1	
WS-014304	8/5/2019	8/5/2020	1	Combo Faucet	In room 101 pre-school classroom	WF-08052019-014304	8/14/2019	FT-FY20-082019-014304-A	2.6	FT-FY20-082019-014304-B	<1	
WS-014305	8/5/2019	8/5/2020	1	Combo Fountain	In room 101 pre-school classroom	WF-08052019-014305	8/14/2019	FT-FY20-082019-014305-A	<1	FT-FY20-082019-014305-B	<1	
WS-014306	8/5/2019	8/5/2020	1	Combo Faucet	In room 102 pre-k classroom	WF-08052019-014306	8/14/2019	FT-FY20-082019-014306-A	<1	FT-FY20-082019-014306-B	<1	
WS-014307	8/5/2019	8/5/2020	1	Combo Fountain	In room 102 pre-k classroom	WF-08052019-014307	8/14/2019	FT-FY20-082019-014307-A	<1	FT-FY20-082019-014307-B	<1	
WS-014310	8/5/2019	8/5/2020	1	Combo Faucet	In room 103 pre-school classroom	WF-08052019-014310	8/14/2019	FT-FY20-082019-014310-A	<1	FT-FY20-082019-014310-B	<1	
WS-014311	8/5/2019	8/5/2020	1	Combo Fountain	In room 103 pre-school classroom	WF-08052019-014311	8/14/2019	FT-FY20-082019-014311-A	<1	FT-FY20-082019-014311-B	<1	
WS-014312	8/5/2019	8/5/2020	1	Break Room	In room 108 teacher collaboration	WF-08052019-014312	8/14/2019	FT-FY20-082019-014312-A	<1	FT-FY20-082019-014312-B	<1	
WS-014313	8/5/2019	8/5/2020	1	Combo Faucet	In room 109 pre-k classroom	WF-08052019-014313	8/14/2019	FT-FY20-082019-014313-A	<1	FT-FY20-082019-014313-B	<1	
WS-014314	8/5/2019	8/5/2020	1	Combo Fountain	In room 109 pre-k classroom	WF-08052019-014314	8/14/2019	FT-FY20-082019-014314-A	<1	FT-FY20-082019-014314-B	<1	
WS-014317	8/5/2019	8/5/2020	1	Combo Faucet	In room 110 kindergarten classroom	WF-08052019-014317	8/14/2019	FT-FY20-082019-014317-A	<1	FT-FY20-082019-014317-B	<1	
WS-014318	8/5/2019	8/5/2020	1	Combo Fountain	In room 110 kindergarten classroom	WF-08052019-014318	8/14/2019	FT-FY20-082019-014318-A	<1	FT-FY20-082019-014318-B	<1	
WS-014319	8/5/2019	8/5/2020	1	Combo Faucet	In room 111 kindergarten classroom	WF-08052019-014319	8/14/2019	FT-FY20-082019-014319-A	<1	FT-FY20-082019-014319-B	<1	
WS-014320	8/5/2019	8/5/2020	1	Combo Fountain	In room 111 kindergarten classroom	WF-08052019-014320	8/14/2019	FT-FY20-082019-014320-A	<1	FT-FY20-082019-014320-B	<1	
WS-014323	8/5/2019	8/5/2020	1	Combo Faucet	In room 112 kindergarten classroom	WF-08052019-014323	8/14/2019	FT-FY20-082019-014323-A	4.2	FT-FY20-082019-014323-B	<1	
WS-014324	8/5/2019	8/5/2020	1	Combo Fountain	In room 112 kindergarten classroom	WF-08052019-014324	8/14/2019	FT-FY20-082019-014324-A	<1	FT-FY20-082019-014324-B	<1	
WS-014326	8/5/2019	8/5/2020	1	Combo Fountain	In room 113 Makerspace	WF-08052019-014326	8/14/2019	FT-FY20-082019-014326-A	1.5	FT-FY20-082019-014326-B	<1	
WS-014327	8/5/2019	8/5/2020	1	Bottle Filler	In hallway adjacent to 113 makerspace	WF-08052019-014327	8/14/2019	FT-FY20-082019-014327-A	<1	FT-FY20-082019-014327-B	<1	
WS-014328	8/5/2019	8/5/2020	1	Cooler	In hallway adjacent to 113 makerspace	High Left	WF-08052019-014328	8/14/2019	FT-FY20-082019-014328-A	<1	FT-FY20-082019-014328-B	<1
WS-014329	8/5/2019	8/5/2020	1	Cooler	In hallway adjacent to 113 makerspace	Low Right	WF-08052019-014329	8/14/2019	FT-FY20-082019-014329-A	<1	FT-FY20-082019-014329-B	<1
WS-014332	8/5/2019	8/5/2020	1	Combo Fountain	In room 117 1st grade classroom	WF-08052019-014332	8/14/2019	FT-FY20-082019-014332-A	<1	FT-FY20-082019-014332-B	<1	
WS-014334	8/5/2019	8/5/2020	1	Combo Fountain	In room 118 speech classroom	WF-08052019-014334	8/14/2019	FT-FY20-082019-014334-A	<1	FT-FY20-082019-014334-B	<1	
WS-014336	8/5/2019	8/5/2020	1	Combo Fountain	In room 119 1st grade classroom	WF-08052019-014336	8/14/2019	FT-FY20-082019-014336-A	<1	FT-FY20-082019-014336-B	<1	
WS-014338	8/5/2019	8/5/2020	1	Combo Fountain	In room 120 special education	WF-08052019-014338	8/14/2019	FT-FY20-082019-014338-A	<1	FT-FY20-082019-014338-B	<1	
WS-014340	8/5/2019	8/5/2020	1	Combo Fountain	In room 121 resource room	WF-08052019-014340	8/14/2019	FT-FY20-082019-014340-A	<1	FT-FY20-082019-014340-B	<1	
WS-014342	8/5/2019	8/5/2020	1	Combo Fountain	In room 123 special education	WF-08052019-014342	8/14/2019	FT-FY20-082019-014342-A	<1	FT-FY20-082019-014342-B	<1	
WS-014344	8/5/2019	8/5/2020	1	Combo Fountain	In room 124 special education	WF-08052019-014344	8/14/2019	FT-FY20-082019-014344-A	<1	FT-FY20-082019-014344-B	<1	
WS-014346	8/5/2019	8/5/2020	1	Combo Fountain	In room 129 special education	WF-08052019-014346	8/14/2019	FT-FY20-082019-014346-A	<1	FT-FY20-082019-014346-B	<1	
WS-014349	8/5/2019	8/5/2020	1	Combo Fountain	In room 130 project science	WF-08052019-014349	8/14/2019	FT-FY20-082019-014349-A	<1	FT-FY20-082019-014349-B	<1	
WS-014350	8/5/2019	8/5/2020	1	Bottle Filler	In hallway adjacent to 130 project science	WF-08052019-014350	8/14/2019	FT-FY20-082019-014350-A	<1	FT-FY20-082019-014350-B	<1	
WS-014351	8/5/2019	8/5/2020	1	Cooler	In hallway adjacent to 130 project science	High Left	WF-08052019-014351	8/14/2019	FT-FY20-082019-014351-A	<1	FT-FY20-082019-014351-B	<1
WS-014352	8/5/2019	8/5/2020	1	Cooler	In hallway adjacent to 130 project science	Low Right	WF-08052019-014352	8/14/2019	FT-FY20-082019-014352-A	<1	FT-FY20-082019-014352-B	<1
WS-014354	8/5/2019	8/5/2020	1	Combo Fountain	In room 131 music room	WF-08052019-014354	8/14/2019	FT-FY20-082019-014354-A	<1	FT-FY20-082019-014354-B	<1	

WS-014355	8/5/2019	8/5/2020	2	Break Room	In room 201 staff lounge		WF-08052019-014355	8/14/2019	FT-FY20-082019-014355-A	1.9	FT-FY20-082019-014355-B	<1
WS-014356	8/5/2019	8/5/2020	2	Break Room	In room 203 teacher collaboration		WF-08052019-014356	8/14/2019	FT-FY20-082019-014356-A	2.7	FT-FY20-082019-014356-B	<1
WS-014358	8/5/2019	8/5/2020	2	Combo Fountain	In room 205 3rd grade classroom		WF-08052019-014358	8/14/2019	FT-FY20-082019-014358-A	<1	FT-FY20-082019-014358-B	<1
WS-014359	8/5/2019	8/5/2020	2	Bottle Filler	In hallway adjacent to 205 3rd grade classroom		WF-08052019-014359	8/14/2019	FT-FY20-082019-014359-A	<1	FT-FY20-082019-014359-B	<1
WS-014360	8/5/2019	8/5/2020	2	Cooler	In hallway adjacent to 205 3rd grade classroom	High Left	WF-08052019-014360	8/14/2019	FT-FY20-082019-014360-A	<1	FT-FY20-082019-014360-B	<1
WS-014361	8/5/2019	8/5/2020	2	Cooler	In hallway adjacent to 205 3rd grade classroom	Low Right	WF-08052019-014361	8/14/2019	FT-FY20-082019-014361-A	<1	FT-FY20-082019-014361-B	<1
WS-014363	8/5/2019	8/5/2020	2	Combo Fountain	In room 210 3rd grade classroom		WF-08052019-014363	8/14/2019	FT-FY20-082019-014363-A	<1	FT-FY20-082019-014363-B	<1
WS-014365	8/5/2019	8/5/2020	2	Combo Fountain	In room 211 4th grade classroom		WF-08052019-014365	8/14/2019	FT-FY20-082019-014365-A	<1	FT-FY20-082019-014365-B	<1
WS-014367	8/5/2019	8/5/2020	2	Combo Fountain	In room 217 4th grade classroom		WF-08052019-014367	8/14/2019	FT-FY20-082019-014367-A	<1	FT-FY20-082019-014367-B	<1
WS-014369	8/5/2019	8/5/2020	2	Combo Fountain	In room 218 5th grade classroom		WF-08052019-014369	8/14/2019	FT-FY20-082019-014369-A	<1	FT-FY20-082019-014369-B	<1
WS-014371	8/5/2019	8/5/2020	2	Combo Fountain	In room 223 5th grade classroom		WF-08052019-014371	8/14/2019	FT-FY20-082019-014371-A	<1	FT-FY20-082019-014371-B	<1
WS-014373	8/5/2019	8/5/2020	2	Combo Fountain	In room 224 library		WF-08052019-014373	8/14/2019	FT-FY20-082019-014373-A	<1	FT-FY20-082019-014373-B	<1
WS-014375	8/5/2019	8/5/2020	2	Bottle Filler	In hallway adjacent to C201 storage corridor		WF-08052019-014375	8/14/2019	FT-FY20-082019-014375-A	<1	FT-FY20-082019-014375-B	<1
WS-014376	8/5/2019	8/5/2020	2	Cooler	In hallway adjacent to C201 storage corridor	High Left	WF-08052019-014376	8/14/2019	FT-FY20-082019-014376-A	<1	FT-FY20-082019-014376-B	<1
WS-014377	8/5/2019	8/5/2020	2	Cooler	In hallway adjacent to C201 storage corridor	Low Right	WF-08052019-014377	8/14/2019	FT-FY20-082019-014377-A	<1	FT-FY20-082019-014377-B	<1
WS-014379	8/5/2019	8/5/2020	2	Combo Fountain	In room 226 special education		WF-08052019-014379	8/14/2019	FT-FY20-082019-014379-A	<1	FT-FY20-082019-014379-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013305	8/5/2019	8/5/2020	Ground Floor	Food Prep Sink	In portable kitchen 2nd clockwise from entry	WF-08052019-013305	8/14/2019	FT-FY20-082019-013305-A	<1	FT-FY20-082019-013305-B	<1