



Kimball ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014450	8/6/2019	8/6/2020	1	Break Room	In room 103 staff	WF-08062019-014450	8/16/2019	FT-FY20-082019-014450-A	<1	FT-FY20-082019-014450-B	<1
WS-014451	8/6/2019	8/6/2020	1	Combo Fountain	In room 103 staff	WF-08062019-014451	8/16/2019	FT-FY20-082019-014451-A	<1	FT-FY20-082019-014451-B	<1
WS-014453	8/6/2019	8/6/2020	1	Combo Fountain	In room 106 parent resource center	WF-08062019-014453	8/16/2019	FT-FY20-082019-014453-A	<1	FT-FY20-082019-014453-B	<1
WS-014454	8/6/2019	8/6/2020	1	Break Room	In room 119 staff	WF-08062019-014454	8/16/2019	FT-FY20-082019-014454-A	1.1	FT-FY20-082019-014454-B	<1
WS-014455	8/6/2019	8/6/2020	1	Combo Fountain	In room 119 staff	WF-08062019-014455	8/16/2019	FT-FY20-082019-014455-A	1.1	FT-FY20-082019-014455-B	<1
WS-014456	8/6/2019	8/6/2020	1	Health Suite	In room 113 nursing	WF-08062019-014456	8/16/2019	FT-FY20-082019-014456-A	<1	FT-FY20-082019-014456-B	<1
WS-014458	8/6/2019	8/6/2020	1	Combo Fountain	In room 117 classroom	WF-08062019-014458	8/16/2019	FT-FY20-082019-014458-A	<1	FT-FY20-082019-014458-B	<1
WS-014460	8/6/2019	8/6/2020	1	Combo Fountain	In room 116 classroom	WF-08062019-014460	8/16/2019	FT-FY20-082019-014460-A	<1	FT-FY20-082019-014460-B	<1
WS-014462	8/6/2019	8/6/2020	1	Combo Fountain	In room 139 commons Left	WF-08062019-014462	8/16/2019	FT-FY20-082019-014462-A	<1	FT-FY20-082019-014462-B	<1
WS-014464	8/6/2019	8/6/2020	1	Combo Fountain	In room 139 commons Right	WF-08062019-014464	8/16/2019	FT-FY20-082019-014464-A	<1	FT-FY20-082019-014464-B	<1
WS-014465	8/6/2019	8/6/2020	1	Combo Faucet	In room 121 classroom	WF-08062019-014465	8/16/2019	FT-FY20-082019-014465-A	<1	FT-FY20-082019-014465-B	<1
WS-014466	8/6/2019	8/6/2020	1	Combo Fountain	In room 121 classroom	WF-08062019-014466	8/16/2019	FT-FY20-082019-014466-A	<1	FT-FY20-082019-014466-B	<1
WS-014467	8/6/2019	8/6/2020	1	Combo Faucet	In room 122 classroom	WF-08062019-014467	8/16/2019	FT-FY20-082019-014467-A	<1	FT-FY20-082019-014467-B	<1
WS-014468	8/6/2019	8/6/2020	1	Combo Fountain	In room 122 classroom	WF-08062019-014468	8/16/2019	FT-FY20-082019-014468-A	<1	FT-FY20-082019-014468-B	<1
WS-014469	8/6/2019	8/6/2020	1	Combo Faucet	In room 123 classroom	WF-08062019-014469	8/16/2019	FT-FY20-082019-014469-A	<1	FT-FY20-082019-014469-B	<1
WS-014470	8/6/2019	8/6/2020	1	Combo Fountain	In room 123 classroom	WF-08062019-014470	8/16/2019	FT-FY20-082019-014470-A	<1	FT-FY20-082019-014470-B	<1
WS-014471	8/6/2019	8/6/2020	1	Bottle Filler	In hallway outside of restrooms	WF-08062019-014471	8/16/2019	FT-FY20-082019-014471-A	<1	FT-FY20-082019-014471-B	<1
WS-014472	8/6/2019	8/6/2020	1	Cooler	In hallway outside of restrooms High Left	WF-08062019-014472	8/16/2019	FT-FY20-082019-014472-A	<1	FT-FY20-082019-014472-B	<1
WS-014473	8/6/2019	8/6/2020	1	Cooler	In hallway outside of restrooms Low Right	WF-08062019-014473	8/16/2019	FT-FY20-082019-014473-A	<1	FT-FY20-082019-014473-B	<1
WS-014481	8/6/2019	8/6/2020	1	Bottle Filler	In room 128 student dining	WF-08062019-014481	8/16/2019	FT-FY20-082019-014481-A	<1	FT-FY20-082019-014481-B	<1
WS-014482	8/6/2019	8/6/2020	1	Cooler	In room 128 student dining High Left	WF-08062019-014482	8/16/2019	FT-FY20-082019-014482-A	<1	FT-FY20-082019-014482-B	<1
WS-014483	8/6/2019	8/6/2020	1	Cooler	In room 128 student dining Low Right	WF-08062019-014483	8/16/2019	FT-FY20-082019-014483-A	<1	FT-FY20-082019-014483-B	<1
WS-014484	8/6/2019	8/6/2020	1	Bottle Filler	In room 130 platform	WF-08062019-014484	8/16/2019	FT-FY20-082019-014484-A	<1	FT-FY20-082019-014484-B	<1
WS-014485	8/6/2019	8/6/2020	1	Cooler	In room 130 platform High Left	WF-08062019-014485	8/16/2019	FT-FY20-082019-014485-A	<1	FT-FY20-082019-014485-B	<1
WS-014486	8/6/2019	8/6/2020	1	Cooler	In room 130 platform Low Right	WF-08062019-014486	8/16/2019	FT-FY20-082019-014486-A	<1	FT-FY20-082019-014486-B	<1
WS-014487	8/6/2019	8/6/2020	1	Combo Faucet	In room 132 classroom	WF-08062019-014487	8/16/2019	FT-FY20-082019-014487-A	<1	FT-FY20-082019-014487-B	<1
WS-014488	8/6/2019	8/6/2020	1	Combo Fountain	In room 132 classroom	WF-08062019-014488	8/16/2019	FT-FY20-082019-014488-A	<1	FT-FY20-082019-014488-B	<1
WS-014489	8/6/2019	8/6/2020	1	Combo Faucet	In room 133 classroom	WF-08062019-014489	8/16/2019	FT-FY20-082019-014489-A	<1	FT-FY20-082019-014489-B	<1
WS-014490	8/6/2019	8/6/2020	1	Combo Fountain	In room 133 classroom	WF-08062019-014490	8/16/2019	FT-FY20-082019-014490-A	<1	FT-FY20-082019-014490-B	<1
WS-014491	8/6/2019	8/6/2020	1	Combo Faucet	In room 134 classroom	WF-08062019-014491	8/16/2019	FT-FY20-082019-014491-A	<1	FT-FY20-082019-014491-B	<1
WS-014492	8/6/2019	8/6/2020	1	Combo Fountain	In room 134 classroom	WF-08062019-014492	8/16/2019	FT-FY20-082019-014492-A	<1	FT-FY20-082019-014492-B	<1
WS-014493	8/6/2019	8/6/2020	1	Combo Faucet	In room 135 classroom	WF-08062019-014493	8/16/2019	FT-FY20-082019-014493-A	<1	FT-FY20-082019-014493-B	<1
WS-014494	8/6/2019	8/6/2020	1	Combo Fountain	In room 135 classroom	WF-08062019-014494	8/16/2019	FT-FY20-082019-014494-A	<1	FT-FY20-082019-014494-B	<1
WS-014496	8/6/2019	8/6/2020	2	Combo Fountain	In room 210 classroom first clockwise from entry	WF-08062019-014496	8/16/2019	FT-FY20-082019-014496-A	<1	FT-FY20-082019-014496-B	<1
WS-014498	8/6/2019	8/6/2020	2	Combo Fountain	In room 210 classroom second clockwise from entry	WF-08062019-014498	8/16/2019	FT-FY20-082019-014498-A	<1	FT-FY20-082019-014498-B	<1

WS-014500	8/6/2019	8/6/2020	2	Combo Fountain	In room 210 classroom third clockwise from entry	WF-08062019-014500	8/16/2019	FT-FY20-082019-014500-A	<1	FT-FY20-082019-014500-B	<1	
WS-014502	8/6/2019	8/6/2020	2	Combo Fountain	In room 210 classroom fourth clockwise from entry	WF-08062019-014502	8/16/2019	FT-FY20-082019-014502-A	<1	FT-FY20-082019-014502-B	<1	
WS-014503	8/6/2019	8/6/2020	2	Break Room	In room 211 staff	WF-08062019-014503	8/16/2019	FT-FY20-082019-014503-A	<1	FT-FY20-082019-014503-B	<1	
WS-014504	8/6/2019	8/6/2020	2	Combo Fountain	In room 211 staff	WF-08062019-014504	8/16/2019	FT-FY20-082019-014504-A	<1	FT-FY20-082019-014504-B	<1	
WS-014509	8/6/2019	8/6/2020	2	Combo Fountain	In room music classroom	WF-08062019-014509	8/16/2019	FT-FY20-082019-014509-A	<1	FT-FY20-082019-014509-B	<1	
WS-014511	8/6/2019	8/6/2020	2	Combo Fountain	In room 237 commons	WF-08062019-014511	8/16/2019	FT-FY20-082019-014511-A	<1	FT-FY20-082019-014511-B	<1	
WS-014513	8/6/2019	8/6/2020	2	Combo Fountain	In room 216 food prints lab first clockwise from entry	WF-08062019-014513	8/16/2019	FT-FY20-082019-014513-A	<1	FT-FY20-082019-014513-B	<1	
WS-014514	8/6/2019	8/6/2020	2	Food Prep Sink	In room 216 food prints lab second clockwise from entry	Left	WF-08062019-014514	8/16/2019	FT-FY20-082019-014514-A	<1	FT-FY20-082019-014514-B	<1
WS-014515	8/6/2019	8/6/2020	2	Food Prep Sink	In room 216 food prints lab third clockwise from entry	Mid	WF-08062019-014515	8/16/2019	FT-FY20-082019-014515-A	<1	FT-FY20-082019-014515-B	<1
WS-014516	8/6/2019	8/6/2020	2	Food Prep Sink	In room 216 food prints lab fourth clockwise from entry	Right	WF-08062019-014516	8/16/2019	FT-FY20-082019-014516-A	<1	FT-FY20-082019-014516-B	<1
WS-014518	8/6/2019	8/6/2020	2	Combo Fountain	In room 216 food prints lab fifth clockwise from entry	WF-08062019-014518	8/16/2019	FT-FY20-082019-014518-A	<1	FT-FY20-082019-014518-B	<1	
WS-014520	8/6/2019	8/6/2020	2	Combo Fountain	In room 217 classroom	WF-08062019-014520	8/16/2019	FT-FY20-082019-014520-A	<1	FT-FY20-082019-014520-B	<1	
WS-014522	8/6/2019	8/6/2020	2	Combo Fountain	In room 218 classroom	WF-08062019-014522	8/16/2019	FT-FY20-082019-014522-A	<1	FT-FY20-082019-014522-B	<1	
WS-014524	8/6/2019	8/6/2020	2	Combo Fountain	In room 219 classroom	WF-08062019-014524	8/16/2019	FT-FY20-082019-014524-A	<1	FT-FY20-082019-014524-B	<1	
WS-014525	8/6/2019	8/6/2020	2	Break Room	In room 222 classroom	WF-08062019-014525	8/16/2019	FT-FY20-082019-014525-A	<1	FT-FY20-082019-014525-B	<1	
WS-014526	8/6/2019	8/6/2020	2	Combo Fountain	In room 222 classroom	WF-08062019-014526	8/16/2019	FT-FY20-082019-014526-A	<1	FT-FY20-082019-014526-B	<1	
WS-014528	8/6/2019	8/6/2020	2	Combo Fountain	In library in room 223D small group instruction	WF-08062019-014528	8/16/2019	FT-FY20-082019-014528-A	<1	FT-FY20-082019-014528-B	<1	
WS-014530	8/6/2019	8/6/2020	2	Combo Fountain	In room 227 classroom	WF-08062019-014530	8/16/2019	FT-FY20-082019-014530-A	<1	FT-FY20-082019-014530-B	<1	
WS-014532	8/6/2019	8/6/2020	2	Combo Fountain	In room 228 classroom	WF-08062019-014532	8/16/2019	FT-FY20-082019-014532-A	<1	FT-FY20-082019-014532-B	<1	
WS-014534	8/6/2019	8/6/2020	2	Combo Fountain	In room 230 classroom	WF-08062019-014534	8/16/2019	FT-FY20-082019-014534-A	<1	FT-FY20-082019-014534-B	<1	
WS-014536	8/6/2019	8/6/2020	2	Combo Fountain	In room 231 classroom	WF-08062019-014536	8/16/2019	FT-FY20-082019-014536-A	<1	FT-FY20-082019-014536-B	<1	
WS-014538	8/6/2019	8/6/2020	2	Combo Fountain	In room 233 classroom	WF-08062019-014538	8/16/2019	FT-FY20-082019-014538-A	<1	FT-FY20-082019-014538-B	<1	
WS-014540	8/6/2019	8/6/2020	3	Combo Fountain	In room 300 commons	WF-08062019-014540	8/16/2019	FT-FY20-082019-014540-A	<1	FT-FY20-082019-014540-B	<1	
WS-014541	8/6/2019	8/6/2020	3	Break Room	In room 301 staff	WF-08062019-014541	8/16/2019	FT-FY20-082019-014541-A	<1	FT-FY20-082019-014541-B	<1	
WS-014542	8/6/2019	8/6/2020	3	Combo Fountain	In room 301 staff	WF-08062019-014542	8/16/2019	FT-FY20-082019-014542-A	<1	FT-FY20-082019-014542-B	<1	
WS-014544	8/6/2019	8/6/2020	3	Combo Fountain	In room 305 classroom	WF-08062019-014544	8/16/2019	FT-FY20-082019-014544-A	<1	FT-FY20-082019-014544-B	<1	
WS-014546	8/6/2019	8/6/2020	3	Combo Fountain	In room 306 classroom	WF-08062019-014546	8/16/2019	FT-FY20-082019-014546-A	<1	FT-FY20-082019-014546-B	<1	
WS-014548	8/6/2019	8/6/2020	3	Combo Fountain	In room 307 classroom	WF-08062019-014548	8/16/2019	FT-FY20-082019-014548-A	<1	FT-FY20-082019-014548-B	<1	
WS-014550	8/6/2019	8/6/2020	3	Combo Fountain	In room 308 classroom	WF-08062019-014550	8/16/2019	FT-FY20-082019-014550-A	<1	FT-FY20-082019-014550-B	<1	
WS-014552	8/6/2019	8/6/2020	3	Combo Fountain	In room 309 classroom	WF-08062019-014552	8/16/2019	FT-FY20-082019-014552-A	<1	FT-FY20-082019-014552-B	<1	
WS-014553	8/6/2019	8/6/2020	3	Bottle Filler	In hallway across from 310 electrical	WF-08062019-014553	8/16/2019	FT-FY20-082019-014553-A	<1	FT-FY20-082019-014553-B	<1	
WS-014554	8/6/2019	8/6/2020	3	Cooler	In hallway across from 310 electrical	High Left	WF-08062019-014554	8/16/2019	FT-FY20-082019-014554-A	<1	FT-FY20-082019-014554-B	<1
WS-014555	8/6/2019	8/6/2020	3	Cooler	In hallway across from 310 electrical	Low Right	WF-08062019-014555	8/16/2019	FT-FY20-082019-014555-A	<1	FT-FY20-082019-014555-B	<1
WS-014557	8/6/2019	8/6/2020	3	Combo Fountain	In room 311 classroom	WF-08062019-014557	8/16/2019	FT-FY20-082019-014557-A	<1	FT-FY20-082019-014557-B	<1	
WS-014559	8/6/2019	8/6/2020	3	Combo Fountain	In room 312 classroom	WF-08062019-014559	8/16/2019	FT-FY20-082019-014559-A	<1	FT-FY20-082019-014559-B	<1	
WS-014561	8/6/2019	8/6/2020	3	Combo Fountain	In room 313 classroom	WF-08062019-014561	8/16/2019	FT-FY20-082019-014561-A	<1	FT-FY20-082019-014561-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014476	8/6/2019	8/6/2020	1	Food Prep Sink	In kitchen third clockwise from entry	WF-08062019-014476	8/16/2019	FT-FY20-082019-014476-A	<1	FT-FY20-082019-014476-B	<1