



CW Harris ES (Post Modernization) Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014223	8/3/2020	8/3/2021	1	Break Room	In room 137 parent resource center	WF-08032020-014223	8/19/2020	FT-FY20-082020-014223-A	<1	FT-FY20-082020-014223-B	<1
WS-014224	8/3/2020	8/3/2021	1	Combo Fountain	In room 137 parent resource center	WF-08032020-014224	8/19/2020	FT-FY20-082020-014224-A	<1	FT-FY20-082020-014224-B	<1
WS-014225	8/3/2020	8/3/2021	1	Break Room	In room 108 admin workroom	WF-08032020-014225	8/19/2020	FT-FY20-082020-014225-A	<1	FT-FY20-082020-014225-B	<1
WS-014226	8/3/2020	8/3/2021	1	Health Suite	In health suite in room 115 treatment	WF-08032020-014226	8/19/2020	FT-FY20-082020-014226-A	<1	FT-FY20-082020-014226-B	<1
WS-014238	8/3/2020	8/3/2021	1	Bottle Filler	In gym adjacent to stage ramp	WF-08032020-014238	8/19/2020	FT-FY20-082020-014238-A	<1	FT-FY20-082020-014238-B	<1
WS-014239	8/3/2020	8/3/2021	1	Cooler	In gym adjacent to stage ramp Low Left	WF-08032020-014239	8/19/2020	FT-FY20-082020-014239-A	<1	FT-FY20-082020-014239-B	<1
WS-014240	8/3/2020	8/3/2021	1	Cooler	In gym adjacent to stage ramp High Right	WF-08032020-014240	8/19/2020	FT-FY20-082020-014240-A	<1	FT-FY20-082020-014240-B	<1
WS-014241	8/3/2020	8/3/2021	2	Break Room	In room 237 wellness	WF-08032020-014241	8/19/2020	FT-FY20-082020-014241-A	<1	FT-FY20-082020-014241-B	<1
WS-014242	8/3/2020	8/3/2021	2	Break Room	In room 238 staff lounge	WF-08032020-014242	8/19/2020	FT-FY20-082020-014242-A	<1	FT-FY20-082020-014242-B	<1
WS-014243	8/3/2020	8/3/2021	2	Combo Fountain	In room 238 staff lounge	WF-08032020-014243	8/19/2020	FT-FY20-082020-014243-A	<1	FT-FY20-082020-014243-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014233	8/3/2020	8/3/2021	1	Food Prep Sink	In kitchen seventh clockwise from entry	WF-08032020-014233	8/19/2020	FT-FY20-082020-014233-A	<1	FT-FY20-082020-014233-B	<1