



Eliot Hine MS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015505	11/2/2020	11/2/2021	Ground Floor	Break Room	In room G23	WF-11022020-015505	11/10/2020	FT-FY21-112020-015505-A	<1	FT-FY21-112020-015505-B	<1
WS-015506	11/2/2020	11/2/2021	Ground Floor	Bottle Filler	In cafeteria	WF-11022020-015506	11/10/2020	FT-FY21-112020-015506-A	<1	FT-FY21-112020-015506-B	<1
WS-015507	11/2/2020	11/2/2021	Ground Floor	Cooler	In cafeteria	High Left	WF-11022020-015507	11/10/2020	FT-FY21-112020-015507-A	<1	FT-FY21-112020-015507-B
WS-015508	11/2/2020	11/2/2021	Ground Floor	Cooler	In cafeteria	Low Right	WF-11022020-015508	11/10/2020	FT-FY21-112020-015508-A	<1	FT-FY21-112020-015508-B
WS-015511	11/2/2020	11/2/2021	Ground Floor	Bottle Filler	In hallway adjacent to room G66	Left	WF-11022020-015511	11/10/2020	FT-FY21-112020-015511-A	<1	FT-FY21-112020-015511-B
WS-015512	11/2/2020	11/2/2021	Ground Floor	Cooler	In hallway adjacent to room G66	Left	WF-11022020-015512	11/10/2020	FT-FY21-112020-015512-A	<1	FT-FY21-112020-015512-B
WS-015513	11/2/2020	11/2/2021	Ground Floor	Bottle Filler	In hallway adjacent to room G66	Mid	WF-11022020-015513	11/10/2020	FT-FY21-112020-015513-A	<1	FT-FY21-112020-015513-B
WS-015514	11/2/2020	11/2/2021	Ground Floor	Cooler	In hallway adjacent to room G66	Mid	WF-11022020-015514	11/10/2020	FT-FY21-112020-015514-A	<1	FT-FY21-112020-015514-B
WS-015515	11/2/2020	11/2/2021	Ground Floor	Bottle Filler	In hallway adjacent to room G66	Right	WF-11022020-015515	11/10/2020	FT-FY21-112020-015515-A	<1	FT-FY21-112020-015515-B
WS-015516	11/2/2020	11/2/2021	Ground Floor	Cooler	In hallway adjacent to room G66	Right	WF-11022020-015516	11/10/2020	FT-FY21-112020-015516-A	<1	FT-FY21-112020-015516-B
WS-015528	11/2/2020	11/2/2021	1	Health Suite	Inside heath suite 130 in room 132		WF-11022020-015528	11/10/2020	FT-FY21-112020-015528-A	<1	FT-FY21-112020-015528-B
WS-015529	11/2/2020	11/2/2021	1	Bottle Filler	In hallway adjacent to room 130		WF-11022020-015529	11/10/2020	FT-FY21-112020-015529-A	<1	FT-FY21-112020-015529-B
WS-015530	11/2/2020	11/2/2021	1	Cooler	In hallway adjacent to room 130	High Left	WF-11022020-015530	11/10/2020	FT-FY21-112020-015530-A	<1	FT-FY21-112020-015530-B
WS-015531	11/2/2020	11/2/2021	1	Cooler	In hallway adjacent to room 130	Low Right	WF-11022020-015531	11/10/2020	FT-FY21-112020-015531-A	<1	FT-FY21-112020-015531-B
WS-015532	11/2/2020	11/2/2021	1	Break Room	In room 120		WF-11022020-015532	11/10/2020	FT-FY21-112020-015532-A	<1	FT-FY21-112020-015532-B
WS-015533	11/2/2020	11/2/2021	1	Bottle Filler	In hallway adjacent to room 120		WF-11022020-015533	11/10/2020	FT-FY21-112020-015533-A	<1	FT-FY21-112020-015533-B
WS-015534	11/2/2020	11/2/2021	1	Cooler	In hallway adjacent to room 120	High Left	WF-11022020-015534	11/10/2020	FT-FY21-112020-015534-A	<1	FT-FY21-112020-015534-B
WS-015535	11/2/2020	11/2/2021	1	Cooler	In hallway adjacent to room 120	Low Right	WF-11022020-015535	11/10/2020	FT-FY21-112020-015535-A	<1	FT-FY21-112020-015535-B
WS-015538	11/2/2020	11/2/2021	1	Bottle Filler	In hallway adjacent to stairwell outside of gym		WF-11022020-015538	11/10/2020	FT-FY21-112020-015538-A	<1	FT-FY21-112020-015538-B
WS-015539	11/2/2020	11/2/2021	1	Cooler	In hallway adjacent to stairwell outside of gym	High Left	WF-11022020-015539	11/10/2020	FT-FY21-112020-015539-A	<1	FT-FY21-112020-015539-B
WS-015540	11/2/2020	11/2/2021	1	Cooler	In hallway adjacent to stairwell outside of gym	Low Right	WF-11022020-015540	11/10/2020	FT-FY21-112020-015540-A	<1	FT-FY21-112020-015540-B
WS-015541	11/2/2020	11/2/2021	1	Bottle Filler	In gym		WF-11022020-015541	11/10/2020	FT-FY21-112020-015541-A	<1	FT-FY21-112020-015541-B
WS-015542	11/2/2020	11/2/2021	1	Cooler	In gym	High Left	WF-11022020-015542	11/10/2020	FT-FY21-112020-015542-A	<1	FT-FY21-112020-015542-B
WS-015543	11/2/2020	11/2/2021	1	Cooler	In gym	Low Right	WF-11022020-015543	11/10/2020	FT-FY21-112020-015543-A	<1	FT-FY21-112020-015543-B
WS-015547	11/2/2020	11/2/2021	1	Combo Fountain	In room 134		WF-11022020-015547	11/10/2020	FT-FY21-112020-015547-A	<1	FT-FY21-112020-015547-B
WS-015548	11/2/2020	11/2/2021	1	Bottle Filler	In hallway adjacent to room 134		WF-11022020-015548	11/10/2020	FT-FY21-112020-015548-A	<1	FT-FY21-112020-015548-B
WS-015549	11/2/2020	11/2/2021	1	Cooler	In hallway adjacent to room 134	High Left	WF-11022020-015549	11/10/2020	FT-FY21-112020-015549-A	<1	FT-FY21-112020-015549-B
WS-015550	11/2/2020	11/2/2021	1	Cooler	In hallway adjacent to room 134	Low Right	WF-11022020-015550	11/10/2020	FT-FY21-112020-015550-A	<1	FT-FY21-112020-015550-B
WS-015551	11/2/2020	11/2/2021	2	Bottle Filler	In hallway across from 245		WF-11022020-015551	11/10/2020	FT-FY21-112020-015551-A	<1	FT-FY21-112020-015551-B
WS-015552	11/2/2020	11/2/2021	2	Cooler	In hallway across from 245	High Left	WF-11022020-015552	11/10/2020	FT-FY21-112020-015552-A	<1	FT-FY21-112020-015552-B
WS-015553	11/2/2020	11/2/2021	2	Cooler	In hallway across from 245	Low Right	WF-11022020-015553	11/10/2020	FT-FY21-112020-015553-A	<1	FT-FY21-112020-015553-B
WS-015554	11/2/2020	11/2/2021	2	Break Room	In room 242		WF-11022020-015554	11/10/2020	FT-FY21-112020-015554-A	<1	FT-FY21-112020-015554-B
WS-015557	11/2/2020	11/2/2021	2	Break Room	Inside room 211 in room 211A		WF-11022020-015557	11/10/2020	FT-FY21-112020-015557-A	<1	FT-FY21-112020-015557-B

WS-015560	11/2/2020	11/2/2021	2	Health Suite	In room 212		WF-11022020-015560	11/10/2020	FT-FY21-112020-015560-A	<1	FT-FY21-112020-015560-B	<1
WS-015561	11/2/2020	11/2/2021	2	Bottle Filler	In hallway adjacent to room 216		WF-11022020-015561	11/10/2020	FT-FY21-112020-015561-A	<1	FT-FY21-112020-015561-B	<1
WS-015562	11/2/2020	11/2/2021	2	Cooler	In hallway adjacent to room 216	High Left	WF-11022020-015562	11/10/2020	FT-FY21-112020-015562-A	<1	FT-FY21-112020-015562-B	<1
WS-015563	11/2/2020	11/2/2021	2	Cooler	In hallway adjacent to room 216	Low Right	WF-11022020-015563	11/10/2020	FT-FY21-112020-015563-A	<1	FT-FY21-112020-015563-B	<1
WS-015564	11/2/2020	11/2/2021	2	Cooler	In hallway adjacent to room 263	Low Left	WF-11022020-015564	11/10/2020	FT-FY21-112020-015564-A	<1	FT-FY21-112020-015564-B	<1
WS-015565	11/2/2020	11/2/2021	2	Cooler	In hallway adjacent to room 263	High Right	WF-11022020-015565	11/10/2020	FT-FY21-112020-015565-A	<1	FT-FY21-112020-015565-B	<1
WS-015567	11/2/2020	11/2/2021	2	Combo Fountain	In room 236		WF-11022020-015567	11/10/2020	FT-FY21-112020-015567-A	<1	FT-FY21-112020-015567-B	<1
WS-015568	11/2/2020	11/2/2021	2	Food Prep Sink	In room 234 between 236 and 232		WF-11022020-015568	11/10/2020	FT-FY21-112020-015568-A	<1	FT-FY21-112020-015568-B	<1
WS-015570	11/2/2020	11/2/2021	2	Combo Fountain	In room 232		WF-11022020-015570	11/10/2020	FT-FY21-112020-015570-A	<1	FT-FY21-112020-015570-B	<1
WS-015571	11/2/2020	11/2/2021	2	Bottle Filler	In hallway adjacent to room 232		WF-11022020-015571	11/10/2020	FT-FY21-112020-015571-A	<1	FT-FY21-112020-015571-B	<1
WS-015572	11/2/2020	11/2/2021	2	Cooler	In hallway adjacent to room 232	High Left	WF-11022020-015572	11/10/2020	FT-FY21-112020-015572-A	<1	FT-FY21-112020-015572-B	<1
WS-015573	11/2/2020	11/2/2021	2	Cooler	In hallway adjacent to room 232	Low Right	WF-11022020-015573	11/10/2020	FT-FY21-112020-015573-A	<1	FT-FY21-112020-015573-B	<1
WS-015591	11/2/2020	11/2/2021	3	Break Room	In room 328		WF-11022020-015591	11/10/2020	FT-FY21-112020-015591-A	<1	FT-FY21-112020-015591-B	<1
WS-015592	11/2/2020	11/2/2021	3	Bottle Filler	In hallway adjacent to room 318		WF-11022020-015592	11/10/2020	FT-FY21-112020-015592-A	<1	FT-FY21-112020-015592-B	<1
WS-015593	11/2/2020	11/2/2021	3	Cooler	In hallway adjacent to room 318	High Left	WF-11022020-015593	11/10/2020	FT-FY21-112020-015593-A	<1	FT-FY21-112020-015593-B	<1
WS-015594	11/2/2020	11/2/2021	3	Cooler	In hallway adjacent to room 318	Low Right	WF-11022020-015594	11/10/2020	FT-FY21-112020-015594-A	<1	FT-FY21-112020-015594-B	<1
WS-015595	11/2/2020	11/2/2021	3	Bottle Filler	In hallway adjacent to room 334		WF-11022020-015595	11/10/2020	FT-FY21-112020-015595-A	<1	FT-FY21-112020-015595-B	<1
WS-015596	11/2/2020	11/2/2021	3	Cooler	In hallway adjacent to room 334	High Left	WF-11022020-015596	11/10/2020	FT-FY21-112020-015596-A	<1	FT-FY21-112020-015596-B	<1
WS-015597	11/2/2020	11/2/2021	3	Cooler	In hallway adjacent to room 334	Low Right	WF-11022020-015597	11/10/2020	FT-FY21-112020-015597-A	<1	FT-FY21-112020-015597-B	<1
WS-015598	11/2/2020	11/2/2021	3	Break Room	In room 330		WF-11022020-015598	11/10/2020	FT-FY21-112020-015598-A	<1	FT-FY21-112020-015598-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015524	11/2/2020	11/2/2021	Ground Floor	Food Prep Sink	In kitchen seventh clockwise from entry	WF-11022020-015524	11/10/2020	FT-FY21-112020-015524-A	<1	FT-FY21-112020-015524-B	<1