



Houston ES (Post Modernization) Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014381	8/11/2020	8/11/2021	1	Break Room	In workroom 134	WF-08112020-014381	8/19/2020	FT-FY20-082020-014381-A	<1	FT-FY20-082020-014381-B	<1
WS-014383	8/11/2020	8/11/2021	1	Break Room	In parent resource 144	WF-08112020-014383	8/19/2020	FT-FY20-082020-014383-A	<1	FT-FY20-082020-014383-B	<1
WS-014384	8/11/2020	8/11/2021	1	Health Suite	In health suite in treatment room 150E	WF-08112020-014384	8/19/2020	FT-FY20-082020-014384-A	<1	FT-FY20-082020-014384-B	<1
WS-014386	8/11/2020	8/11/2021	1	Cooler	In hallway between restrooms 145 and 146 High Left	WF-08112020-014386	8/19/2020	FT-FY20-082020-014386-A	<1	FT-FY20-082020-014386-B	<1
WS-014387	8/11/2020	8/11/2021	1	Cooler	In hallway between restrooms 145 and 146 Low Right	WF-08112020-014387	8/19/2020	FT-FY20-082020-014387-A	<1	FT-FY20-082020-014387-B	<1
WS-014388	8/13/2020	8/13/2021	1	Bottle Filler	In cafeteria	WF-08132020-014388	8/19/2020	FT-FY20-082020-014388-A	<1	FT-FY20-082020-014388-B	<1
WS-014389	8/13/2020	8/13/2021	1	Cooler	In cafeteria High Left	WF-08132020-014389	8/19/2020	FT-FY20-082020-014389-A	<1	FT-FY20-082020-014389-B	<1
WS-014390	8/13/2020	8/13/2021	1	Cooler	In cafeteria Low Right	WF-08132020-014390	8/19/2020	FT-FY20-082020-014390-A	<1	FT-FY20-082020-014390-B	<1
WS-014402	8/11/2020	8/11/2021	2	Combo Fountain	In classroom 231	WF-08112020-014402	8/19/2020	FT-FY20-082020-014402-A	<1	FT-FY20-082020-014402-B	<1
WS-014404	8/11/2020	8/11/2021	2	Combo Fountain	In classroom 232	WF-08112020-014404	8/19/2020	FT-FY20-082020-014404-A	<1	FT-FY20-082020-014404-B	<1
WS-014407	8/11/2020	8/11/2021	2	Combo Fountain	In classroom 234	WF-08112020-014407	8/19/2020	FT-FY20-082020-014407-A	<1	FT-FY20-082020-014407-B	<1
WS-014409	8/11/2020	8/11/2021	2	Combo Fountain	In classroom 235	WF-08112020-014409	8/19/2020	FT-FY20-082020-014409-A	<1	FT-FY20-082020-014409-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014397	8/11/2020	8/11/2021	1	Food Prep Sink	In kitchen second clockwise from entry	WF-08112020-014397	8/19/2020	FT-FY20-082020-014397-A	<1	FT-FY20-082020-014397-B	<1