



Jefferson MS (Post Modernization) Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014909	8/12/2020	8/12/2021	Basement	Bottle Filler	In hallway adjacent to room L35 MDF	WF-08122020-014909	8/20/2020	FT-FY20-082020-014909-A	<1	FT-FY20-082020-014909-B	<1
WS-014910	8/12/2020	8/12/2021	Basement	Cooler	In hallway adjacent to room L35 MDF High Left	WF-08122020-014910	8/20/2020	FT-FY20-082020-014910-A	1.1	FT-FY20-082020-014910-B	<1
WS-014911	8/12/2020	8/12/2021	Basement	Cooler	In hallway adjacent to room L35 MDF Low Right	WF-08122020-014911	8/20/2020	FT-FY20-082020-014911-A	<1	FT-FY20-082020-014911-B	<1
WS-014967	8/12/2020	8/12/2021	3	Bottle Filler	In hallway across from stair B level 3	WF-08122020-014967	8/20/2020	FT-FY20-082020-014967-A	<1	FT-FY20-082020-014967-B	<1
WS-014968	8/12/2020	8/12/2021	3	Cooler	In hallway across from stair B level 3 High Left	WF-08122020-014968	8/20/2020	FT-FY20-082020-014968-A	<1	FT-FY20-082020-014968-B	<1
WS-014969	8/12/2020	8/12/2021	3	Cooler	In hallway across from stair B level 3 Low Right	WF-08122020-014969	8/20/2020	FT-FY20-082020-014969-A	<1	FT-FY20-082020-014969-B	<1
WS-014978	8/12/2020	8/12/2021	2	Bottle Filler	In hallway adjacent to room 203	WF-08122020-014978	8/20/2020	FT-FY20-082020-014978-A	<1	FT-FY20-082020-014978-B	<1
WS-014979	8/12/2020	8/12/2021	2	Cooler	In hallway adjacent to room 203 High Left	WF-08122020-014979	8/20/2020	FT-FY20-082020-014979-A	<1	FT-FY20-082020-014979-B	<1
WS-014980	8/12/2020	8/12/2021	2	Cooler	In hallway adjacent to room 203 Low Right	WF-08122020-014980	8/20/2020	FT-FY20-082020-014980-A	<1	FT-FY20-082020-014980-B	<1
WS-014982	8/11/2020	8/11/2021	Basement	Combo Fountain	In classroom L48 instrumental	WF-08112020-014982	8/20/2020	FT-FY20-082020-014982-A	<1	FT-FY20-082020-014982-B	<1
WS-014984	8/11/2020	8/11/2021	Basement	Combo Fountain	In classroom L43	WF-08112020-014984	8/20/2020	FT-FY20-082020-014984-A	<1	FT-FY20-082020-014984-B	<1
WS-014987	8/11/2020	8/11/2021	Basement	Combo Fountain	In classroom L39	WF-08112020-014987	8/20/2020	FT-FY20-082020-014987-A	<1	FT-FY20-082020-014987-B	<1
WS-014988	8/11/2020	8/11/2021	1	Bottle Filler	In gym on boy's locker room side	WF-08112020-014988	8/20/2020	FT-FY20-082020-014988-A	<1	FT-FY20-082020-014988-B	<1
WS-014989	8/11/2020	8/11/2021	1	Cooler	In gym on boy's locker room side High Left	WF-08112020-014989	8/20/2020	FT-FY20-082020-014989-A	<1	FT-FY20-082020-014989-B	<1
WS-014990	8/11/2020	8/11/2021	1	Cooler	In gym on boy's locker room side Low Right	WF-08112020-014990	8/20/2020	FT-FY20-082020-014990-A	<1	FT-FY20-082020-014990-B	<1
WS-014991	8/11/2020	8/11/2021	1	Bottle Filler	In gym on girls's locker room side	WF-08112020-014991	8/20/2020	FT-FY20-082020-014991-A	<1	FT-FY20-082020-014991-B	<1
WS-014992	8/11/2020	8/11/2021	1	Cooler	In gym on girls's locker room side High Left	WF-08112020-014992	8/20/2020	FT-FY20-082020-014992-A	<1	FT-FY20-082020-014992-B	<1
WS-014993	8/11/2020	8/11/2021	1	Cooler	In gym on girls's locker room side Low Right	WF-08112020-014993	8/20/2020	FT-FY20-082020-014993-A	<1	FT-FY20-082020-014993-B	<1