



Kenilworth Swing Space Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000416	9/28/2020	9/28/2021	1	Cooler	In hallway adjacent to 113 main office	WF-09282020-000416	11/9/2020	FT-FY21-112020-000416-A	<1	FT-FY21-112020-000416-B	<1
WS- 000417	9/28/2020	9/28/2021	1	Cooler	In 119 health suite	WF-09282020-000417	11/9/2020	FT-FY21-112020-000417-A	<1	FT-FY21-112020-000417-B	<1
WS- 000418	9/28/2020	9/28/2021	1	Cooler	In 102 library	WF-09282020-000418	11/9/2020	FT-FY21-112020-000418-A	<1	FT-FY21-112020-000418-B	<1
WS- 000419	9/28/2020	9/28/2021	1	Cooler	In hallway adjacent to 101	WF-09282020-000419	11/9/2020	FT-FY21-112020-000419-A	<1	FT-FY21-112020-000419-B	<1
WS- 000421	9/28/2020	9/28/2021	2	Cooler	In hallway adjacent to 213	WF-09282020-000421	11/9/2020	FT-FY21-112020-000421-A	<1	FT-FY21-112020-000421-B	<1
WS- 000422	9/28/2020	9/28/2021	2	Cooler	In hallway adjacent to 201	WF-09282020-000422	11/9/2020	FT-FY21-112020-000422-A	<1	FT-FY21-112020-000422-B	<1
WS- 000423	9/28/2020	9/28/2021	2	Cooler	In hallway adjacent to girls' restroom	WF-09282020-000423	11/9/2020	FT-FY21-112020-000423-A	<1	FT-FY21-112020-000423-B	<1
WS- 000424	9/28/2020	9/28/2021	2	Cooler	In hallway adjacent to 231	WF-09282020-000424	11/9/2020	FT-FY21-112020-000424-A	<1	FT-FY21-112020-000424-B	<1
WS- 000425	9/28/2020	9/28/2021	3	Break Room	In 304 staff lounge	WF-09282020-000425	11/9/2020	FT-FY21-112020-000425-A	2.4	FT-FY21-112020-000425-B	<1
WS- 000426	9/28/2020	9/28/2021	3	Cooler	In hallway adjacent to 313	WF-09282020-000426	11/9/2020	FT-FY21-112020-000426-A	<1	FT-FY21-112020-000426-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000432	9/28/2020	9/28/2021	Ground Floor	Food Prep Sink	In kitchen trailer 1st clockwise from outdoor entry	WF-09282020-000432	11/9/2020	FT-FY21-112020-000432-A	<1	FT-FY21-112020-000432-B	<1