



# Ferebee-Hope RC Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005689	3/21/2019	3/21/2020	1	Cooler	In women's locker room	WF-03212019-005689	3/18/2020	FT-FY20-012020-005689-A	<1	FT-FY20-012020-005689-B	<1
WS- 005690	3/21/2019	3/21/2020	1	Cooler	In hallway adjacent to gym	Right WF-03212019-005690	3/18/2020	FT-FY20-012020-005690-A	<1	FT-FY20-012020-005690-B	<1
WS- 005691	3/21/2019	3/21/2020	1	Cooler	In hallway adjacent to girl's gym (valve broken)	Left WF-03212019-005691	3/18/2020	FT-FY20-012020-005691-A	<1	FT-FY20-012020-005691-B	<1
WS- 005693	3/21/2019	3/21/2020	2	Cooler	In men's locker room	WF-03212019-005693	3/18/2020	FT-FY20-012020-005693-A	<1	FT-FY20-012020-005693-B	<1