



FLORIDA AVE PLAYGROUND LEAD WATER TEST RESULTS May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 FLORIDA AVE PLAYGROUND	5/24/2016	WS- 005513	Fountain	Ground Floor	Exterior adjacent to basketball court	High	WT-042916-5530- A	2.8	WT-042916-5530- B	3.3				
2 FLORIDA AVE PLAYGROUND	5/24/2016	WS- 005514	Fountain	Ground Floor	Exterior adjacent to basketball court	Low	WT-042916-5531- A	3.1	WT-042916-5531- B	3.5				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.