



# Fort Davis RC Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005385	6/1/2021	6/1/2022	1	Cooler	In hallway adjacent to room 103	WF-06012021-005385	3/6/2022	FT-FY22-02212022-005385-A	<1	FT-FY22-02212022-005385-B	<1
WS- 005386	2/7/2022	2/7/2023	1	Food Prep Sink	In pantry room 104 in kitchen	WF-02072022-005386	3/6/2022	FT-FY22-02212022-005386-A	<1	FT-FY22-02212022-005386-B	<1