



Fort Davis Recreation Center Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005385	6/29/2022	6/29/2023	1	Cooler	In hallway adjacent to room 103	WF-06292022-005385	2/21/2023	FT-FY23-02022023-005385-A	<1	FT-FY23-02022023-005385-B	<1
WS- 005386	1/10/2023	1/10/2024	1	Food Prep Sink	In pantry room 104 in kitchen	WF-01102023-005386	2/21/2023	FT-FY23-02022023-005386-A	<1	FT-FY23-02022023-005386-B	<1