



Fort Davis Recreation Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005385	4/22/2024	4/22/2025	1	Cooler	In hallway adjacent to room 103	WF-04222024-005385	5/7/2024	FT-FY24-04242024-005385-A	<1	FT-FY24-04242024-005385-B	<1
WS- 005386	12/4/2023	12/4/2024	1	Food Prep Sink	In pantry room 104 in kitchen	WF-12042023-005386	5/7/2024	FT-FY24-04242024-005386-A	<1	FT-FY24-04242024-005386-B	<1