



Fort Dupont Pool Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003804	4/29/2019	4/29/2020	1	Food Prep Sink	In kitchen Right	WF-04292019-003804	3/11/2020	FT-FY20-012020-003804-A	<1	FT-FY20-012020-003804-B	<1
WS- 003806	4/5/2019	4/5/2020	1	Cooler	In hallway adjacent to aquatics office 110 High	WF-04052019-003806	3/11/2020	FT-FY20-012020-003806-A	<1	FT-FY20-012020-003806-B	<1
WS- 003807	4/5/2019	4/5/2020	1	Bottle Filler	In hallway adjacent to aquatics office 110 (bottle filler)	WF-04052019-003807	3/11/2020	FT-FY20-012020-003807-A	<1	FT-FY20-012020-003807-B	<1
WS- 003808	4/5/2019	4/5/2020	Ground Floor	Cooler	In hallway adjacent to aquatics office 110 Low	WF-04052019-003808	3/11/2020	FT-FY20-012020-003808-A	<1	FT-FY20-012020-003808-B	<1
WS- 003809	4/5/2019	4/5/2020	1	Cooler	In hallway adjacent to room 100 High	WF-04052019-003809	3/11/2020	FT-FY20-012020-003809-A	<1	FT-FY20-012020-003809-B	<1
WS- 003810	4/5/2019	4/5/2020	1	Bottle Filler	In hallway adjacent to room 100 (bottle filler)	WF-04052019-003810	3/11/2020	FT-FY20-012020-003810-A	<1	FT-FY20-012020-003810-B	<1
WS- 003811	4/5/2019	4/5/2020	1	Cooler	In hallway adjacent to room 100 Low	WF-04052019-003811	3/11/2020	FT-FY20-012020-003811-A	<1	FT-FY20-012020-003811-B	<1
WS- 003812	4/8/2019	4/8/2020	1	Classroom Faucet	In arts and crafts room 104	WF-04082019-003812	3/11/2020	FT-FY20-012020-003812-A	<1	FT-FY20-012020-003812-B	<1