



Fort Dupont Pool Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003804	1/26/2022	1/26/2023	1	Food Prep Sink	In kitchen Right	WF-01262022-003804	3/7/2022	FT-FY22-02212022-003804-A	<1	FT-FY22-02212022-003804-B	<1
WS- 003809	3/25/2021	3/25/2022	1	Cooler	In hallway adjacent to room 100 High	WF-03252021-003809	3/7/2022	FT-FY22-02212022-003809-A	<1	FT-FY22-02212022-003809-B	<1
WS- 003810	3/25/2021	3/25/2022	1	Bottle Filler	In hallway adjacent to room 100 (bottle filler)	WF-03252021-003810	3/7/2022	FT-FY22-02212022-003810-A	<1	FT-FY22-02212022-003810-B	<1
WS- 003811	3/25/2021	3/25/2022	1	Cooler	In hallway adjacent to room 100 Low	WF-03252021-003811	3/7/2022	FT-FY22-02212022-003811-A	<1	FT-FY22-02212022-003811-B	<1
WS- 003812	3/26/2021	3/26/2022	1	Classroom Faucet	In arts and crafts room 104	WF-03262021-003812	3/7/2022	FT-FY22-02212022-003812-A	<1	FT-FY22-02212022-003812-B	<1