



# Fort Stanton Recreation Center Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006231	3/19/2024	3/19/2025	Ground Floor	Cooler	In lobby adjacent to elevator High Left	WF-03192024-006231	4/9/2024	FT-FY24-03272024-006231-A	<1	FT-FY24-03272024-006231-B	<1
WS- 006232	3/19/2024	3/19/2025	Ground Floor	Cooler	In lobby adjacent to elevator Low Right	WF-03192024-006232	4/9/2024	FT-FY24-03272024-006232-A	<1	FT-FY24-03272024-006232-B	<1
WS- 006233	3/19/2024	3/19/2025	Ground Floor	Cooler	In hallway adjacent to kitchen 103 High Left	WF-03192024-006233	4/9/2024	FT-FY24-03272024-006233-A	<1	FT-FY24-03272024-006233-B	<1
WS- 006234	3/19/2024	3/19/2025	Ground Floor	Cooler	In hallway adjacent to kitchen 103 Low Right	WF-03192024-006234	4/9/2024	FT-FY24-03272024-006234-A	<1	FT-FY24-03272024-006234-B	<1
WS- 006235	12/4/2023	12/4/2024	Ground Floor	Food Prep Sink	In kitchen 103	WF-12042023-006235	4/9/2024	FT-FY24-03272024-006235-A	<1	FT-FY24-03272024-006235-B	<1