



FORT STANTON REC LEAD WATER TEST RESULTS May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 FORT STANTON RECREATION CENTER	5/25/2016	WS- 006230	Cooler	Ground Floor	Exterior in the pool area	WT-042916-6247- A	< 1	WT-042916-6247- B	< 1				
2 FORT STANTON RECREATION CENTER	5/25/2016	WS- 006231	Cooler	Ground Floor	In lobby adjacent elevator Left High	WT-042916-6248- A	< 1	WT-042916-6248- B	< 1				
3 FORT STANTON RECREATION CENTER	5/25/2016	WS- 006232	Cooler	Ground Floor	In the lobby adjacent to elevator Right Low	WT-042916-6249- A	< 1	WT-042916-6249- B	< 1				
4 FORT STANTON RECREATION CENTER	5/25/2016	WS- 006233	Cooler	Ground Floor	In hallway adjacent to kitchen 103 Left High	WT-042916-6250- A	< 1	WT-042916-6250- B	< 1				
5 FORT STANTON RECREATION CENTER	5/25/2016	WS- 006234	Cooler	Ground Floor	In hallway adjacent to kitchen 103 Right Low	WT-042916-6251- A	< 1	WT-042916-6251- B	< 1				
6 FORT STANTON RECREATION CENTER	5/25/2016	WS- 006235	Kitchen	Ground Floor	In kitchen 103	WT-042916-6252- A	< 1	WT-042916-6252- B	< 1				
7 FORT STANTON RECREATION CENTER	5/25/2016	WS- 006236	Classroom	Ground Floor	In Arts and Crafts 109	WT-042916-6253- A	< 1	WT-042916-6253- B	< 1				
8 FORT STANTON RECREATION CENTER	5/25/2016	WS- 006237	Classroom	Ground Floor	In seniors lounge 111	WT-042916-6254- A	< 1	WT-042916-6254- B	< 1				
9 FORT STANTON RECREATION CENTER	5/25/2016	WS- 006238	Utility	Ground Floor	In Mech./Elec. 106	WT-042916-6255- A	2.4	WT-042916-6255- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.