



Fort Stevens Recreation Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012703	3/19/2024	3/19/2025	Ground Floor	Cooler	In Rec center adjacent to women's bathroom Low Left	WF-03192024-012703	4/9/2024	FT-FY24-03272024-012703-A	<1	FT-FY24-03272024-012703-B	<1
WS- 012704	3/19/2024	3/19/2025	Ground Floor	Cooler	In Rec center adjacent to women's bathroom Right	WF-03192024-012704	4/9/2024	FT-FY24-03272024-012704-A	<1	FT-FY24-03272024-012704-B	<1
WS- 012705	3/19/2024	3/19/2025	Ground Floor	Bottle Filler	In Senior Center adjacent to kitchen (bottle filler)	WF-03192024-012705	4/9/2024	FT-FY24-03272024-012705-A	<1	FT-FY24-03272024-012705-B	<1
WS- 012706	3/19/2024	3/19/2025	Ground Floor	Cooler	In Senior Center adjacent to kitchen High Left	WF-03192024-012706	4/9/2024	FT-FY24-03272024-012706-A	<1	FT-FY24-03272024-012706-B	<1
WS- 012707	3/19/2024	3/19/2025	Ground Floor	Cooler	In Senior Center adjacent to kitchen Low Right	WF-03192024-012707	4/9/2024	FT-FY24-03272024-012707-A	<1	FT-FY24-03272024-012707-B	<1