



Fort Stevens Recreation Center Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012705	4/11/2022	4/11/2023	Ground Floor	Bottle Filler	In Senior Center adjacent to kitchen (bottle filler)	WF-04112022-012705	2/9/2023	FT-FY23-01192023-012705-A	<1	FT-FY23-01192023-012705-B	<1
WS- 012706	4/11/2022	4/11/2023	Ground Floor	Cooler	In Senior Center adjacent to kitchen High Left	WF-04112022-012706	2/9/2023	FT-FY23-01192023-012706-A	<1	FT-FY23-01192023-012706-B	<1
WS- 012707	4/11/2022	4/11/2023	Ground Floor	Cooler	In Senior Center adjacent to kitchen Low Right	WF-04112022-012707	2/9/2023	FT-FY23-01192023-012707-A	<1	FT-FY23-01192023-012707-B	<1