



FRANCIS EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	FRANCIS EDUCATIONAL CAMPUS	WS- 008705	8/15/2016	1	Cooler	In hallway adjacent to southwest stairwell	FT-82016-008705-A	< 1	FT-82016-008705-B	< 1
2	FRANCIS EDUCATIONAL CAMPUS	WS- 008706	8/15/2016	1	Cooler	In hallway adjacent to library	FT-82016-008706-A	< 1	FT-82016-008706-B	< 1
3	FRANCIS EDUCATIONAL CAMPUS	WS- 008707	8/15/2016	1	Bottle Filler	In cafeteria (bottle filler)	FT-82016-008707-A	< 1	FT-82016-008707-B	< 1
4	FRANCIS EDUCATIONAL CAMPUS	WS- 008708	8/15/2016	1	Cooler	In cafeteria High Left	FT-82016-008708-A	< 1	FT-82016-008708-B	< 1
5	FRANCIS EDUCATIONAL CAMPUS	WS- 008709	8/15/2016	1	Cooler	In cafeteria Low Right	FT-82016-008709-A	< 1	FT-82016-008709-B	< 1
6	FRANCIS EDUCATIONAL CAMPUS	WS- 008710	8/15/2016	1	Food Prep Sink	In kitchen first clockwise from entry door	FT-82016-008710-A	< 1	FT-82016-008710-B	< 1
7	FRANCIS EDUCATIONAL CAMPUS	WS- 008712	8/15/2016	1	Food Prep Sink	In kitchen second clockwise from entry door	FT-82016-008712-A	< 1	FT-82016-008712-B	< 1
8	FRANCIS EDUCATIONAL CAMPUS	WS- 008713	8/15/2016	1	Food Prep Sink	In kitchen third clockwise from entry door	FT-82016-008713-A	< 1	FT-82016-008713-B	< 1
9	FRANCIS EDUCATIONAL CAMPUS	WS- 008714	8/15/2016	1	Food Prep Sink	In kitchen fourth clockwise from entry door	FT-72016-008714-A	< 1	FT-72016-008714-B	< 1
10	FRANCIS EDUCATIONAL CAMPUS	WS- 008715	8/15/2016	1	Food Prep Sink	In kitchen fifth clockwise from entry door	FT-72016-008715-A	< 1	FT-72016-008715-B	< 1
11	FRANCIS EDUCATIONAL CAMPUS	WS- 008716	8/15/2016	1	Ice Maker	In kitchen (ice maker)	FT-82016-008716-A	< 1	FT-82016-008716-B	< 1
12	FRANCIS EDUCATIONAL CAMPUS	WS- 008718	8/15/2016	1	Cooler	In classroom 104	FT-82016-008718-A	< 1	FT-82016-008718-B	< 1
13	FRANCIS EDUCATIONAL CAMPUS	WS- 008720	8/15/2016	1	Cooler	In classroom 102	FT-82016-008720-A	< 1	FT-82016-008720-B	< 1
14	FRANCIS EDUCATIONAL CAMPUS	WS- 008721	8/15/2016	1	Cooler	In classroom 101	FT-82016-008721-A	< 1	FT-82016-008721-B	< 1
15	FRANCIS EDUCATIONAL CAMPUS	WS- 008722	8/15/2016	1	Classroom Faucet	In classroom 101	FT-72016-008722-A	< 1	FT-72016-008722-B	< 1
16	FRANCIS EDUCATIONAL CAMPUS	WS- 008728	8/15/2016	1	Classroom Faucet	In science lab room 112 fourth clockwise from entry door	FT-72016-008728-A	< 1	FT-72016-008728-B	< 1
17	FRANCIS EDUCATIONAL CAMPUS	WS- 008732	8/15/2016	1	Cooler	In classroom 110	FT-82016-008732-A	< 1	FT-82016-008732-B	< 1
18	FRANCIS EDUCATIONAL CAMPUS	WS- 008734	8/15/2016	1	Cooler	In classroom 109	FT-82016-008734-A	< 1	FT-82016-008734-B	< 1
19	FRANCIS EDUCATIONAL CAMPUS	WS- 008736	8/15/2016	2	Cooler	In hallway adjacent to southwest stairwell	FT-82016-008736-A	< 1	FT-82016-008736-B	< 1
20	FRANCIS EDUCATIONAL CAMPUS	WS- 008737	8/15/2016	2	Cooler	In hallway adjacent to room 206	FT-82016-008737-A	< 1	FT-82016-008737-B	< 1
21	FRANCIS EDUCATIONAL CAMPUS	WS- 008738	8/15/2016	1	Health Suite	In health suite	FT-82016-008738-A	< 1	FT-82016-008738-B	< 1
22	FRANCIS EDUCATIONAL CAMPUS	WS- 008739	8/15/2016	3	Cooler	In hallway adjacent to room 309	FT-82016-008739-A	< 1	FT-82016-008739-B	< 1
23	FRANCIS EDUCATIONAL CAMPUS	WS- 008743	8/15/2016	3	Classroom Faucet	In science lab room 309 second clockwise from west entry door	FT-72016-008743-A	< 1	FT-72016-008743-B	< 1
24	FRANCIS EDUCATIONAL CAMPUS	WS- 008744	8/15/2016	3	Classroom Faucet	In science lab room 309 third clockwise from west entry door	FT-72016-008744-A	< 1	FT-72016-008744-B	< 1
25	FRANCIS EDUCATIONAL CAMPUS	WS- 008746	8/15/2016	3	Cooler	In hallway adjacent to room 305	FT-82016-008746-A	< 1	FT-82016-008746-B	< 1