



Francis Pool Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011574	3/26/2021	3/26/2022	1	Health Suite	In health suite	WF-03262021-011574	6/8/2021	FT-FY21-052021-011574-A	<1	FT-FY21-052021-011574-B	<1
WS- 011576	3/26/2021	3/26/2022	1	Cooler	In hallway adjacent to room 117 High Right	WF-03262021-011576	6/8/2021	FT-FY21-052021-011576-A	<1	FT-FY21-052021-011576-B	<1
WS- 011577	3/26/2021	3/26/2022	1	Cooler	In hallway adjacent to room 117 Low Left	WF-03262021-011577	6/8/2021	FT-FY21-052021-011577-A	<1	FT-FY21-052021-011577-B	<1