



Francis Pool Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
|------------|-----------------------|------------------------|-------|--------------|--|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| WS- 011574 | 4/9/2019 | 4/9/2020 | 1 | Health Suite | In health suite | WF-04092019-011574 | 5/24/2019 | FT-FY19-052019-011574-A | <1 | FT-FY19-052019-011574-B | <1 |
| WS- 011576 | 4/9/2019 | 4/9/2020 | 1 | Cooler | In hallway adjacent to room 117 High Right | WF-04092019-011576 | 5/24/2019 | FT-FY19-052019-011576-A | <1 | FT-FY19-052019-011576-B | <1 |
| WS- 011577 | 4/9/2019 | 4/9/2020 | 1 | Cooler | In hallway adjacent to room 117 Low Left | WF-04092019-011577 | 5/24/2019 | FT-FY19-052019-011577-A | <1 | FT-FY19-052019-011577-B | <1 |