



Francis Education Campus Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008709	5/19/17	5/19/18	1	Cooler	In cafeteria Right Low	WF-52017-008709	12/5/17	FT-FY18--52017-008709-A	<1	FT-FY18--52017-008709-B	<1
WS- 008718	5/19/17	5/19/18	1	Cooler	In classroom 104	WF-52017-008718	12/5/17	FT-FY18--52017-008718-A	<1	FT-FY18--52017-008718-B	<1
WS- 008721	5/19/17	5/19/18	1	Cooler	In classroom 101	WF-52017-008721	12/5/17	FT-FY18--52017-008721-A	<1	FT-FY18--52017-008721-B	<1
WS- 008722	11/21/17	11/21/18	1	Classroom Faucet	In classroom 101	WF-112017-008722	12/5/17	FT-FY18-112017-008722-A	<1	FT-FY18-112017-008722-B	<1
WS- 008733	11/21/17	11/21/18	1	Classroom Faucet	In classroom 110	WF-112017-008733	12/5/17	FT-FY18-112017-008733-A	<1	FT-FY18-112017-008733-B	<1
WS- 008734	5/19/17	5/19/18	1	Cooler	In classroom 109	WF-52017-008734	12/5/17	FT-FY18--52017-008734-A	<1	FT-FY18--52017-008734-B	<1
WS- 008736	5/19/17	5/19/18	2	Cooler	In hallway adjacent to southwest stairwell	WF-52017-008736	12/5/17	FT-FY18--52017-008736-A	<1	FT-FY18--52017-008736-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008710	1	Food Prep Sink	In kitchen first clockwise from entry door	12/5/17	FT-FY18-102017-008710-A	<1	FT-FY18-102017-008710-B	<1	
WS- 008712	1	Food Prep Sink	In kitchen second clockwise from entry door	12/5/17	FT-FY18-102017-008712-A	<1	FT-FY18-102017-008712-B	<1	
WS- 008713	1	Food Prep Sink	In kitchen third clockwise from entry door	12/5/17	FT-FY18-102017-008713-A	<1	FT-FY18-102017-008713-B	<1	
WS- 008714	1	Food Prep Sink	In kitchen fourth clockwise from entry door	12/5/17	FT-FY18-102017-008714-A	<1	FT-FY18-102017-008714-B	<1	
WS- 008715	1	Food Prep Sink	In kitchen fifth clockwise from entry door	12/5/17	FT-FY18-102017-008715-A	<1	FT-FY18-102017-008715-B	<1	