



Friendship Recreation Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001220	3/25/2024	3/25/2025	Ground Floor	Bottle Filler	In hallway adjacent to main office	WF-03252024-001220	4/19/2024	FT-FY24-04022024-001220-A	<1	FT-FY24-04022024-001220-B	<1
WS- 001221	3/25/2024	3/25/2025	Ground Floor	Cooler	In hallway adjacent to main office	WF-03252024-001221	4/19/2024	FT-FY24-04022024-001221-A	<1	FT-FY24-04022024-001221-B	<1
WS- 001222	3/25/2024	3/25/2025	Ground Floor	Cooler	In hallway adjacent to main office	WF-03252024-001222	4/19/2024	FT-FY24-04022024-001222-A	<1	FT-FY24-04022024-001222-B	<1