



Friendship RC Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001220	4/20/2021	4/20/2022	Ground Floor	Bottle Filler	In hallway adjacent to main office	WF-04202021-001220	2/9/2022	FT-FY22-01182022-001220-A	<1	FT-FY22-01182022-001220-B	<1
WS- 001221	4/20/2021	4/20/2022	Ground Floor	Cooler	In hallway adjacent to main office Low Left	WF-04202021-001221	2/9/2022	FT-FY22-01182022-001221-A	<1	FT-FY22-01182022-001221-B	<1
WS- 001222	4/20/2021	4/20/2022	Ground Floor	Cooler	In hallway adjacent to main office Low Right	WF-04202021-001222	2/9/2022	FT-FY22-01182022-001222-A	<1	FT-FY22-01182022-001222-B	<1
WS- 001223	4/20/2021	4/20/2022	Ground Floor	Break Room	In warm kitchen adjacent to main office	WF-04202021-001223	2/9/2022	FT-FY22-01182022-001223-A	<1	FT-FY22-01182022-001223-B	<1