



GARRISON ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Below Actionable Level - Devices Requiring No Remediation									
Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
GARRISON ELEMENTARY SCHOOL	WS-002847	8/29/2017	2	Break Room	In staff lounge 248	FT-82017-002847-A	1.3	FT-82017-002847-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002849	8/29/2017	2	Combo Fountain	In classroom 249	FT-82017-002849-A	< 1	FT-82017-002849-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002850	8/29/2017	2	Cooler	In hallway adjacent to staff restroom High Left	FT-82017-002850-A	< 1	FT-82017-002850-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002851	8/29/2017	2	Cooler	In hallway adjacent to staff restroom Low Right	FT-82017-002851-A	< 1	FT-82017-002851-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002853	8/29/2017	2	Combo Fountain	In classroom 246	FT-82017-002853-A	< 1	FT-82017-002853-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002855	8/29/2017	2	Combo Fountain	In classroom 246	FT-82017-002855-A	< 1	FT-82017-002855-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002857	8/29/2017	2	Combo Fountain	In classroom 247	FT-82017-002857-A	< 1	FT-82017-002857-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002859	8/29/2017	2	Combo Fountain	In classroom 244	FT-82017-002859-A	< 1	FT-82017-002859-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002861	8/29/2017	2	Combo Fountain	In classroom 241	FT-82017-002861-A	< 1	FT-82017-002861-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002862	8/29/2017	2	Cooler	In hallway adjacent to staff restroom	FT-82017-002862-A	< 1	FT-82017-002862-B	1.1
GARRISON ELEMENTARY SCHOOL	WS-002864	8/29/2017	2	Combo Fountain	In classroom 223	FT-82017-002864-A	< 1	FT-82017-002864-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002866	8/29/2017	2	Combo Fountain	In classroom 225	FT-82017-002866-A	< 1	FT-82017-002866-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002868	8/29/2017	2	Combo Fountain	In classroom 227	FT-82017-002868-A	< 1	FT-82017-002868-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002870	8/29/2017	2	Combo Fountain	In classroom 226	FT-82017-002870-A	< 1	FT-82017-002870-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002872	8/29/2017	2	Combo Fountain	In classroom 228	FT-82017-002872-A	< 1	FT-82017-002872-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002874	8/29/2017	2	Combo Fountain	In classroom 230	FT-82017-002874-A	1.2	FT-82017-002874-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002876	8/29/2017	2	Combo Fountain	In classroom 229	FT-82017-002876-A	1.7	FT-82017-002876-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002878	8/29/2017	1	Cooler	In hallway adjacent to health suite 162A	FT-82017-002878-A	< 1	FT-82017-002878-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002879	8/29/2017	1	Combo Faucet	In classroom 145	FT-82017-002879-A	4.3	FT-82017-002879-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002880	8/29/2017	1	Combo Fountain	In classroom 145	FT-82017-002880-A	< 1	FT-82017-002880-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002881	8/29/2017	1	Combo Faucet	In classroom 160	FT-82017-002881-A	< 1	FT-82017-002881-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002882	8/29/2017	1	Combo Fountain	In classroom 160	FT-82017-002882-A	4.1	FT-82017-002882-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002883	8/29/2017	1	Combo Faucet	In classroom 143	FT-82017-002883-A	< 1	FT-82017-002883-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002884	8/29/2017	1	Combo Fountain	In classroom 143	FT-82017-002884-A	< 1	FT-82017-002884-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002886	8/29/2017	2	Combo Fountain	In classroom 243	FT-82017-002886-A	< 1	FT-82017-002886-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002887	8/29/2017	1	Break Room	In parent resource center C105	FT-82017-002887-A	< 1	FT-82017-002887-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002888	8/29/2017	1	Cooler	In hallway adjacent to stairwell 1 High Left	FT-82017-002888-A	< 1	FT-82017-002888-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002889	8/29/2017	1	Cooler	In hallway adjacent to stairwell 1 Low Right	FT-82017-002889-A	< 1	FT-82017-002889-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002890	8/29/2017	1	Combo Faucet	In classroom 125	FT-82017-002890-A	< 1	FT-82017-002890-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002891	8/29/2017	1	Combo Fountain	In classroom 125	FT-82017-002891-A	< 1	FT-82017-002891-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002892	8/29/2017	1	Combo Faucet	In classroom 126	FT-82017-002892-A	< 1	FT-82017-002892-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002893	8/29/2017	1	Combo Fountain	In classroom 126	FT-82017-002893-A	< 1	FT-82017-002893-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002894	8/29/2017	1	Combo Faucet	In classroom 127	FT-82017-002894-A	2.2	FT-82017-002894-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002895	8/29/2017	1	Combo Fountain	In classroom 127	FT-82017-002895-A	< 1	FT-82017-002895-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002896	8/29/2017	1	Combo Faucet	In classroom 128	FT-82017-002896-A	< 1	FT-82017-002896-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002897	8/29/2017	1	Combo Fountain	In classroom 128	FT-82017-002897-A	< 1	FT-82017-002897-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002898	8/29/2017	1	Combo Faucet	In classroom 132	FT-82017-002898-A	< 1	FT-82017-002898-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002899	8/29/2017	1	Combo Fountain	In classroom 132	FT-82017-002899-A	2.9	FT-82017-002899-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002900	8/29/2017	1	Combo Faucet	In classroom 129	FT-82017-002900-A	< 1	FT-82017-002900-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002901	8/29/2017	1	Combo Fountain	In classroom 129	FT-82017-002901-A	< 1	FT-82017-002901-B	< 1
GARRISON ELEMENTARY SCHOOL	WS-002902	8/29/2017	1	Break Room	In staff lounge 123	FT-82017-002902-A	< 1	FT-82017-002902-B	< 1

Above Actionable Level - Devices Shut Off and Corrective Action to be Taken									
GARRISON ELEMENTARY SCHOOL	WS-002877	8/29/2017	1	Health Suite	In health suite 162B	FT-82017-002877-A	37	FT-82017-002877-B	< 1