



Garfield Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004520	3/22/2021	3/22/2022	Basement	Cooler	In cafeteria adjacent to kitchen	WF-03222021-004520	2/4/2022	FT-FY22-01182022-004520-A	<1	FT-FY22-01182022-004520-B	<1
WS- 004521	3/22/2021	3/22/2022	1	Cooler	In hallway adjacent to main office 101	WF-03222021-004521	2/4/2022	FT-FY22-01182022-004521-A	<1	FT-FY22-01182022-004521-B	<1
WS- 004522	3/22/2021	3/22/2022	2	Cooler	In hallway adjacent to staff lounge 210	WF-03222021-004522	2/4/2022	FT-FY22-01182022-004522-A	<1	FT-FY22-01182022-004522-B	<1
WS- 004523	3/22/2021	3/22/2022	2	Cooler	In hallway across from stairwell 4	WF-03222021-004523	2/4/2022	FT-FY22-01182022-004523-A	<1	FT-FY22-01182022-004523-B	<1
WS- 004524	3/22/2021	3/22/2022	1	Cooler	In hallway adjacent to room 109	WF-03222021-004524	2/4/2022	FT-FY22-01182022-004524-A	<1	FT-FY22-01182022-004524-B	<1
WS- 004525	3/22/2021	3/22/2022	1	Cooler	In hallway adjacent to ECE boys' room	WF-03222021-004525	2/4/2022	FT-FY22-01182022-004525-A	<1	FT-FY22-01182022-004525-B	<1
WS- 004526	3/22/2021	3/22/2022	2	Cooler	In hallway adjacent to room 201	WF-03222021-004526	2/4/2022	FT-FY22-01182022-004526-A	<1	FT-FY22-01182022-004526-B	<1
WS- 004527	3/22/2021	3/22/2022	2	Cooler	In hallway adjacent to room 203	WF-03222021-004527	2/4/2022	FT-FY22-01182022-004527-A	<1	FT-FY22-01182022-004527-B	<1
WS- 008610	3/22/2021	3/22/2022	1	Cooler	In hallway adjacent to room 104	WF-03222021-008610	2/4/2022	FT-FY22-01182022-008610-A	<1	FT-FY22-01182022-008610-B	<1
WS- 008611	3/22/2021	3/22/2022	1	Cooler	In health suite 107	WF-03222021-008611	2/4/2022	FT-FY22-01182022-008611-A	<1	FT-FY22-01182022-008611-B	<1
WS- 008613	3/22/2021	3/22/2022	1	Break Room	In break room 109	WF-03222021-008613	2/4/2022	FT-FY22-01182022-008613-A	<1	FT-FY22-01182022-008613-B	<1
WS- 008614	3/22/2021	3/22/2022	1	Cooler	In classroom 110	WF-03222021-008614	2/4/2022	FT-FY22-01182022-008614-A	<1	FT-FY22-01182022-008614-B	<1
WS- 008615	3/22/2021	3/22/2022	1	Cooler	In classroom 111	WF-03222021-008615	2/4/2022	FT-FY22-01182022-008615-A	<1	FT-FY22-01182022-008615-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008607	2/22/2021	2/22/2022	Basement	Food Prep Sink	In kitchen	Left	WF-02222021-008607	2/4/2022	FT-FY22-01182022-008607-A	<1	FT-FY22-01182022-008607-B	<1
WS- 008608	2/22/2021	2/22/2022	Basement	Food Prep Sink	In kitchen	Right	WF-02222021-008608	2/4/2022	FT-FY22-01182022-008608-A	<1	FT-FY22-01182022-008608-B	<1