



Garfield Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004519	3/30/2020	3/30/2021	Basement	Cooler	In cafeteria adjacent to entry door	WF-03302020-004519	3/22/2021	FT-FY21-032021-004519-A	<1	FT-FY21-032021-004519-B	<1
WS- 004520	3/30/2020	3/30/2021	Basement	Cooler	In cafeteria adjacent to kitchen	WF-03302020-004520	3/22/2021	FT-FY21-032021-004520-A	<1	FT-FY21-032021-004520-B	<1
WS- 004523	3/30/2020	3/30/2021	2	Cooler	In hallway across from stairwell 4	WF-03302020-004523	3/22/2021	FT-FY21-032021-004523-A	<1	FT-FY21-032021-004523-B	<1
WS- 004524	3/30/2020	3/30/2021	1	Cooler	In hallway adjacent to room 109	WF-03302020-004524	3/22/2021	FT-FY21-032021-004524-A	<1	FT-FY21-032021-004524-B	<1
WS- 004526	3/30/2020	3/30/2021	2	Cooler	In hallway adjacent to room 201	WF-03302020-004526	3/22/2021	FT-FY21-032021-004526-A	<1	FT-FY21-032021-004526-B	<1
WS- 008610	3/30/2020	3/30/2021	1	Cooler	In hallway adjacent to room 104	WF-03302020-008610	3/22/2021	FT-FY21-032021-008610-A	<1	FT-FY21-032021-008610-B	<1
WS- 008613	3/30/2020	3/30/2021	1	Break Room	In break room 109	WF-03302020-008613	3/22/2021	FT-FY21-032021-008613-A	<1	FT-FY21-032021-008613-B	<1
WS- 008614	7/8/2020	7/8/2021	1	Cooler	In classroom 110	WF-07082020-008614	3/22/2021	FT-FY21-032021-008614-A	<1	FT-FY21-032021-008614-B	<1
WS- 008615	7/8/2020	7/8/2021	1	Cooler	In classroom 111	WF-07082020-008615	3/22/2021	FT-FY21-032021-008615-A	<1	FT-FY21-032021-008615-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008607	2/22/2021	2/22/2022	Basement	Food Prep Sink	In kitchen	Left	WF-02222021-008607	3/22/2021	FT-FY21-032021-008607-A	<1	FT-FY21-032021-008607-B	<1
WS- 008608	2/22/2021	2/22/2022	Basement	Food Prep Sink	In kitchen	Right	WF-02222021-008608	3/22/2021	FT-FY21-032021-008608-A	<1	FT-FY21-032021-008608-B	<1