



Garfield ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004521	4/8/2019	4/8/2020	1	Cooler	In hallway adjacent to main office 101	WF-04082019-004521	10/21/2019	FT-FY20-102019-004521-A	<1	FT-FY20-102019-004521-B	<1
WS- 004522	4/8/2019	4/8/2020	2	Cooler	In hallway adjacent to staff lounge 210	WF-04082019-004522	10/21/2019	FT-FY20-102019-004522-A	<1	FT-FY20-102019-004522-B	<1
WS- 004523	4/8/2019	4/8/2020	2	Cooler	In hallway across from stairwell 4	WF-04082019-004523	10/21/2019	FT-FY20-102019-004523-A	<1	FT-FY20-102019-004523-B	<1
WS- 004524	4/8/2019	4/8/2020	1	Cooler	In hallway adjacent to room 109	WF-04082019-004524	10/21/2019	FT-FY20-102019-004524-A	<1	FT-FY20-102019-004524-B	<1
WS- 004525	4/8/2019	4/8/2020	1	Cooler	In hallway adjacent to ECE boys' room	WF-04082019-004525	10/21/2019	FT-FY20-102019-004525-A	<1	FT-FY20-102019-004525-B	<1
WS- 008611	4/8/2019	4/8/2020	1	Cooler	In health suite 107	WF-04082019-008611	10/21/2019	FT-FY20-102019-008611-A	<1	FT-FY20-102019-008611-B	<1
WS- 008613	4/8/2019	4/8/2020	1	Break Room	In break room 109	WF-04082019-008613	10/21/2019	FT-FY20-102019-008613-A	<1	FT-FY20-102019-008613-B	<1
WS- 008614	4/8/2019	4/8/2020	1	Cooler	In classroom 110	WF-04082019-008614	10/21/2019	FT-FY20-102019-008614-A	<1	FT-FY20-102019-008614-B	<1
WS- 008615	4/8/2019	4/8/2020	1	Cooler	In classroom 111	WF-04082019-008615	10/21/2019	FT-FY20-102019-008615-A	<1	FT-FY20-102019-008615-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008607	7/11/2019	7/11/2020	Basement	Food Prep Sink	In kitchen Left	WF-07112019-008607	10/21/2019	FT-FY20-102019-008607-A	<1	FT-FY20-102019-008607-B	<1
WS- 008608	7/11/2019	7/11/2020	Basement	Food Prep Sink	In kitchen Right	WF-07112019-008608	10/21/2019	FT-FY20-102019-008608-A	<1	FT-FY20-102019-008608-B	<1