



Garfield Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004521	3/14/2022	3/14/2023	1	Cooler	In hallway adjacent to main office 101	WF-03142022-004521	10/25/2022	FT-FY23-10102022-004521-A	<1	FT-FY23-10102022-004521-B	<1
WS- 004523	3/14/2022	3/14/2023	2	Cooler	In hallway across from stairwell 4	WF-03142022-004523	10/25/2022	FT-FY23-10102022-004523-A	<1	FT-FY23-10102022-004523-B	<1
WS- 004524	3/14/2022	3/14/2023	1	Cooler	In hallway adjacent to room 109	WF-03142022-004524	10/25/2022	FT-FY23-10102022-004524-A	<1	FT-FY23-10102022-004524-B	<1
WS- 004525	3/14/2022	3/14/2023	1	Cooler	In hallway adjacent to ECE boys' room	WF-03142022-004525	10/25/2022	FT-FY23-10102022-004525-A	<1	FT-FY23-10102022-004525-B	<1
WS- 004526	3/14/2022	3/14/2023	2	Cooler	In hallway adjacent to room 201	WF-03142022-004526	10/25/2022	FT-FY23-10102022-004526-A	<1	FT-FY23-10102022-004526-B	<1
WS- 004527	3/14/2022	3/14/2023	2	Cooler	In hallway adjacent to room 203	WF-03142022-004527	10/25/2022	FT-FY23-10102022-004527-A	<1	FT-FY23-10102022-004527-B	<1
WS- 004528	3/14/2022	3/14/2023	2	Bottle Filler	In hallway adjacent to staff lounge 210	WF-03142022-004528	10/25/2022	FT-FY23-10102022-004528-A	<1	FT-FY23-10102022-004528-B	<1
WS- 008610	3/14/2022	3/14/2023	1	Cooler	In hallway adjacent to room 104	WF-03142022-008610	10/25/2022	FT-FY23-10102022-008610-A	<1	FT-FY23-10102022-008610-B	<1
WS- 008611	3/14/2022	3/14/2023	1	Cooler	In health suite 107	WF-03142022-008611	10/25/2022	FT-FY23-10102022-008611-A	<1	FT-FY23-10102022-008611-B	<1
WS- 008613	3/14/2022	3/14/2023	1	Break Room	In break room 109	WF-03142022-008613	10/25/2022	FT-FY23-10102022-008613-A	<1	FT-FY23-10102022-008613-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008607	2/14/2022	2/14/2023	Basement	Food Prep Sink	In kitchen	Left	WF-02142022-008607	10/25/2022	FT-FY23-10102022-008607-A	<1	FT-FY23-10102022-008607-B	<1
WS- 008608	2/14/2022	2/14/2023	Basement	Food Prep Sink	In kitchen	Right	WF-02142022-008608	10/25/2022	FT-FY23-10102022-008608-A	<1	FT-FY23-10102022-008608-B	<1