



GARFIELD ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	GARFIELD ELEMENTARY SCHOOL	WS- 004519	8/8/2016	Basement	Cooler	In cafeteria adjacent to entry door	FT-72016-004519-A	< 1	FT-72016-004519-B	< 1
2	GARFIELD ELEMENTARY SCHOOL	WS- 004520	8/8/2016	Basement	Cooler	In cafeteria adjacent to kitchen	FT-72016-004520-A	< 1	FT-72016-004520-B	< 1
3	GARFIELD ELEMENTARY SCHOOL	WS- 004521	8/8/2016	1	Cooler	In hallway adjacent to main office 101	FT-72016-004521-A	< 1	FT-72016-004521-B	< 1
4	GARFIELD ELEMENTARY SCHOOL	WS- 004522	8/8/2016	2	Cooler	In hallway adjacent to staff lounge 210	FT-72016-004522-A	< 1	FT-72016-004522-B	< 1
5	GARFIELD ELEMENTARY SCHOOL	WS- 004523	8/8/2016	2	Cooler	In hallway across from stairwell 4	FT-72016-004523-A	1.3	FT-72016-004523-B	< 1
6	GARFIELD ELEMENTARY SCHOOL	WS- 004524	8/8/2016	1	Cooler	In hallway adjacent to room 109	FT-72016-004524-A	< 1	FT-72016-004524-B	< 1
7	GARFIELD ELEMENTARY SCHOOL	WS- 004525	8/8/2016	1	Cooler	In hallway adjacent to ECE boys' room	FT-72016-004525-A	1.4	FT-72016-004525-B	< 1
8	GARFIELD ELEMENTARY SCHOOL	WS- 004526	8/8/2016	2	Cooler	In hallway adjacent to room 201	FT-72016-004526-A	< 1	FT-72016-004526-B	< 1
9	GARFIELD ELEMENTARY SCHOOL	WS- 004527	8/8/2016	2	Cooler	In hallway adjacent to room 203	FT-72016-004527-A	< 1	FT-72016-004527-B	< 1
10	GARFIELD ELEMENTARY SCHOOL	WS- 008607	8/8/2016	Basement	Food Prep Sink	In kitchen	Left FT-72016-008607-A	< 1	FT-72016-008607-B	< 1
11	GARFIELD ELEMENTARY SCHOOL	WS- 008608	8/8/2016	Basement	Food Prep Sink	In kitchen	Right FT-72016-008608-A	< 1	FT-72016-008608-B	< 1
12	GARFIELD ELEMENTARY SCHOOL	WS- 008610	8/8/2016	1	Cooler	In hallway adjacent to room 104	FT-72016-008610-A	< 1	FT-72016-008610-B	< 1
13	GARFIELD ELEMENTARY SCHOOL	WS- 008611	8/8/2016	1	Cooler	In health suite 107	Left FT-72016-008611-A	< 1	FT-72016-008611-B	< 1
14	GARFIELD ELEMENTARY SCHOOL	WS- 008614	8/8/2016	1	Cooler	In classroom 110	FT-72016-008614-A	< 1	FT-72016-008614-B	< 1
15	GARFIELD ELEMENTARY SCHOOL	WS- 008615	8/8/2016	1	Cooler	In classroom 111	FT-72016-008615-A	< 1	FT-72016-008615-B	< 1