



# GARFIELD LEAD WATER TEST RESULTS

May 24th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-004518	Utility	Basement	Boiler room	WT-042916-4535- A	1.8	WT-042916-4535- B	1.8				
2 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-004519	Cooler	Basement	Cafeteria adjacent to entrance	WT-042916-4536- A	< 1	WT-042916-4536- B	< 1				
3 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-004520	Cooler	Basement	Cafeteria opposite entrance	WT-042916-4537- A	3.4	WT-042916-4537- B	1				
4 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-004521	Cooler	1	Adjacent to main office 101	WT-042916-4538- A	< 1	WT-042916-4538- B	< 1				
5 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-004522	Cooler	2	2nd floor hallway adjacent to teachers lounge	WT-042916-4539- A	< 1	WT-042916-4539- B	< 1				
6 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-004523	Cooler	2	2nd floor across from Stairs	WT-042916-4540- A	< 1	WT-042916-4540- B	< 1				
7 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-004524	Cooler	1	First floor hallway adjacent to office 109	WT-042916-4541- A	< 1	WT-042916-4541- B	2.1				
8 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-004525	Cooler	1	First floor hallway adjacent to ECE boys room	WT-042916-4542- A	< 1	WT-042916-4542- B	< 1				
9 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-004526	Cooler	2	2nd floor hallway adjacent room 201	WT-042916-4543- A	< 1	WT-042916-4543- B	< 1				
10 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-004527	Cooler	2	2nd floor adjacent to floor 203	WT-042916-4544- A	< 1	WT-042916-4544- B	< 1				
11 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-008606	Classroom	Basement	In art room	WT-042916-8623- A	2	WT-042916-8623- B	1.4				
12 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-008607	Kitchen	Basement	In kitchen	WT-042916-8624- A	< 1	WT-042916-8624- B	1.1				
13 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-008608	Kitchen	Basement	In kitchen	WT-042916-8625- A	1.1	WT-042916-8625- B	< 1				
14 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-008609	Kitchen	Basement	In kitchen spray nozzle	WT-042916-8626- A	160	WT-042916-8626- B	17.3	Filter will be installed and then retested			
15 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-008610	Cooler	1	In hallway adjacent to room 104	WT-042916-8627- A	1.2	WT-042916-8627- B	< 1				
16 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-008611	Cooler	1	In health suit room 107	WT-042916-8628- A	< 1	WT-042916-8628- B	< 1				
17 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-008612	Classroom	1	In health suit room 107	WT-042916-8629- A	< 1	WT-042916-8629- B	1.3				
18 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-008613	Break Room	1	In room 109	WT-042916-8630- A	1.9	WT-042916-8630- B	2.6				
19 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-008614	Cooler	1	In classroom 110	WT-042916-8631- A	1.6	WT-042916-8631- B	< 1				
20 GARFIELD ELEMENTARY SCHOOL	5/11/2016	WS-008615	Cooler	1	In classroom 111	WT-042916-8632- A	< 1	WT-042916-8632- B	< 1				

**Footnotes:**

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.