



GARFIELD ES LEAD WATER TEST RESULTS



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004521	6/8/2017	6/8/2018	1	Cooler	In hallway adjacent to main office 101	WF-62017-004521	10/23/2017	FT-FY18-102017-004521-A	< 1	FT-FY18-102017-004521-B	< 1
WS-004522	6/8/2017	6/8/2018	2	Cooler	In hallway adjacent to staff lounge 210	WF-62017-004522	10/23/2017	FT-FY18-102017-004522-A	< 1	FT-FY18-102017-004522-B	< 1
WS-008610	6/8/2017	6/8/2018	1	Cooler	In hallway adjacent to room 104	WF-62017-008610	10/23/2017	FT-FY18-102017-008610-A	< 1	FT-FY18-102017-008610-B	< 1
WS-008613	6/8/2017	6/8/2018	1	Break Room	In break room 109	WF-62017-008613	10/23/2017	FT-FY18-102017-008613-A	< 1	FT-FY18-102017-008613-B	< 1
WS-008614	6/8/2017	6/8/2018	1	Cooler	In classroom 110	WF-62017-008614	10/23/2017	FT-FY18-102017-008614-A	< 1	FT-FY18-102017-008614-B	< 1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS-008607	Basement	Food Prep Sink	In kitchen Left	10/23/2017	FT-FY18-102017-008607-A	< 1	FT-FY18-102017-008607-B	< 1			
WS-008608	Basement	Food Prep Sink	In kitchen Right	10/23/2017	FT-FY18-102017-008608-A	< 1	FT-FY18-102017-008608-B	< 1			