



GARNETT-PATTERSON MS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	GARNETT-PATTERSON MIDDLE	WS- 004815	8/24/2016	Basement	Kitchen	In kitchen first clockwise from entry door	FT-72016-004815-A	< 1	FT-72016-004815-B	< 1
2	GARNETT-PATTERSON MIDDLE	WS- 004818	8/24/2016	1	Cooler	In hallway adjacent to room 142	FT-82016-004818-A	< 1	FT-82016-004818-B	< 1
3	GARNETT-PATTERSON MIDDLE	WS- 004819	8/24/2016	1	Cooler	In hallway adjacent to room 112	FT-82016-004819-A	< 1	FT-82016-004819-B	< 1
4	GARNETT-PATTERSON MIDDLE	WS- 004820	8/24/2016	1	Cooler	In hallway adjacent to room 122	FT-82016-004820-A	< 1	FT-82016-004820-B	< 1
5	GARNETT-PATTERSON MIDDLE	WS- 004821	8/24/2016	2	Cooler	In hallway adjacent to room 209B	FT-82016-004821-A	< 1	FT-82016-004821-B	< 1
6	GARNETT-PATTERSON MIDDLE	WS- 004822	8/24/2016	2	Cooler	In hallway adjacent to room 217	FT-82016-004822-A	< 1	FT-82016-004822-B	< 1
7	GARNETT-PATTERSON MIDDLE	WS- 004823	8/24/2016	3	Cooler	In hallway adjacent to room 312	FT-72016-004823-A	< 1	FT-72016-004823-B	< 1
8	GARNETT-PATTERSON MIDDLE	WS- 004824	8/24/2016	3	Cooler	In hallway adjacent to room 305	FT-82016-004824-A	< 1	FT-82016-004824-B	< 1
9	GARNETT-PATTERSON MIDDLE	WS- 009160	8/24/2016	2	Health Suite	In health suite 216	FT-82016-009160-A	< 1	FT-82016-009160-B	< 1