



# Garrison Elementary School Lead in Water Test Results



## FY21 Filter Test

| Less than 5ppb - Devices requiring no remediation |                       |                        |       |                |   |                     |               |                         |                                  |                         |                                  |
|---|-----------------------|------------------------|-------|----------------|---|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID   | Filter Installed Date | Filter Expiration Date | Floor | Device Type    | Device Location                                 | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
| WS- 002847  | 6/2/2020              | 6/2/2021               | 2     | Break Room     | In staff lounge 248                             | WF-06022020-002847  | 1/28/2021     | FT-FY21-012021-002847-A | <1                               | FT-FY21-012021-002847-B | <1                               |
| WS- 002849  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 249                                | WF-06022020-002849  | 1/28/2021     | FT-FY21-012021-002849-A | 1.5                              | FT-FY21-012021-002849-B | <1                               |
| WS- 002850  | 6/2/2020              | 6/2/2021               | 2     | Cooler         | In hallway adjacent to staff restroom High Left | WF-06022020-002850  | 1/28/2021     | FT-FY21-012021-002850-A | <1                               | FT-FY21-012021-002850-B | <1                               |
| WS- 002851  | 6/2/2020              | 6/2/2021               | 2     | Cooler         | In hallway adjacent to staff restroom Low Right | WF-06022020-002851  | 1/28/2021     | FT-FY21-012021-002851-A | <1                               | FT-FY21-012021-002851-B | <1                               |
| WS- 002853  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 246                                | WF-06022020-002853  | 1/28/2021     | FT-FY21-012021-002853-A | 2.7                              | FT-FY21-012021-002853-B | <1                               |
| WS- 002855  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 246                                | WF-06022020-002855  | 1/28/2021     | FT-FY21-012021-002855-A | 2.5                              | FT-FY21-012021-002855-B | <1                               |
| WS- 002857  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 247                                | WF-06022020-002857  | 1/28/2021     | FT-FY21-012021-002857-A | 3.6                              | FT-FY21-012021-002857-B | <1                               |
| WS- 002859  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 244                                | WF-06022020-002859  | 1/28/2021     | FT-FY21-012021-002859-A | 1.3                              | FT-FY21-012021-002859-B | <1                               |
| WS- 002861  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 241                                | WF-06022020-002861  | 1/28/2021     | FT-FY21-012021-002861-A | <1                               | FT-FY21-012021-002861-B | <1                               |
| WS- 002864  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 223                                | WF-06022020-002864  | 1/28/2021     | FT-FY21-012021-002864-A | 1.8                              | FT-FY21-012021-002864-B | <1                               |
| WS- 002866  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 225                                | WF-06022020-002866  | 1/28/2021     | FT-FY21-012021-002866-A | <1                               | FT-FY21-012021-002866-B | <1                               |
| WS- 002868  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 227                                | WF-06022020-002868  | 1/28/2021     | FT-FY21-012021-002868-A | <1                               | FT-FY21-012021-002868-B | <1                               |
| WS- 002870  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 226                                | WF-06022020-002870  | 1/28/2021     | FT-FY21-012021-002870-A | <1                               | FT-FY21-012021-002870-B | <1                               |
| WS- 002872  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 228                                | WF-06022020-002872  | 1/28/2021     | FT-FY21-012021-002872-A | 1.1                              | FT-FY21-012021-002872-B | <1                               |
| WS- 002874  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 230                                | WF-06022020-002874  | 1/28/2021     | FT-FY21-012021-002874-A | <1                               | FT-FY21-012021-002874-B | <1                               |
| WS- 002876  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 229                                | WF-06022020-002876  | 1/28/2021     | FT-FY21-012021-002876-A | <1                               | FT-FY21-012021-002876-B | <1                               |
| WS- 002877  | 6/2/2020              | 6/2/2021               | 1     | Health Suite   | In health suite 162B                            | WF-06022020-002877  | 1/28/2021     | FT-FY21-012021-002877-A | <1                               | FT-FY21-012021-002877-B | <1                               |
| WS- 002878  | 6/2/2020              | 6/2/2021               | 1     | Cooler         | In hallway adjacent to health suite 162A        | WF-06022020-002878  | 1/28/2021     | FT-FY21-012021-002878-A | <1                               | FT-FY21-012021-002878-B | <1                               |
| WS- 002879  | 9/9/2020              | 9/9/2021               | 1     | Combo Faucet   | In classroom 145                                | WF-09092020-002879  | 1/28/2021     | FT-FY21-012021-002879-A | 1.7                              | FT-FY21-012021-002879-B | <1                               |
| WS- 002880  | 6/2/2020              | 6/2/2021               | 1     | Combo Fountain | In classroom 145                                | WF-06022020-002880  | 1/28/2021     | FT-FY21-012021-002880-A | 2.3                              | FT-FY21-012021-002880-B | <1                               |
| WS- 002881  | 9/9/2020              | 9/9/2021               | 1     | Combo Faucet   | In classroom 160                                | WF-09092020-002881  | 1/28/2021     | FT-FY21-012021-002881-A | <1                               | FT-FY21-012021-002881-B | <1                               |
| WS- 002882  | 6/2/2020              | 6/2/2021               | 1     | Combo Fountain | In classroom 160                                | WF-06022020-002882  | 1/28/2021     | FT-FY21-012021-002882-A | <1                               | FT-FY21-012021-002882-B | <1                               |
| WS- 002883  | 9/9/2020              | 9/9/2021               | 1     | Combo Faucet   | In classroom 143                                | WF-09092020-002883  | 1/28/2021     | FT-FY21-012021-002883-A | 1.5                              | FT-FY21-012021-002883-B | <1                               |
| WS- 002884  | 6/2/2020              | 6/2/2021               | 1     | Combo Fountain | In classroom 143                                | WF-06022020-002884  | 1/28/2021     | FT-FY21-012021-002884-A | 1.4                              | FT-FY21-012021-002884-B | <1                               |
| WS- 002886  | 6/2/2020              | 6/2/2021               | 2     | Combo Fountain | In classroom 243                                | WF-06022020-002886  | 1/28/2021     | FT-FY21-012021-002886-A | 3.5                              | FT-FY21-012021-002886-B | <1                               |
| WS- 002887  | 6/2/2020              | 6/2/2021               | 1     | Break Room     | In parent resource center C105                  | WF-06022020-002887  | 1/28/2021     | FT-FY21-012021-002887-A | <1                               | FT-FY21-012021-002887-B | <1                               |
| WS- 002888  | 6/2/2020              | 6/2/2021               | 1     | Cooler         | In hallway adjacent to stairwell 1 High Left    | WF-06022020-002888  | 1/28/2021     | FT-FY21-012021-002888-A | <1                               | FT-FY21-012021-002888-B | <1                               |
| WS- 002889  | 6/2/2020              | 6/2/2021               | 1     | Cooler         | In hallway adjacent to stairwell 1 Low Right    | WF-06022020-002889  | 1/28/2021     | FT-FY21-012021-002889-A | <1                               | FT-FY21-012021-002889-B | <1                               |
| WS- 002890  | 9/9/2020              | 9/9/2021               | 1     | Combo Faucet   | In classroom 125                                | WF-09092020-002890  | 1/28/2021     | FT-FY21-012021-002890-A | <1                               | FT-FY21-012021-002890-B | <1                               |
| WS- 002891  | 6/2/2020              | 6/2/2021               | 1     | Combo Fountain | In classroom 125                                | WF-06022020-002891  | 1/28/2021     | FT-FY21-012021-002891-A | <1                               | FT-FY21-012021-002891-B | <1                               |
| WS- 002892  | 9/9/2020              | 9/9/2021               | 1     | Combo Faucet   | In classroom 126                                | WF-09092020-002892  | 1/28/2021     | FT-FY21-012021-002892-A | <1                               | FT-FY21-012021-002892-B | <1                               |
| WS- 002893  | 6/2/2020              | 6/2/2021               | 1     | Combo Fountain | In classroom 126                                | WF-06022020-002893  | 1/28/2021     | FT-FY21-012021-002893-A | <1                               | FT-FY21-012021-002893-B | <1                               |
| WS- 002894  | 9/9/2020              | 9/9/2021               | 1     | Combo Faucet   | In classroom 127                                | WF-09092020-002894  | 1/28/2021     | FT-FY21-012021-002894-A | <1                               | FT-FY21-012021-002894-B | <1                               |

|            |          |          |   |                  |  |                    |           |                         |     |                         |    |
|------------|----------|----------|---|------------------|--|--------------------|-----------|-------------------------|-----|-------------------------|----|
| WS- 002895 | 6/2/2020 | 6/2/2021 | 1 | Combo Fountain   | In classroom 127                                 | WF-06022020-002895 | 1/28/2021 | FT-FY21-012021-002895-A | <1  | FT-FY21-012021-002895-B | <1 |
| WS- 002896 | 9/9/2020 | 9/9/2021 | 1 | Combo Faucet     | In classroom 128                                 | WF-09092020-002896 | 1/28/2021 | FT-FY21-012021-002896-A | 1.0 | FT-FY21-012021-002896-B | <1 |
| WS- 002897 | 6/2/2020 | 6/2/2021 | 1 | Combo Fountain   | In classroom 128                                 | WF-06022020-002897 | 1/28/2021 | FT-FY21-012021-002897-A | <1  | FT-FY21-012021-002897-B | <1 |
| WS- 002898 | 9/9/2020 | 9/9/2021 | 1 | Combo Faucet     | In classroom 132                                 | WF-09092020-002898 | 1/28/2021 | FT-FY21-012021-002898-A | <1  | FT-FY21-012021-002898-B | <1 |
| WS- 002899 | 6/2/2020 | 6/2/2021 | 1 | Combo Fountain   | In classroom 132                                 | WF-06022020-002899 | 1/28/2021 | FT-FY21-012021-002899-A | <1  | FT-FY21-012021-002899-B | <1 |
| WS- 002900 | 9/9/2020 | 9/9/2021 | 1 | Combo Faucet     | In classroom 129                                 | WF-09092020-002900 | 1/28/2021 | FT-FY21-012021-002900-A | 1.2 | FT-FY21-012021-002900-B | <1 |
| WS- 002901 | 6/2/2020 | 6/2/2021 | 1 | Combo Fountain   | In classroom 129                                 | WF-06022020-002901 | 1/28/2021 | FT-FY21-012021-002901-A | <1  | FT-FY21-012021-002901-B | <1 |
| WS- 002902 | 6/2/2020 | 6/2/2021 | 1 | Break Room       | In staff lounge 123                              | WF-06022020-002902 | 1/28/2021 | FT-FY21-012021-002902-A | <1  | FT-FY21-012021-002902-B | <1 |
| WS- 002904 | 9/9/2020 | 9/9/2021 | 1 | Classroom Faucet | In classroom 121 first clockwise from entry door | WF-09092020-002904 | 1/28/2021 | FT-FY21-012021-002904-A | <1  | FT-FY21-012021-002904-B | <1 |

### Food Prep Sink

| Less than 5ppb - Devices requiring no remediation |                       |                        |       |                |                 |                     |               |                         |                                  |                         |                                  |
|---|-----------------------|------------------------|-------|----------------|-----------------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID   | Filter Installed Date | Filter Expiration Date | Floor | Device Type    | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
| WS- 002731  | 1/13/2021             | 1/13/2022              | 1     | Food Prep Sink | In kitchen Left | WF-01132021-002731  | 1/28/2021     | FT-FY21-012021-002731-A | <1                               | FT-FY21-012021-002731-B | <1                               |