



Garrison Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002847	4/19/2023	4/19/2024	2	Break Room	In staff lounge 248	WF-04192023-002847	11/7/2023	FT-FY24-10102023-002847-A	<1	FT-FY24-10102023-002847-B	<1
WS- 002849	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 249	WF-04192023-002849	11/7/2023	FT-FY24-10102023-002849-A	<1	FT-FY24-10102023-002849-B	<1
WS- 002850	4/19/2023	4/19/2024	2	Cooler	In hallway adjacent to staff restroom High Left	WF-04192023-002850	11/7/2023	FT-FY24-10102023-002850-A	<1	FT-FY24-10102023-002850-B	<1
WS- 002851	4/19/2023	4/19/2024	2	Cooler	In hallway adjacent to staff restroom Low Right	WF-04192023-002851	11/7/2023	FT-FY24-10102023-002851-A	<1	FT-FY24-10102023-002851-B	<1
WS- 002857	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 247	WF-04192023-002857	11/7/2023	FT-FY24-10102023-002857-A	<1	FT-FY24-10102023-002857-B	<1
WS- 002859	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 244	WF-04192023-002859	11/7/2023	FT-FY24-10102023-002859-A	<1	FT-FY24-10102023-002859-B	<1
WS- 002862	4/19/2023	4/19/2024	2	Cooler	In hallway adjacent to staff restroom	WF-04192023-002862	11/7/2023	FT-FY24-10102023-002862-A	<1	FT-FY24-10102023-002862-B	<1
WS- 002864	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 223	WF-04192023-002864	11/7/2023	FT-FY24-10102023-002864-A	<1	FT-FY24-10102023-002864-B	<1
WS- 002866	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 225	WF-04192023-002866	11/7/2023	FT-FY24-10102023-002866-A	<1	FT-FY24-10102023-002866-B	<1
WS- 002868	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 227	WF-04192023-002868	11/7/2023	FT-FY24-10102023-002868-A	<1	FT-FY24-10102023-002868-B	<1
WS- 002870	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 226	WF-04192023-002870	11/7/2023	FT-FY24-10102023-002870-A	<1	FT-FY24-10102023-002870-B	<1
WS- 002872	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 228	WF-04192023-002872	11/7/2023	FT-FY24-10102023-002872-A	<1	FT-FY24-10102023-002872-B	<1
WS- 002874	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 230	WF-04192023-002874	11/7/2023	FT-FY24-10102023-002874-A	<1	FT-FY24-10102023-002874-B	<1
WS- 002876	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 229	WF-04192023-002876	11/7/2023	FT-FY24-10102023-002876-A	<1	FT-FY24-10102023-002876-B	<1
WS- 002877	4/19/2023	4/19/2024	1	Health Suite	In health suite 162B	WF-04192023-002877	11/7/2023	FT-FY24-10102023-002877-A	<1	FT-FY24-10102023-002877-B	<1
WS- 002878	4/19/2023	4/19/2024	1	Cooler	In hallway adjacent to health suite 162A	WF-04192023-002878	11/7/2023	FT-FY24-10102023-002878-A	<1	FT-FY24-10102023-002878-B	<1
WS- 002879	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 145	WF-08152023-002879	11/7/2023	FT-FY24-10102023-002879-A	<1	FT-FY24-10102023-002879-B	<1
WS- 002880	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 145	WF-04192023-002880	11/7/2023	FT-FY24-10102023-002880-A	<1	FT-FY24-10102023-002880-B	<1
WS- 002881	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 160	WF-08152023-002881	11/7/2023	FT-FY24-10102023-002881-A	<1	FT-FY24-10102023-002881-B	<1
WS- 002882	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 160	WF-04192023-002882	11/7/2023	FT-FY24-10102023-002882-A	<1	FT-FY24-10102023-002882-B	<1
WS- 002883	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 143	WF-08152023-002883	11/7/2023	FT-FY24-10102023-002883-A	<1	FT-FY24-10102023-002883-B	<1
WS- 002884	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 143	WF-04192023-002884	11/7/2023	FT-FY24-10102023-002884-A	<1	FT-FY24-10102023-002884-B	<1
WS- 002886	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 243	WF-04192023-002886	11/7/2023	FT-FY24-10102023-002886-A	<1	FT-FY24-10102023-002886-B	<1
WS- 002887	4/19/2023	4/19/2024	1	Break Room	In parent resource center C105	WF-04192023-002887	11/7/2023	FT-FY24-10102023-002887-A	<1	FT-FY24-10102023-002887-B	<1
WS- 002888	4/19/2023	4/19/2024	1	Cooler	In hallway adjacent to stairwell 1 High Left	WF-04192023-002888	11/7/2023	FT-FY24-10102023-002888-A	<1	FT-FY24-10102023-002888-B	<1
WS- 002889	4/19/2023	4/19/2024	1	Cooler	In hallway adjacent to stairwell 1 Low Right	WF-04192023-002889	11/7/2023	FT-FY24-10102023-002889-A	<1	FT-FY24-10102023-002889-B	<1
WS- 002890	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 125	WF-08152023-002890	11/7/2023	FT-FY24-10102023-002890-A	<1	FT-FY24-10102023-002890-B	<1
WS- 002891	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 125	WF-04192023-002891	11/7/2023	FT-FY24-10102023-002891-A	<1	FT-FY24-10102023-002891-B	<1
WS- 002892	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 126	WF-08152023-002892	11/7/2023	FT-FY24-10102023-002892-A	<1	FT-FY24-10102023-002892-B	<1
WS- 002894	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 127	WF-08152023-002894	11/7/2023	FT-FY24-10102023-002894-A	<1	FT-FY24-10102023-002894-B	<1
WS- 002895	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 127	WF-04192023-002895	11/7/2023	FT-FY24-10102023-002895-A	<1	FT-FY24-10102023-002895-B	<1
WS- 002896	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 128	WF-08152023-002896	11/7/2023	FT-FY24-10102023-002896-A	<1	FT-FY24-10102023-002896-B	<1
WS- 002897	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 128	WF-04192023-002897	11/7/2023	FT-FY24-10102023-002897-A	<1	FT-FY24-10102023-002897-B	<1
WS- 002898	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 132	WF-08152023-002898	11/7/2023	FT-FY24-10102023-002898-A	<1	FT-FY24-10102023-002898-B	<1

WS- 002899	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 132	WF-04192023-002899	11/7/2023	FT-FY24-10102023-002899-A	<1	FT-FY24-10102023-002899-B	<1	
WS- 002900	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 129	WF-08152023-002900	11/7/2023	FT-FY24-10102023-002900-A	<1	FT-FY24-10102023-002900-B	<1	
WS- 002901	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 129	WF-04192023-002901	11/7/2023	FT-FY24-10102023-002901-A	<1	FT-FY24-10102023-002901-B	<1	
WS- 002904	8/15/2023	8/15/2024	1	Classroom Faucet	In classroom 121 first clockwise from entry door	WF-08152023-002904	11/7/2023	FT-FY24-10102023-002904-A	<1	FT-FY24-10102023-002904-B	<1	
WS- 002906	4/19/2023	4/19/2024	1	Cooler	In multipurpose room	High Left	WF-04192023-002906	11/7/2023	FT-FY24-10102023-002906-A	<1	FT-FY24-10102023-002906-B	<1
WS- 002907	4/19/2023	4/19/2024	1	Cooler	In multipurpose room	Low Right	WF-04192023-002907	11/7/2023	FT-FY24-10102023-002907-A	<1	FT-FY24-10102023-002907-B	<1
WS- 002908	4/19/2023	4/19/2024	1	Bottle Filler	In multipurpose room		WF-04192023-002908	11/7/2023	FT-FY24-10102023-002908-A	<1	FT-FY24-10102023-002908-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002731	12/21/2022	12/21/2023	1	Food Prep Sink	In kitchen	Left	WF-12212022-002731	11/7/2023	FT-FY24-10102023-002731-A	<1	FT-FY24-10102023-002731-B	<1