



Garrison ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002847	4/1/2025	4/1/2026	2	Break Room	In staff lounge 248	WF-04012025-002847	10/28/2025	FT-FY26-09302025-002847-A	<2	FT-FY26-09302025-002847-B	<2	
WS- 002849	4/1/2025	4/1/2026	2	Combo Fountain	In classroom 249	WF-04012025-002849	10/28/2025	FT-FY26-09302025-002849-A	<2	FT-FY26-09302025-002849-B	<2	
WS- 002850	4/1/2025	4/1/2026	2	Cooler	In hallway adjacent to staff restroom	High Left	WF-04012025-002850	10/28/2025	FT-FY26-09302025-002850-A	<2	FT-FY26-09302025-002850-B	<2
WS- 002851	4/1/2025	4/1/2026	2	Cooler	In hallway adjacent to staff restroom	Low Right	WF-04012025-002851	10/28/2025	FT-FY26-09302025-002851-A	<2	FT-FY26-09302025-002851-B	<2
WS- 002857	4/1/2025	4/1/2026	2	Combo Fountain	In classroom 247	WF-04012025-002857	10/28/2025	FT-FY26-09302025-002857-A	<2	FT-FY26-09302025-002857-B	<2	
WS- 002859	4/1/2025	4/1/2026	2	Combo Fountain	In classroom 244	WF-04012025-002859	10/28/2025	FT-FY26-09302025-002859-A	<2	FT-FY26-09302025-002859-B	<2	
WS- 002861	4/1/2025	4/1/2026	2	Combo Fountain	In classroom 241	WF-04012025-002861	10/28/2025	FT-FY26-09302025-002861-A	<2	FT-FY26-09302025-002861-B	<2	
WS- 002862	4/1/2025	4/1/2026	2	Cooler	In hallway adjacent to staff restroom		WF-04012025-002862	10/28/2025	FT-FY26-09302025-002862-A	<2	FT-FY26-09302025-002862-B	<2
WS- 002864	4/1/2025	4/1/2026	2	Combo Fountain	In classroom 223	WF-04012025-002864	10/28/2025	FT-FY26-09302025-002864-A	<2	FT-FY26-09302025-002864-B	<2	
WS- 002866	4/1/2025	4/1/2026	2	Combo Fountain	In classroom 225	WF-04012025-002866	10/28/2025	FT-FY26-09302025-002866-A	<2	FT-FY26-09302025-002866-B	<2	
WS- 002868	4/1/2025	4/1/2026	2	Combo Fountain	In classroom 227	WF-04012025-002868	10/28/2025	FT-FY26-09302025-002868-A	<2	FT-FY26-09302025-002868-B	<2	
WS- 002870	4/1/2025	4/1/2026	2	Combo Fountain	In classroom 226	WF-04012025-002870	10/28/2025	FT-FY26-09302025-002870-A	<2	FT-FY26-09302025-002870-B	<2	
WS- 002872	4/1/2025	4/1/2026	2	Combo Fountain	In classroom 228	WF-04012025-002872	10/28/2025	FT-FY26-09302025-002872-A	<2	FT-FY26-09302025-002872-B	<2	
WS- 002874	4/1/2025	4/1/2026	2	Combo Fountain	In classroom 230	WF-04012025-002874	10/28/2025	FT-FY26-09302025-002874-A	<2	FT-FY26-09302025-002874-B	<2	
WS- 002876	4/1/2025	4/1/2026	2	Combo Fountain	In classroom 229	WF-04012025-002876	10/28/2025	FT-FY26-09302025-002876-A	<2	FT-FY26-09302025-002876-B	<2	
WS- 002877	4/1/2025	4/1/2026	1	Health Suite	In health suite 162B	WF-04012025-002877	10/28/2025	FT-FY26-09302025-002877-A	<2	FT-FY26-09302025-002877-B	<2	
WS- 002878	4/1/2025	4/1/2026	1	Cooler	In hallway adjacent to health suite 162A		WF-04012025-002878	10/28/2025	FT-FY26-09302025-002878-A	<2	FT-FY26-09302025-002878-B	<2
WS- 002879	8/5/2025	8/5/2026	1	Combo Faucet	In classroom 145	WF-08052025-002879	10/28/2025	FT-FY26-09302025-002879-A	<2	FT-FY26-09302025-002879-B	<2	
WS- 002880	4/1/2025	4/1/2026	1	Combo Fountain	In classroom 145	WF-04012025-002880	10/28/2025	FT-FY26-09302025-002880-A	<2	FT-FY26-09302025-002880-B	<2	
WS- 002881	8/5/2025	8/5/2026	1	Combo Faucet	In classroom 160	WF-08052025-002881	10/28/2025	FT-FY26-09302025-002881-A	<2	FT-FY26-09302025-002881-B	<2	
WS- 002882	4/1/2025	4/1/2026	1	Combo Fountain	In classroom 160	WF-04012025-002882	10/28/2025	FT-FY26-09302025-002882-A	<2	FT-FY26-09302025-002882-B	<2	
WS- 002883	8/5/2025	8/5/2026	1	Combo Faucet	In classroom 143	WF-08052025-002883	10/28/2025	FT-FY26-09302025-002883-A	<2	FT-FY26-09302025-002883-B	<2	
WS- 002884	4/1/2025	4/1/2026	1	Combo Fountain	In classroom 143	WF-04012025-002884	10/28/2025	FT-FY26-09302025-002884-A	<2	FT-FY26-09302025-002884-B	<2	
WS- 002886	4/1/2025	4/1/2026	2	Combo Fountain	In classroom 243	WF-04012025-002886	10/28/2025	FT-FY26-09302025-002886-A	<2	FT-FY26-09302025-002886-B	<2	
WS- 002887	4/1/2025	4/1/2026	1	Break Room	In parent resource center C105	WF-04012025-002887	10/28/2025	FT-FY26-09302025-002887-A	<2	FT-FY26-09302025-002887-B	<2	
WS- 002888	4/1/2025	4/1/2026	1	Cooler	In hallway adjacent to stairwell 1	High Left	WF-04012025-002888	10/28/2025	FT-FY26-09302025-002888-A	<2	FT-FY26-09302025-002888-B	<2
WS- 002889	4/1/2025	4/1/2026	1	Cooler	In hallway adjacent to stairwell 1	Low Right	WF-04012025-002889	10/28/2025	FT-FY26-09302025-002889-A	<2	FT-FY26-09302025-002889-B	<2
WS- 002890	8/5/2025	8/5/2026	1	Combo Faucet	In classroom 125	WF-08052025-002890	10/28/2025	FT-FY26-09302025-002890-A	<2	FT-FY26-09302025-002890-B	<2	
WS- 002891	4/1/2025	4/1/2026	1	Combo Fountain	In classroom 125	WF-04012025-002891	10/28/2025	FT-FY26-09302025-002891-A	<2	FT-FY26-09302025-002891-B	<2	
WS- 002892	8/5/2025	8/5/2026	1	Combo Faucet	In classroom 126	WF-08052025-002892	10/28/2025	FT-FY26-09302025-002892-A	<2	FT-FY26-09302025-002892-B	<2	
WS- 002894	8/5/2025	8/5/2026	1	Combo Faucet	In classroom 127	WF-08052025-002894	10/28/2025	FT-FY26-09302025-002894-A	<2	FT-FY26-09302025-002894-B	<2	
WS- 002895	4/1/2025	4/1/2026	1	Combo Fountain	In classroom 127	WF-04012025-002895	10/28/2025	FT-FY26-09302025-002895-A	<2	FT-FY26-09302025-002895-B	<2	
WS- 002896	8/5/2025	8/5/2026	1	Combo Faucet	In classroom 128	WF-08052025-002896	10/28/2025	FT-FY26-09302025-002896-A	<2	FT-FY26-09302025-002896-B	<2	
WS- 002897	4/1/2025	4/1/2026	1	Combo Fountain	In classroom 128	WF-04012025-002897	10/28/2025	FT-FY26-09302025-002897-A	<2	FT-FY26-09302025-002897-B	<2	

WS-002898	8/5/2025	8/5/2026	1	Combo Faucet	In classroom 132		WF-08052025-002898	10/28/2025	FT-FY26-09302025-002898-A	<2	FT-FY26-09302025-002898-B	<2
WS-002899	4/1/2025	4/1/2026	1	Combo Fountain	In classroom 132		WF-04012025-002899	10/28/2025	FT-FY26-09302025-002899-A	<2	FT-FY26-09302025-002899-B	<2
WS-002900	8/5/2025	8/5/2026	1	Combo Faucet	In classroom 129		WF-08052025-002900	10/28/2025	FT-FY26-09302025-002900-A	<2	FT-FY26-09302025-002900-B	<2
WS-002901	4/1/2025	4/1/2026	1	Combo Fountain	In classroom 129		WF-04012025-002901	10/28/2025	FT-FY26-09302025-002901-A	<2	FT-FY26-09302025-002901-B	<2
WS-002902	4/1/2025	4/1/2026	1	Break Room	In staff lounge 123		WF-04012025-002902	10/28/2025	FT-FY26-09302025-002902-A	<2	FT-FY26-09302025-002902-B	<2
WS-002904	8/5/2025	8/5/2026	1	Classroom Faucet	In classroom 121 first clockwise from entry door		WF-08052025-002904	10/28/2025	FT-FY26-09302025-002904-A	<2	FT-FY26-09302025-002904-B	<2
WS-002906	4/1/2025	4/1/2026	1	Cooler	In multipurpose room	High Left	WF-04012025-002906	10/28/2025	FT-FY26-09302025-002906-A	<2	FT-FY26-09302025-002906-B	<2
WS-002907	4/1/2025	4/1/2026	1	Cooler	In multipurpose room	Low Right	WF-04012025-002907	10/28/2025	FT-FY26-09302025-002907-A	<2	FT-FY26-09302025-002907-B	<2
WS-002908	4/1/2025	4/1/2026	1	Bottle Filler	In multipurpose room		WF-04012025-002908	10/28/2025	FT-FY26-09302025-002908-A	<2	FT-FY26-09302025-002908-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002731	9/17/2025	9/17/2026	1	Food Prep Sink	In kitchen	Left	WF-09172025-002731	10/28/2025	FT-FY26-09302025-002731-A	<2	FT-FY26-09302025-002731-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.