



GARRISON ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	GARRISON ELEMENTARY SCHOOL	WS- 002728	8/19/2016	1	Cooler	In hallway adjacent to room 122	FT-72016-002728-A	< 1	FT-72016-002728-B	< 1
2	GARRISON ELEMENTARY SCHOOL	WS- 002729	8/19/2016	1	Cooler	In hallway adjacent to custodian supply room	FT-72016-002729-A	< 1	FT-72016-002729-B	< 1
3	GARRISON ELEMENTARY SCHOOL	WS- 002730	8/19/2016	1	Cooler	In cafeteria adjacent to kitchen entrance	FT-72016-002730-A	< 1	FT-72016-002730-B	< 1
4	GARRISON ELEMENTARY SCHOOL	WS- 002732	8/19/2016	1	Food Prep Sink	In kitchen Right	FT-72016-002732-A	< 1	FT-72016-002732-B	< 1
5	GARRISON ELEMENTARY SCHOOL	WS- 002733	8/19/2016	1	Cooler	In hallway adjacent to principal's office	FT-72016-002733-A	< 1	FT-72016-002733-B	< 1
6	GARRISON ELEMENTARY SCHOOL	WS- 002734	8/19/2016	1	Cooler	In health suite	FT-72016-002734-A	< 1	FT-72016-002734-B	< 1
7	GARRISON ELEMENTARY SCHOOL	WS- 002735	8/19/2016	1	Health Suite	In health suite	FT-72016-002735-A	< 1	FT-72016-002735-B	< 1
8	GARRISON ELEMENTARY SCHOOL	WS- 002736	8/19/2016	1	Cooler	In classroom 110	FT-72016-002736-A	< 1	FT-72016-002736-B	< 1
9	GARRISON ELEMENTARY SCHOOL	WS- 002737	8/19/2016	1	Cooler	In classroom 109	FT-72016-002737-A	< 1	FT-72016-002737-B	< 1
10	GARRISON ELEMENTARY SCHOOL	WS- 002738	8/19/2016	1	Cooler	In hallway adjacent to staff restroom	FT-72016-002738-A	< 1	FT-72016-002738-B	< 1
11	GARRISON ELEMENTARY SCHOOL	WS- 002745	8/19/2016	2	Cooler	In hallway adjacent to teachers' restroom	FT-72016-002745-A	< 1	FT-72016-002745-B	< 1
12	GARRISON ELEMENTARY SCHOOL	WS- 002747	8/19/2016	2	Cooler	In hallway adjacent to room 201	FT-72016-002747-A	< 1	FT-72016-002747-B	< 1
13	GARRISON ELEMENTARY SCHOOL	WS- 002749	8/19/2016	2	Cooler	In hallway adjacent to east wing trash chute	FT-72016-002749-A	< 1	FT-72016-002749-B	< 1
14	GARRISON ELEMENTARY SCHOOL	WS- 002750	8/19/2016	2	Cooler	In hallway adjacent to room 217	FT-72016-002750-A	< 1	FT-72016-002750-B	< 1