



Garrison ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002847	6/22/2018	6/22/2019	2	Break Room	In staff lounge 248	WF-06222018-002847	10/27/2018	FT-FY19-102018-002847-A	< 1	FT-FY19-102018-002847-B	< 1	
WS- 002849	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 249	WF-06222018-002849	10/27/2018	FT-FY19-102018-002849-A	< 1	FT-FY19-102018-002849-B	< 1	
WS- 002850	6/22/2018	6/22/2019	2	Cooler	In hallway adjacent to staff restroom	High Left	WF-06222018-002850	10/27/2018	FT-FY19-102018-002850-A	< 1	FT-FY19-102018-002850-B	< 1
WS- 002851	6/22/2018	6/22/2019	2	Cooler	In hallway adjacent to staff restroom	Low Right	WF-06222018-002851	10/27/2018	FT-FY19-102018-002851-A	< 1	FT-FY19-102018-002851-B	< 1
WS- 002853	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 246	WF-06222018-002853	10/27/2018	FT-FY19-102018-002853-A	< 1	FT-FY19-102018-002853-B	< 1	
WS- 002855	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 246	WF-06222018-002855	10/27/2018	FT-FY19-102018-002855-A	< 1	FT-FY19-102018-002855-B	< 1	
WS- 002857	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 247	WF-06222018-002857	10/27/2018	FT-FY19-102018-002857-A	< 1	FT-FY19-102018-002857-B	< 1	
WS- 002859	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 244	WF-06222018-002859	10/27/2018	FT-FY19-102018-002859-A	< 1	FT-FY19-102018-002859-B	< 1	
WS- 002861	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 241	WF-06222018-002861	10/27/2018	FT-FY19-102018-002861-A	< 1	FT-FY19-102018-002861-B	< 1	
WS- 002862	6/22/2018	6/22/2019	2	Cooler	In hallway adjacent to staff restroom	WF-06222018-002862	10/27/2018	FT-FY19-102018-002862-A	< 1	FT-FY19-102018-002862-B	< 1	
WS- 002864	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 223	WF-06222018-002864	10/27/2018	FT-FY19-102018-002864-A	< 1	FT-FY19-102018-002864-B	< 1	
WS- 002866	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 225	WF-06222018-002866	10/27/2018	FT-FY19-102018-002866-A	< 1	FT-FY19-102018-002866-B	< 1	
WS- 002868	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 227	WF-06222018-002868	10/27/2018	FT-FY19-102018-002868-A	< 1	FT-FY19-102018-002868-B	< 1	
WS- 002870	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 226	WF-06222018-002870	10/27/2018	FT-FY19-102018-002870-A	< 1	FT-FY19-102018-002870-B	< 1	
WS- 002872	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 228	WF-06222018-002872	10/27/2018	FT-FY19-102018-002872-A	< 1	FT-FY19-102018-002872-B	< 1	
WS- 002874	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 230	WF-06222018-002874	10/27/2018	FT-FY19-102018-002874-A	< 1	FT-FY19-102018-002874-B	< 1	
WS- 002876	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 229	WF-06222018-002876	10/27/2018	FT-FY19-102018-002876-A	< 1	FT-FY19-102018-002876-B	< 1	
WS- 002877	6/22/2018	6/22/2019	1	Health Suite	In health suite 162B	WF-06222018-002877	10/27/2018	FT-FY19-102018-002877-A	< 1	FT-FY19-102018-002877-B	< 1	
WS- 002878	6/22/2018	6/22/2019	1	Cooler	In hallway adjacent to health suite 162A	WF-06222018-002878	10/27/2018	FT-FY19-102018-002878-A	< 1	FT-FY19-102018-002878-B	< 1	
WS- 002879	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 145	WF-09242018-002879	10/27/2018	FT-FY19-102018-002879-A	< 1	FT-FY19-102018-002879-B	< 1	
WS- 002880	6/22/2018	6/22/2019	1	Combo Fountain	In classroom 145	WF-06222018-002880	10/27/2018	FT-FY19-102018-002880-A	< 1	FT-FY19-102018-002880-B	< 1	
WS- 002881	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 160	WF-09242018-002881	10/27/2018	FT-FY19-102018-002881-A	< 1	FT-FY19-102018-002881-B	< 1	
WS- 002882	6/22/2018	6/22/2019	1	Combo Fountain	In classroom 160	WF-06222018-002882	10/27/2018	FT-FY19-102018-002882-A	< 1	FT-FY19-102018-002882-B	< 1	
WS- 002883	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 143	WF-09242018-002883	10/27/2018	FT-FY19-102018-002883-A	< 1	FT-FY19-102018-002883-B	< 1	
WS- 002884	6/22/2018	6/22/2019	1	Combo Fountain	In classroom 143	WF-06222018-002884	10/27/2018	FT-FY19-102018-002884-A	< 1	FT-FY19-102018-002884-B	< 1	
WS- 002886	6/22/2018	6/22/2019	2	Combo Fountain	In classroom 243	WF-06222018-002886	10/27/2018	FT-FY19-102018-002886-A	< 1	FT-FY19-102018-002886-B	< 1	
WS- 002887	6/22/2018	6/22/2019	1	Break Room	In parent resource center C105	WF-06222018-002887	10/27/2018	FT-FY19-102018-002887-A	< 1	FT-FY19-102018-002887-B	< 1	
WS- 002888	6/22/2018	6/22/2019	1	Cooler	In hallway adjacent to stairwell 1	High Left	WF-06222018-002888	10/27/2018	FT-FY19-102018-002888-A	< 1	FT-FY19-102018-002888-B	< 1
WS- 002889	6/22/2018	6/22/2019	1	Cooler	In hallway adjacent to stairwell 1	Low Right	WF-06222018-002889	10/27/2018	FT-FY19-102018-002889-A	< 1	FT-FY19-102018-002889-B	< 1
WS- 002890	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 125	WF-09242018-002890	10/27/2018	FT-FY19-102018-002890-A	< 1	FT-FY19-102018-002890-B	< 1	
WS- 002891	6/22/2018	6/22/2019	1	Combo Fountain	In classroom 125	WF-06222018-002891	10/27/2018	FT-FY19-102018-002891-A	< 1	FT-FY19-102018-002891-B	< 1	
WS- 002892	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 126	WF-09242018-002892	10/27/2018	FT-FY19-102018-002892-A	< 1	FT-FY19-102018-002892-B	< 1	
WS- 002893	6/22/2018	6/22/2019	1	Combo Fountain	In classroom 126	WF-06222018-002893	10/27/2018	FT-FY19-102018-002893-A	< 1	FT-FY19-102018-002893-B	< 1	
WS- 002894	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 127	WF-09242018-002894	10/27/2018	FT-FY19-102018-002894-A	< 1	FT-FY19-102018-002894-B	< 1	
WS- 002895	6/22/2018	6/22/2019	1	Combo Fountain	In classroom 127	WF-06222018-002895	10/27/2018	FT-FY19-102018-002895-A	< 1	FT-FY19-102018-002895-B	< 1	
WS- 002896	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 128	WF-09242018-002896	10/27/2018	FT-FY19-102018-002896-A	< 1	FT-FY19-102018-002896-B	< 1	

WS- 002897	6/22/2018	6/22/2019	1	Combo Fountain	In classroom 128	WF-06222018-002897	10/27/2018	FT-FY19-102018-002897-A	< 1	FT-FY19-102018-002897-B	1	
WS- 002898	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 132	WF-09242018-002898	10/27/2018	FT-FY19-102018-002898-A	< 1	FT-FY19-102018-002898-B	< 1	
WS- 002899	6/22/2018	6/22/2019	1	Combo Fountain	In classroom 132	WF-06222018-002899	10/27/2018	FT-FY19-102018-002899-A	< 1	FT-FY19-102018-002899-B	< 1	
WS- 002900	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 129	WF-09242018-002900	10/27/2018	FT-FY19-102018-002900-A	< 1	FT-FY19-102018-002900-B	< 1	
WS- 002901	6/22/2018	6/22/2019	1	Combo Fountain	In classroom 129	WF-06222018-002901	10/27/2018	FT-FY19-102018-002901-A	< 1	FT-FY19-102018-002901-B	< 1	
WS- 002902	6/22/2018	6/22/2019	1	Break Room	In staff lounge 123	WF-06222018-002902	10/27/2018	FT-FY19-102018-002902-A	< 1	FT-FY19-102018-002902-B	< 1	
WS- 002904	9/24/2018	9/24/2019	1	Classroom Faucet	In classroom 121 first clockwise from entry door	WF-09242018-002904	10/27/2018	FT-FY19-102018-002904-A	< 1	FT-FY19-102018-002904-B	< 1	
WS- 002906	6/22/2018	6/22/2019	1	Cooler	In multipurpose room	High Left	WF-06222018-002906	10/27/2018	FT-FY19-102018-002906-A	< 1	FT-FY19-102018-002906-B	< 1
WS- 002907	6/22/2018	6/22/2019	1	Cooler	In multipurpose room	Low Right	WF-06222018-002907	10/27/2018	FT-FY19-102018-002907-A	< 1	FT-FY19-102018-002907-B	< 1
WS- 002908	6/22/2018	6/22/2019	1	Bottle Filler	In multipurpose room		WF-06222018-002908	10/27/2018	FT-FY19-102018-002908-A	< 1	FT-FY19-102018-002908-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002731	1	Food Prep Sink	In kitchen		Left	10/27/2018	FT-FY19-102018-002731-A	< 1	FT-FY19-102018-002731-B	< 1