



# Guy Mason Recreation Center Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012541	3/12/2024	3/12/2025	Basement	Cooler	In hallway across from boiler room High Left	WF-03122024-012541	4/1/2024	FT-FY24-03202024-012541-A	<1	FT-FY24-03202024-012541-B	<1
WS- 012542	3/12/2024	3/12/2025	Basement	Cooler	In hallway across from boiler room Low Right	WF-03122024-012542	4/1/2024	FT-FY24-03202024-012542-A	<1	FT-FY24-03202024-012542-B	<1
WS- 012548	11/21/2023	11/21/2024	2	Food Prep Sink	In activity room 2A	WF-11212023-012548	4/1/2024	FT-FY24-03202024-012548-A	<1	FT-FY24-03202024-012548-B	<1
WS- 012549	3/12/2024	3/12/2025	2	Cooler	In hallway across from room 2A High Left	WF-03122024-012549	4/1/2024	FT-FY24-03202024-012549-A	<1	FT-FY24-03202024-012549-B	<1
WS- 012550	3/12/2024	3/12/2025	2	Cooler	In hallway across from room 2A Low Right	WF-03122024-012550	4/1/2024	FT-FY24-03202024-012550-A	<1	FT-FY24-03202024-012550-B	<1