



GUY MASON LEAD WATER TEST RESULTS



Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1 GUY MASON	WS- 012541	9/21/2016	Basement	Cooler	In hallway across from boiler room High	FT-82016-012541-A	< 1	FT-82016-012541-B	< 1
2 GUY MASON	WS- 012542	9/21/2016	Basement	Cooler	In hallway across from boiler room Low	FT-82016-012542-A	< 1	FT-82016-012542-B	< 1
3 GUY MASON	WS- 012548	9/21/2016	2	Food Prep Sink	In activity room 2A	FT-82016-012548-A	< 1	FT-82016-012548-B	< 1
4 GUY MASON	WS- 012549	9/21/2016	2	Cooler	In hallway across from room 2A High	FT-82016-012549-A	< 1	FT-82016-012549-B	< 1
5 GUY MASON	WS- 012550	9/21/2016	2	Cooler	In hallway across from room 2A Low	FT-82016-012550-A	< 1	FT-82016-012550-B	< 1