



H.D. Cooke Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002350	3/30/2020	3/30/2021	1	Cooler	In gym 142 High Left	WF-03302020-002350	1/19/2021	FT-FY21-012021-002350-A	<1	FT-FY21-012021-002350-B	<1
WS-002351	3/30/2020	3/30/2021	1	Cooler	In gym 142 Low Right	WF-03302020-002351	1/19/2021	FT-FY21-012021-002351-A	<1	FT-FY21-012021-002351-B	<1
WS-002352	3/30/2020	3/30/2021	1	Break Room	In work room 130	WF-03302020-002352	1/19/2021	FT-FY21-012021-002352-A	<1	FT-FY21-012021-002352-B	<1
WS-002353	3/30/2020	3/30/2021	1	Break Room	In staff lounge 137	WF-03302020-002353	1/19/2021	FT-FY21-012021-002353-A	<1	FT-FY21-012021-002353-B	<1
WS-002354	3/30/2020	3/30/2021	1	Combo Fountain	In classroom 132	WF-03302020-002354	1/19/2021	FT-FY21-012021-002354-A	<1	FT-FY21-012021-002354-B	<1
WS-002355	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 132	WF-09082020-002355	1/19/2021	FT-FY21-012021-002355-A	<1	FT-FY21-012021-002355-B	<1
WS-002356	3/30/2020	3/30/2021	1	Combo Fountain	In classroom 136	WF-03302020-002356	1/19/2021	FT-FY21-012021-002356-A	<1	FT-FY21-012021-002356-B	<1
WS-002357	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 136	WF-09082020-002357	1/19/2021	FT-FY21-012021-002357-A	<1	FT-FY21-012021-002357-B	<1
WS-002358	3/30/2020	3/30/2021	1	Combo Fountain	In classroom 133	WF-03302020-002358	1/19/2021	FT-FY21-012021-002358-A	<1	FT-FY21-012021-002358-B	<1
WS-002359	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 133	WF-09082020-002359	1/19/2021	FT-FY21-012021-002359-A	1.3	FT-FY21-012021-002359-B	<1
WS-002360	3/30/2020	3/30/2021	1	Combo Fountain	In classroom 135	WF-03302020-002360	1/19/2021	FT-FY21-012021-002360-A	<1	FT-FY21-012021-002360-B	<1
WS-002361	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 135	WF-09082020-002361	1/19/2021	FT-FY21-012021-002361-A	<1	FT-FY21-012021-002361-B	<1
WS-002366	3/30/2020	3/30/2021	1	Cooler	In hallway across from room 105 High Left	WF-03302020-002366	1/19/2021	FT-FY21-012021-002366-A	<1	FT-FY21-012021-002366-B	<1
WS-002367	3/30/2020	3/30/2021	1	Cooler	In hallway across from room 105 Low Right	WF-03302020-002367	1/19/2021	FT-FY21-012021-002367-A	<1	FT-FY21-012021-002367-B	<1
WS-002368	3/30/2020	3/30/2021	1	Health Suite	In health suite in exam room 103E	WF-03302020-002368	1/19/2021	FT-FY21-012021-002368-A	<1	FT-FY21-012021-002368-B	<1
WS-002369	3/30/2020	3/30/2021	1	Health Suite	In health suite in exam room 103C	WF-03302020-002369	1/19/2021	FT-FY21-012021-002369-A	2.8	FT-FY21-012021-002369-B	<1
WS-002370	3/30/2020	3/30/2021	1	Break Room	In break room 110	WF-03302020-002370	1/19/2021	FT-FY21-012021-002370-A	<1	FT-FY21-012021-002370-B	<1
WS-002374	3/30/2020	3/30/2021	2	Cooler	In hallway across from room 204 High Left	WF-03302020-002374	1/19/2021	FT-FY21-012021-002374-A	<1	FT-FY21-012021-002374-B	<1
WS-002375	3/30/2020	3/30/2021	2	Cooler	In hallway across from room 204 Low Right	WF-03302020-002375	1/19/2021	FT-FY21-012021-002375-A	<1	FT-FY21-012021-002375-B	<1
WS-002376	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 205	WF-03302020-002376	1/19/2021	FT-FY21-012021-002376-A	<1	FT-FY21-012021-002376-B	<1
WS-002377	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 205	WF-09082020-002377	1/19/2021	FT-FY21-012021-002377-A	<1	FT-FY21-012021-002377-B	<1
WS-002378	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 204	WF-03302020-002378	1/19/2021	FT-FY21-012021-002378-A	<1	FT-FY21-012021-002378-B	<1
WS-002379	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 204	WF-09082020-002379	1/19/2021	FT-FY21-012021-002379-A	<1	FT-FY21-012021-002379-B	<1
WS-002380	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 202	WF-03302020-002380	1/19/2021	FT-FY21-012021-002380-A	<1	FT-FY21-012021-002380-B	<1
WS-002381	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 202	WF-09082020-002381	1/19/2021	FT-FY21-012021-002381-A	<1	FT-FY21-012021-002381-B	<1
WS-002382	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 203	WF-03302020-002382	1/19/2021	FT-FY21-012021-002382-A	<1	FT-FY21-012021-002382-B	<1
WS-002383	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 203	WF-09082020-002383	1/19/2021	FT-FY21-012021-002383-A	<1	FT-FY21-012021-002383-B	<1
WS-002384	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 210	WF-03302020-002384	1/19/2021	FT-FY21-012021-002384-A	<1	FT-FY21-012021-002384-B	<1
WS-002385	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 210	WF-09082020-002385	1/19/2021	FT-FY21-012021-002385-A	<1	FT-FY21-012021-002385-B	<1
WS-002386	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 211	WF-03302020-002386	1/19/2021	FT-FY21-012021-002386-A	<1	FT-FY21-012021-002386-B	<1
WS-002387	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 211	WF-09082020-002387	1/19/2021	FT-FY21-012021-002387-A	<1	FT-FY21-012021-002387-B	<1
WS-002388	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 212	WF-03302020-002388	1/19/2021	FT-FY21-012021-002388-A	<1	FT-FY21-012021-002388-B	<1

WS- 002389	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 212		WF-09082020-002389	1/19/2021	FT-FY21-012021-002389-A	<1	FT-FY21-012021-002389-B	<1
WS- 002390	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 213		WF-03302020-002390	1/19/2021	FT-FY21-012021-002390-A	<1	FT-FY21-012021-002390-B	<1
WS- 002391	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 213		WF-09082020-002391	1/19/2021	FT-FY21-012021-002391-A	<1	FT-FY21-012021-002391-B	<1
WS- 002392	3/30/2020	3/30/2021	2	Combo Fountain	In resource room 241		WF-03302020-002392	1/19/2021	FT-FY21-012021-002392-A	<1	FT-FY21-012021-002392-B	<1
WS- 002393	9/8/2020	9/8/2021	2	Combo Faucet	In resource room 241		WF-09082020-002393	1/19/2021	FT-FY21-012021-002393-A	<1	FT-FY21-012021-002393-B	<1
WS- 002394	3/30/2020	3/30/2021	2	Combo Fountain	In resource room 230		WF-03302020-002394	1/19/2021	FT-FY21-012021-002394-A	<1	FT-FY21-012021-002394-B	<1
WS- 002395	9/8/2020	9/8/2021	2	Combo Faucet	In resource room 230		WF-09082020-002395	1/19/2021	FT-FY21-012021-002395-A	<1	FT-FY21-012021-002395-B	<1
WS- 002396	3/30/2020	3/30/2021	2	Combo Fountain	In resource room 236		WF-03302020-002396	1/19/2021	FT-FY21-012021-002396-A	<1	FT-FY21-012021-002396-B	<1
WS- 002397	9/8/2020	9/8/2021	2	Combo Faucet	In resource room 236		WF-09082020-002397	1/19/2021	FT-FY21-012021-002397-A	<1	FT-FY21-012021-002397-B	<1
WS- 002398	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 231		WF-03302020-002398	1/19/2021	FT-FY21-012021-002398-A	<1	FT-FY21-012021-002398-B	<1
WS- 002399	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 231		WF-09082020-002399	1/19/2021	FT-FY21-012021-002399-A	<1	FT-FY21-012021-002399-B	<1
WS- 002400	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 235		WF-03302020-002400	1/19/2021	FT-FY21-012021-002400-A	<1	FT-FY21-012021-002400-B	<1
WS- 002401	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 235		WF-09082020-002401	1/19/2021	FT-FY21-012021-002401-A	<1	FT-FY21-012021-002401-B	<1
WS- 002402	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 232		WF-03302020-002402	1/19/2021	FT-FY21-012021-002402-A	<1	FT-FY21-012021-002402-B	<1
WS- 002403	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 232		WF-09082020-002403	1/19/2021	FT-FY21-012021-002403-A	<1	FT-FY21-012021-002403-B	<1
WS- 002404	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 234		WF-03302020-002404	1/19/2021	FT-FY21-012021-002404-A	<1	FT-FY21-012021-002404-B	<1
WS- 002405	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 234		WF-09082020-002405	1/19/2021	FT-FY21-012021-002405-A	<1	FT-FY21-012021-002405-B	<1
WS- 002406	3/30/2020	3/30/2021	3	Cooler	In hallway across from room 304	High Left	WF-03302020-002406	1/19/2021	FT-FY21-012021-002406-A	<1	FT-FY21-012021-002406-B	<1
WS- 002407	3/30/2020	3/30/2021	3	Cooler	In hallway across from room 304	Low Right	WF-03302020-002407	1/19/2021	FT-FY21-012021-002407-A	<1	FT-FY21-012021-002407-B	<1
WS- 002408	3/30/2020	3/30/2021	3	Combo Fountain	In classroom 303		WF-03302020-002408	1/19/2021	FT-FY21-012021-002408-A	<1	FT-FY21-012021-002408-B	<1
WS- 002409	9/8/2020	9/8/2021	3	Combo Faucet	In classroom 303		WF-09082020-002409	1/19/2021	FT-FY21-012021-002409-A	<1	FT-FY21-012021-002409-B	<1
WS- 002410	9/8/2020	9/8/2021	3	Combo Faucet	In classroom 302		WF-09082020-002410	1/19/2021	FT-FY21-012021-002410-A	<1	FT-FY21-012021-002410-B	<1
WS- 002411	3/30/2020	3/30/2021	3	Combo Fountain	In classroom 302		WF-03302020-002411	1/19/2021	FT-FY21-012021-002411-A	<1	FT-FY21-012021-002411-B	<1
WS- 002412	3/30/2020	3/30/2021	3	Combo Fountain	In classroom 304		WF-03302020-002412	1/19/2021	FT-FY21-012021-002412-A	<1	FT-FY21-012021-002412-B	<1
WS- 002413	9/8/2020	9/8/2021	3	Combo Faucet	In classroom 304		WF-09082020-002413	1/19/2021	FT-FY21-012021-002413-A	<1	FT-FY21-012021-002413-B	<1
WS- 002414	3/30/2020	3/30/2021	3	Combo Fountain	In classroom 305		WF-03302020-002414	1/19/2021	FT-FY21-012021-002414-A	<1	FT-FY21-012021-002414-B	<1
WS- 002415	9/8/2020	9/8/2021	3	Combo Faucet	In classroom 305		WF-09082020-002415	1/19/2021	FT-FY21-012021-002415-A	<1	FT-FY21-012021-002415-B	<1
WS- 002416	3/30/2020	3/30/2021	3	Break Room	In staff lounge 319		WF-03302020-002416	1/19/2021	FT-FY21-012021-002416-A	<1	FT-FY21-012021-002416-B	<1
WS- 002417	3/30/2020	3/30/2021	3	Combo Fountain	In classroom 310		WF-03302020-002417	1/19/2021	FT-FY21-012021-002417-A	<1	FT-FY21-012021-002417-B	<1
WS- 002418	9/8/2020	9/8/2021	3	Combo Faucet	In classroom 310		WF-09082020-002418	1/19/2021	FT-FY21-012021-002418-A	<1	FT-FY21-012021-002418-B	<1
WS- 002419	3/30/2020	3/30/2021	3	Combo Fountain	In classroom 311		WF-03302020-002419	1/19/2021	FT-FY21-012021-002419-A	<1	FT-FY21-012021-002419-B	<1
WS- 002420	9/8/2020	9/8/2021	3	Combo Faucet	In classroom 311		WF-09082020-002420	1/19/2021	FT-FY21-012021-002420-A	1.8	FT-FY21-012021-002420-B	<1
WS- 002421	3/30/2020	3/30/2021	3	Combo Fountain	In classroom 312		WF-03302020-002421	1/19/2021	FT-FY21-012021-002421-A	<1	FT-FY21-012021-002421-B	<1
WS- 002422	9/8/2020	9/8/2021	3	Combo Faucet	In classroom 312		WF-09082020-002422	1/19/2021	FT-FY21-012021-002422-A	<1	FT-FY21-012021-002422-B	<1
WS- 002423	3/30/2020	3/30/2021	3	Combo Fountain	In classroom 313		WF-03302020-002423	1/19/2021	FT-FY21-012021-002423-A	<1	FT-FY21-012021-002423-B	<1
WS- 002424	9/8/2020	9/8/2021	3	Combo Faucet	In classroom 313		WF-09082020-002424	1/19/2021	FT-FY21-012021-002424-A	<1	FT-FY21-012021-002424-B	<1
WS- 002425	3/30/2020	3/30/2021	3	Combo Fountain	In classroom 314		WF-03302020-002425	1/19/2021	FT-FY21-012021-002425-A	<1	FT-FY21-012021-002425-B	<1
WS- 002427	3/30/2020	3/30/2021	3	Combo Fountain	In resource room 341		WF-03302020-002427	1/19/2021	FT-FY21-012021-002427-A	<1	FT-FY21-012021-002427-B	<1

WS- 002428	9/8/2020	9/8/2021	3	Combo Faucet	In resource room 341	WF-09082020-002428	1/19/2021	FT-FY21-012021-002428-A	<1	FT-FY21-012021-002428-B	<1
WS- 002429	3/30/2020	3/30/2021	2	Combo Fountain	In classroom 221	WF-03302020-002429	1/19/2021	FT-FY21-012021-002429-A	<1	FT-FY21-012021-002429-B	<1
WS- 002430	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 221	WF-09082020-002430	1/19/2021	FT-FY21-012021-002430-A	<1	FT-FY21-012021-002430-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002363	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen second clockwise from entry door	Left	WF-01062021-002363	1/19/2021	FT-FY21-012021-002363-A	<1	FT-FY21-012021-002363-B	<1
WS- 002364	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen third clockwise from entry door	Right	WF-01062021-002364	1/19/2021	FT-FY21-012021-002364-A	<1	FT-FY21-012021-002364-B	<1
WS- 002365	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen fourth clockwise from entry door		WF-01062021-002365	1/19/2021	FT-FY21-012021-002365-A	<1	FT-FY21-012021-002365-B	<1